

ROSIORII DE VEDE, Romania

WMO: 154700

Lat: 44.1072N

Lon: 24.9786E

Elev: 103

StdP: 100.09

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.5	-11.2	-16.4	0.9	-13.3	-13.0	1.2	-10.1	10.9	1.0	9.5	2.4	1.5	270	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	34.9	20.8	33.2	20.4	31.5	20.0	23.0	30.1	22.1	29.1	21.3	28.1	2.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.0	15.9	24.9	20.2	15.0	24.4	19.3	14.2	23.7	68.5	30.1	65.3	29.2	62.4	28.0	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4)	9.2	7.8	6.7	DB	-18.6	37.2	4.1	2.2	-21.6	38.8	-24.0	40.1	-26.3	41.3	-29.3	42.9
(5)				WB	-18.8	24.3	4.1	1.3	-21.7	25.2	-24.1	25.9	-26.4	26.6	-29.4	27.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	-1.7	1.4	6.8	12.3	17.5	21.6	23.8	23.8	18.7	12.2	6.3	0.2
	DBStd	9.78	5.26	5.60	4.41	3.53	3.31	3.20	2.78	2.92	3.57	4.19	4.34	4.72
	HDD10.0	1198	363	243	116	17	1	0	0	0	0	26	127	305
	HDD18.3	2861	622	476	357	183	55	8	1	2	38	193	363	563
	CDD10.0	1911	0	1	17	86	233	347	428	427	261	94	14	0
	CDD18.3	532	0	0	0	2	30	106	171	170	50	3	0	0
	CDH23.3	5661	0	0	1	33	320	1088	1840	1829	499	49	1	0
	CDH26.7	2355	0	0	0	4	67	422	843	853	158	7	0	0
Wind	WSAvg	2.5	2.4	2.8	3.1	2.9	2.5	2.2	2.1	2.1	2.5	2.4	2.5	2.5
Precipitation	PrecAvg	537	34	26	34	44	59	65	62	47	50	45	33	38
	PrecMax	952	85	59	84	136	130	137	191	225	160	116	93	152
	PrecMin	276	3	2	1	2	10	22	17	6	1	0	0	1
	PrecStd	144	19	15	22	25	27	27	46	45	37	29	24	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	17.1	21.7	27.1	30.6	35.5	38.0	37.2	33.2	27.6	20.8	12.7
		MCWB	7.8	10.9	12.4	17.0	18.8	21.3	19.9	20.7	19.4	17.4	14.7	9.8
	2%	DB	8.7	13.9	19.3	23.5	28.4	33.0	34.9	34.9	30.5	24.4	17.1	9.8
		MCWB	6.7	9.1	11.6	15.2	18.1	20.9	20.8	20.6	18.3	16.0	13.1	7.9
	5%	DB	6.4	11.0	16.9	21.2	26.8	30.8	33.0	33.1	28.3	21.6	14.5	7.5
		MCWB	5.2	8.0	10.3	13.9	17.8	20.4	20.5	20.3	17.6	15.0	11.7	6.3
	10%	DB	4.4	8.5	14.6	19.3	25.0	29.1	31.3	31.4	26.2	19.3	12.4	5.8
		MCWB	3.5	6.3	9.2	12.9	17.0	19.7	20.1	19.9	17.0	14.1	10.5	4.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	11.6	13.7	17.8	21.1	23.9	23.8	24.1	20.7	18.6	15.1	10.0
		MCDB	11.0	15.3	19.6	25.3	27.6	31.1	31.0	31.4	28.5	24.9	19.2	12.3
	2%	WB	6.8	9.6	12.1	16.1	19.6	22.6	22.7	23.0	19.6	17.0	13.6	8.0
		MCDB	8.3	13.2	18.2	22.4	26.0	29.9	29.9	29.8	26.8	22.2	16.7	9.6
	5%	WB	5.3	8.1	10.9	14.8	18.7	21.5	22.0	21.9	18.7	15.9	12.2	6.6
		MCDB	6.4	10.4	16.1	19.9	24.8	28.3	29.1	28.6	25.5	20.3	13.9	7.5
	10%	WB	3.5	6.5	9.6	13.6	17.7	20.6	21.3	21.0	17.9	14.7	10.8	5.0
		MCDB	4.4	8.3	13.9	17.9	23.4	27.0	28.0	28.1	24.3	18.6	12.2	5.7
Mean Daily Temperature Range	5% DB	MDBR	6.2	7.8	10.0	10.9	11.7	12.1	12.6	12.7	11.7	10.1	7.3	6.1
		MCDBR	8.9	12.7	14.8	14.5	14.6	14.7	15.3	15.5	15.3	14.6	12.0	8.9
		MCWBR	6.7	8.2	8.1	7.3	6.1	5.1	4.5	4.5	5.4	7.1	7.6	6.8
	5% WB	MCDBR	8.5	11.8	13.5	12.8	13.1	13.3	13.1	12.7	12.9	12.7	10.3	8.6
		MCWBR	6.5	8.0	7.6	6.7	6.1	5.3	4.5	4.5	5.0	6.6	6.7	6.8
Clear-Sky Solar Irradiance	taub	0.344	0.375	0.411	0.464	0.439	0.446	0.457	0.473	0.436	0.400	0.372	0.348	
	taud	2.284	2.212	2.167	2.036	2.183	2.200	2.175	2.126	2.193	2.280	2.307	2.303	
	Ebn at Noon	756	795	816	800	836	829	814	784	781	759	715	709	
	Edh at Noon	86	110	131	161	143	142	144	146	126	102	84	77	
All-Sky Solar Radiation	RadAvg	1.44	2.27	3.47	4.75	5.86	6.43	6.50	5.77	4.19	2.72	1.52	1.17	
	RadStd	0.21	0.33	0.36	0.47	0.46	0.43	0.41	0.36	0.33	0.33	0.21	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (66 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.49	N/A	N/A	N/A	N/A	N/A	N/A	-137	+64	N/A

Nomenclature: See separate page