

PASSO RESIA, Italy

WMO: 160083

Lat: 46.833N

Lon: 10.500E

Elev: 5906

StdP: 11.82

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.0	10.6	-4.0	5.5	14.4	-0.3	6.7	18.5	21.7	23.7	18.8	21.1	5.8	0	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.7	77.1	57.5	73.7	56.8	71.3	56.1	61.9	70.3	60.2	68.2	58.9	66.6	5.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.2	93.7	64.3	57.4	87.9	62.9	55.8	82.6	61.4	30.9	71.1	29.6	68.0	28.5	66.2	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	14.7	12.5	4.1	82.2	5.3	3.7	0.2	84.8	-2.9	87.0	-5.9	89.1	-9.7	91.7
			2.9	65.7	5.2	2.3	-0.8	67.4	-3.9	68.7	-6.8	70.0	-10.6	71.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.6	26.6	28.7	35.5	42.1	49.5	56.6	59.8	59.2	52.8	46.0	36.0	29.2	(6)
	DBStd	13.33	6.85	7.56	7.20	6.40	5.61	6.28	5.40	5.18	5.33	6.40	7.09	6.86	(7)
	HDD50	3366	727	597	448	245	77	15	3	3	31	154	422	644	(8)
	HDD65	7848	1192	1017	913	686	479	260	174	190	367	590	871	1109	(9)
	CDD50	1022	0	0	0	9	63	211	306	288	114	29	2	0	(10)
	CDD65	29	0	0	0	0	0	7	12	10	0	0	0	0	(11)
	CDH74	286	0	0	0	0	1	81	104	94	6	0	0	0	(12)
	CDH80	35	0	0	0	0	0	9	9	16	1	0	0	0	(13)
	WSAvg	5.0	5.2	5.3	5.0	5.5	5.3	5.1	4.9	4.2	4.6	4.6	5.3	5.0	(14)
(15) Precipitation	PrecAvg	27.6	1.4	1.3	1.5	1.5	2.4	3.3	4.1	4.1	2.6	2.3	2.0	1.5	(15)
	PrecMax	35.3	3.3	6.3	3.7	3.1	4.8	4.9	6.5	7.4	5.5	6.1	6.2	4.2	(16)
	PrecMin	20.0	0.3	0.3	0.3	0.3	0.7	1.5	2.8	1.7	0.9	0.0	0.2	0.2	(17)
	PrecStd	3.9	0.8	1.2	0.8	0.6	0.9	0.9	0.9	1.4	1.2	1.3	1.3	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.7	52.0	59.4	67.6	71.9	80.6	80.8	82.2	73.4	66.5	58.8	48.3	(19)
		MCWB	37.3	38.3	41.8	48.8	53.1	56.8	59.3	59.2	53.5	50.0	46.3	37.4	(20)
	2%	DB	41.4	46.4	55.3	61.2	67.8	75.6	76.9	75.8	68.4	62.2	52.0	43.2	(21)
		MCWB	34.0	36.1	40.9	45.4	50.8	56.7	58.0	57.6	54.4	49.1	43.0	35.0	(22)
	5%	DB	38.1	42.4	50.2	57.3	64.1	71.9	73.6	72.0	65.4	58.7	48.0	39.6	(23)
		MCWB	32.4	33.5	38.1	43.3	49.3	55.6	57.3	56.9	53.3	48.2	41.0	33.6	(24)
	10%	DB	35.3	37.8	46.3	53.5	60.6	68.2	70.2	68.9	61.2	55.1	44.3	37.3	(25)
		MCWB	30.9	31.5	36.8	41.8	48.4	54.4	56.8	56.6	51.7	47.9	39.3	32.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.3	39.9	44.5	50.8	57.0	62.9	64.9	63.5	59.9	55.0	48.9	39.7	(27)
		MCDB	44.0	48.6	55.5	60.9	65.8	71.6	73.2	73.2	68.1	61.0	55.2	43.0	(28)
	2%	WB	35.5	36.9	41.9	47.9	54.1	60.5	62.1	61.4	57.4	52.4	44.7	37.1	(29)
		MCDB	39.0	44.6	51.5	57.4	61.8	69.4	70.3	69.5	64.4	57.6	49.7	41.0	(30)
	5%	WB	33.2	34.4	39.7	45.4	52.1	58.4	60.4	59.8	55.5	50.6	42.3	34.7	(31)
		MCDB	36.4	40.0	47.5	54.3	59.5	67.3	68.5	67.3	61.0	55.4	45.5	38.3	(32)
	10%	WB	31.3	32.3	37.6	43.6	50.3	56.5	59.0	58.3	53.9	48.6	40.3	32.8	(33)
		MCDB	34.5	36.5	43.9	51.1	57.3	64.9	66.8	65.5	59.2	53.3	43.0	36.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.1	15.4	17.0	16.5	16.0	17.6	17.7	16.4	15.5	14.2	11.8	12.1	(35)
		MCDBR	17.2	20.7	23.5	23.8	22.4	23.4	22.8	22.1	21.1	20.2	18.1	15.7	(36)
		MCWBR	11.5	12.4	11.9	10.7	9.5	9.4	8.9	8.6	9.2	9.9	10.3	9.9	(37)
	5% WB	MCDBR	14.5	17.9	20.6	20.4	18.1	20.1	18.7	17.6	17.1	16.1	14.2	13.5	(38)
		MCWBR	10.7	11.7	11.6	10.3	9.4	9.9	9.6	8.9	9.0	9.5	9.2	9.3	(39)
(40) Clear-Sky Solar Irradiance	taub		0.227	0.250	0.291	0.334	0.349	0.356	0.353	0.346	0.316	0.292	0.258	0.227	(40)
	taud		2.358	2.299	2.260	2.277	2.332	2.356	2.361	2.399	2.473	2.513	2.496	2.406	(41)
	Ebn at Noon		284	296	297	292	290	288	287	285	286	278	270	272	(42)
	Edh at Noon		22	29	36	39	39	38	37	35	29	24	19	19	(43)
(44) All-Sky Solar Radiation	RadAvg		489	789	1164	1411	1546	1757	1766	1548	1186	803	482	403	(44)
	RadStd		54	91	138	193	170	147	142	148	125	100	77	51	(45)

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	+1.42	N/A	N/A	N/A	N/A
(47)	Regional (107 neighbors)	+0.61	N/A	N/A	+1.13	+0.72	+0.63	N/A	N/A	+104

Nomenclature: See separate page