

PAGANELLA, Italy

WMO: 160220

Lat: 46.142N

Lon: 11.037E

Elev: 6985

StdP: 11.35

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.9	8.3	-14.8	3.2	20.4	-9.9	4.2	18.9	37.0	15.4	32.8	15.6	18.4	0	0.777

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	65.6	56.1	63.1	54.9	61.0	53.9	58.0	62.9	56.5	61.0	55.0	59.5	7.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.0	86.8	60.4	54.5	82.1	58.9	53.0	77.9	57.4	28.4	63.0	27.3	61.2	26.2	59.5	65.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.8	27.7	23.6	DB	2.3	69.9	4.4	3.5	-0.8	72.4	-3.4	74.4	-5.9	76.4	-9.1	78.9	(4)
(5)			WB	0.6	61.7	3.9	1.6	-2.2	62.9	-4.5	63.8	-6.7	64.8	-9.6	65.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	37.0	24.0	23.4	27.7	32.7	41.1	49.3	52.7	52.2	44.8	38.9	30.4	25.4	(6)
(7)		DBStd	12.64	7.52	8.01	7.48	6.43	6.72	6.94	5.43	5.70	6.10	6.79	7.63	7.59	(7)
(8)		HDD50	5096	807	744	691	518	286	96	37	43	174	347	589	764	(8)
(9)		HDD65	10234	1272	1164	1156	968	741	471	382	397	605	810	1039	1229	(9)
(10)		CDD50	338	0	0	0	0	10	75	120	112	19	2	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	9.3	10.8	10.3	9.7	9.2	9.1	8.3	8.1	8.2	7.7	8.4	10.1	11.1	(14)
(15)	Precipitation	PrecAvg	35.7	1.0	1.2	1.5	2.6	3.7	4.1	3.6	3.5	3.6	3.8	4.0	1.4	(15)
(16)		PrecMax	51.6	5.4	7.3	6.5	5.0	8.9	13.1	6.6	8.1	8.7	10.8	12.5	5.2	(16)
(17)		PrecMin	20.7	0.0	0.3	0.3	1.1	1.3	0.6	0.9	0.9	0.0	0.0	1.0	0.2	(17)
(18)		PrecStd	6.7	1.0	1.4	1.3	1.0	1.9	2.3	1.7	1.7	2.4	2.7	2.7	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.6	45.0	46.0	50.2	61.8	68.0	68.0	68.3	60.9	55.7	48.8	44.7	(19)
(20)			MCWB	32.6	32.6	35.6	40.8	51.6	57.7	56.5	57.0	52.1	45.1	37.8	31.6	(20)
(21)		2%	DB	40.6	41.3	42.8	46.6	57.2	64.7	65.0	64.8	57.6	52.1	45.1	40.0	(21)
(22)			MCWB	30.7	30.8	33.6	39.8	49.1	55.5	56.1	55.7	50.5	42.4	36.0	29.3	(22)
(23)		5%	DB	37.1	37.6	40.7	44.1	53.8	62.3	62.8	62.6	55.2	49.7	42.7	37.4	(23)
(24)			MCWB	28.2	29.0	32.5	38.1	47.1	54.2	55.2	54.7	49.0	41.2	34.1	28.0	(24)
(25)		10%	DB	33.9	34.1	37.8	41.2	50.4	59.1	60.6	60.4	52.8	47.2	39.6	35.0	(25)
(26)			MCWB	27.2	27.0	31.2	36.6	44.6	52.4	54.0	54.0	47.7	40.6	33.5	27.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.0	34.6	37.4	43.2	52.8	59.7	60.0	59.8	54.7	48.6	42.2	34.2	(27)
(28)			MCD B	42.3	42.3	42.6	47.1	59.0	65.4	65.0	65.2	58.1	51.7	45.8	36.9	(28)
(29)		2%	WB	31.9	32.1	35.5	41.2	50.0	57.3	58.0	57.6	52.3	46.4	38.7	32.4	(29)
(30)			MCD B	35.9	37.6	40.2	45.2	55.6	62.1	62.5	62.4	55.7	48.6	41.8	34.7	(30)
(31)		5%	WB	30.3	30.3	33.7	39.2	47.8	55.2	56.4	56.1	50.4	44.6	37.1	31.3	(31)
(32)			MCD B	33.6	35.3	38.0	42.3	52.7	60.0	60.9	60.7	53.3	46.5	39.3	33.7	(32)
(33)		10%	WB	28.8	28.5	32.2	37.1	45.6	53.4	55.0	54.5	48.7	42.9	35.6	29.8	(33)
(34)			MCD B	32.4	32.8	36.1	40.5	49.9	58.2	59.3	58.8	51.5	45.1	37.4	32.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.9	7.3	8.1	8.4	10.2	11.6	11.5	10.4	9.0	7.5	6.4	6.7	(35)
(36)			MCD BR	9.7	8.9	9.4	9.9	13.2	13.5	12.9	11.9	10.3	9.3	8.3	8.7	(36)
(37)			MCWBR	6.4	6.0	6.6	6.9	9.3	9.8	9.5	9.0	8.5	7.5	6.0	5.7	(37)
(38)		5% WB	MCD BR	7.6	7.9	8.4	9.2	12.6	12.8	12.4	11.2	9.5	7.7	6.3	6.8	(38)
(39)			MCWBR	6.0	6.1	6.5	6.8	9.1	9.9	9.7	9.0	8.3	7.1	5.8	6.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.229	0.250	0.287	0.326	0.334	0.347	0.340	0.333	0.316	0.297	0.260	0.230	(40)	
(41)		taud	2.462	2.439	2.422	2.382	2.398	2.387	2.401	2.438	2.478	2.523	2.564	2.515	(41)	
(42)		Ebn at Noon	289	301	301	296	296	291	291	290	287	278	274	278	(42)	
(43)		Edh at Noon	20	26	31	36	36	37	36	33	29	24	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	497	784	1187	1437	1634	1868	1900	1641	1252	810	491	416	(44)	
(45)		RadStd	62	97	149	185	166	123	123	131	108	109	77	51	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+68	N/A	(46)
(47)	Regional (75 neighbors)	+0.65	N/A	N/A	+1.21	+0.67	N/A	N/A	-194	+119	+23	(47)

Nomenclature: See separate page