

TORINO BRIC DELLA CROCE, Italy

WMO: 160610

Lat: 45.034N

Lon: 7.733E

Elev: 710

StdP: 93.08

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.8	-3.1	-20.8	0.6	2.5	-17.8	0.9	3.1	11.8	7.5	10.1	7.0	1.4	0	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	28.2	20.8	27.1	20.4	26.0	19.8	23.4	25.8	22.3	25.0	21.4	24.3	1.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	19.0	24.7	21.5	17.6	23.9	20.3	16.4	23.1	73.7	26.1	69.5	25.3	65.8	24.4	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	6.9	5.4	DB	-5.7	30.3	2.1	1.4	-7.2	31.3	-8.4	32.1	-9.6	32.9	-11.1	34.0	(4)
(5)			WB	-7.2	24.3	1.8	1.7	-8.5	25.6	-9.5	26.6	-10.5	27.6	-11.9	28.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.1	3.1	3.9	8.1	11.2	15.2	19.3	21.6	21.1	17.2	12.6	7.3	3.8	(6)	
	DBStd	7.39	3.47	3.75	4.19	3.77	3.49	3.33	2.79	3.07	2.95	3.30	3.24	3.36	(7)	
	HDD10.0	806	217	172	86	29	3	0	0	0	0	14	92	192	(8)	
	HDD18.3	2576	472	403	317	216	108	28	7	9	56	178	332	449	(9)	
	CDD10.0	1567	2	2	28	65	165	279	360	346	215	94	10	1	(10)	
	CDD18.3	297	0	0	0	1	12	57	109	97	21	1	0	0	(11)	
	CDH23.3	1169	0	0	0	1	24	222	481	413	27	1	0	0	(12)	
	CDH26.7	162	0	0	0	0	1	31	60	69	1	0	0	0	(13)	
(14) Wind	WSAvg	1.6	1.5	1.5	1.9	2.0	1.9	1.7	1.7	1.5	1.4	1.1	1.3	1.4	(14)	
(15) Precipitation	PrecAvg	816	37	53	59	77	108	92	48	85	81	85	62	35	(15)	
	PrecMax	1339	95	258	142	179	255	175	139	181	275	259	172	141	(16)	
	PrecMin	470	1	2	0	0	10	32	9	0	2	0	3	1	(17)	
	PrecStd	220	28	68	40	52	64	38	34	47	70	70	51	32	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	15.0	19.9	22.2	25.7	29.2	29.8	30.8	25.7	21.7	17.0	14.0	(19)	
		MCWB	7.3	7.4	11.0	14.2	17.7	20.8	22.2	21.8	18.6	15.1	10.1	5.4	(20)	
	2%	DB	12.1	12.2	17.2	20.0	23.8	27.2	28.1	28.5	24.1	19.1	14.3	11.1	(21)	
		MCWB	5.1	5.6	9.5	12.8	16.7	20.0	20.8	21.1	18.0	14.4	9.8	4.2	(22)	
	5%	DB	9.2	10.2	15.3	18.1	22.0	25.9	27.1	27.0	22.8	18.0	12.4	9.2	(23)	
		MCWB	4.0	4.8	8.9	11.9	15.7	19.6	20.4	20.6	17.3	14.3	8.5	4.0	(24)	
	10%	DB	7.5	8.9	13.8	16.6	20.2	24.2	26.0	25.6	21.2	16.8	11.2	8.0	(25)	
		MCWB	3.2	4.3	8.1	11.1	14.6	18.7	19.8	20.0	16.4	14.0	8.3	3.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	9.0	13.1	16.4	20.4	23.7	24.9	25.0	21.1	17.8	12.9	8.7	(27)	
		MCDB	13.6	11.3	16.5	19.4	23.5	26.2	27.2	27.0	23.4	19.0	15.2	9.8	(28)	
	2%	WB	6.6	7.5	11.4	14.4	18.1	22.2	23.4	23.4	20.0	16.5	11.3	7.0	(29)	
		MCDB	9.6	9.8	14.7	18.0	21.6	25.0	25.8	25.8	22.4	17.7	12.7	8.3	(30)	
	5%	WB	5.4	6.5	10.1	13.0	16.9	21.1	22.3	22.3	19.0	15.6	10.3	5.9	(31)	
		MCDB	7.5	8.6	13.6	16.9	20.5	23.9	25.0	24.9	21.2	16.9	11.4	7.4	(32)	
	10%	WB	4.4	5.4	9.1	11.8	15.8	19.9	21.3	21.3	18.0	14.7	9.5	5.0	(33)	
		MCDB	6.6	7.8	12.5	15.5	19.0	23.4	24.4	24.3	20.2	16.1	10.5	6.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.7	6.2	6.5	6.7	7.0	7.2	6.6	5.7	4.2	3.7	3.8	(35)	
		MCDBR	6.3	6.4	7.7	7.9	8.0	7.6	7.5	7.3	6.8	5.3	4.8	5.4	(36)	
	5% WB	MCWBR	4.4	4.5	5.0	4.8	5.0	4.9	4.9	4.8	4.3	3.9	4.1	3.9	(37)	
		MCWBR	4.9	5.4	6.8	7.1	7.1	6.9	6.9	6.5	5.9	4.5	3.6	4.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.291	0.313	0.351	0.392	0.396	0.410	0.399	0.394	0.382	0.364	0.321	0.286	(40)	
		taud	2.478	2.422	2.344	2.246	2.283	2.282	2.312	2.333	2.342	2.383	2.467	2.500	(41)	
	Edn at Noon		833	874	879	867	873	859	865	856	834	797	783	802	(42)	
		Edh at Noon	68	87	108	130	129	130	125	118	107	90	69	61	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.64	2.46	3.61	4.46	5.29	6.19	6.39	5.53	4.22	2.66	1.62	1.39	(44)	
	RadStd		0.19	0.32	0.44	0.49	0.46	0.44	0.42	0.33	0.32	0.34	0.24	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (54 neighbors)	+0.31	N/A	N/A	+0.63	N/A	N/A	N/A	N/A	+60	+18

Nomenclature: See separate page