

MILANO LINATE, Italy

WMO: 160800

Lat: 45.445N

Lon: 9.277E

Elev: 353

StdP: 14.51

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.8	27.1	12.1	10.3	39.6	16.4	12.8	37.8	20.2	48.2	16.8	48.0	1.9	190	0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.8	92.6	74.8	89.9	73.3	87.9	72.1	77.3	88.2	75.6	85.9	74.0	84.3	5.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.0	128.5	83.3	72.2	120.6	81.4	70.6	114.2	79.9	41.0	88.2	39.2	85.8	37.7	84.0	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	12.0	9.8	20.5	96.0	3.6	2.3	18.0	97.6	15.9	99.0	13.9	100.2	11.3	101.9
			19.3	79.0	3.6	2.5	16.7	80.8	14.6	82.3	12.6	83.7	10.0	85.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.1	38.7	42.1	50.4	57.3	65.8	73.6	77.4	76.3	68.3	58.9	48.1	39.7	(6)
	DBStd	14.66	4.75	5.57	5.89	5.47	5.52	5.58	4.16	4.67	5.08	5.68	5.84	5.37	(7)
	HDD50	1076	351	225	66	7	0	0	0	0	0	5	101	321	(8)
	HDD65	3723	815	641	453	235	57	5	0	25	201	506	785		(9)
	CDD50	4049	1	4	79	227	491	708	849	815	548	281	45	1	(10)
	CDD65	1219	0	0	0	5	83	263	384	350	122	12	0	0	(11)
	CDH74	11016	0	0	8	56	647	2405	3840	3241	780	39	0	0	(12)
	CDH80	4047	0	0	0	5	152	880	1547	1284	175	4	0	0	(13)
	WSAvg	3.6	3.0	3.5	4.3	4.5	4.4	4.2	4.1	3.4	3.1	2.6	2.9	2.7	(14)
(15) Precipitation	PrecAvg	38.2	3.0	2.6	3.2	3.1	3.7	2.8	2.4	3.3	2.8	4.1	3.9	2.4	(15)
	PrecMax	55.6	10.8	5.9	8.0	9.6	11.4	6.0	8.0	7.0	8.4	16.4	10.4	6.1	(16)
	PrecMin	27.1	0.0	0.0	0.2	0.2	0.2	0.9	0.6	0.0	0.1	0.1	0.0	0.0	(17)
	PrecStd	8.9	2.6	1.8	2.1	2.2	2.8	1.3	1.9	2.2	2.3	3.7	2.5	1.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.1	64.4	73.8	79.2	88.5	94.5	94.7	96.4	87.7	78.5	65.8	56.8	(19)
		MCWB	46.7	51.6	55.8	61.5	69.6	76.3	74.2	77.3	70.4	65.0	59.0	47.8	(20)
	2%	DB	52.2	58.9	68.6	75.2	84.2	91.2	91.8	92.6	84.4	74.0	61.1	52.2	(21)
		MCWB	44.7	48.5	54.5	59.8	66.9	74.0	74.5	74.8	69.2	64.0	55.2	47.8	(22)
	5%	DB	48.6	55.1	65.4	72.0	80.6	88.0	89.8	89.6	82.0	71.3	58.8	50.0	(23)
		MCWB	43.6	46.2	53.4	57.9	65.2	72.1	73.7	73.2	68.0	62.2	54.3	46.6	(24)
	10%	DB	46.4	51.6	62.0	68.8	77.3	85.5	87.8	87.0	78.7	68.1	56.7	48.0	(25)
		MCWB	42.6	44.8	51.8	56.6	63.6	70.6	72.3	71.9	65.9	61.1	53.4	45.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.2	52.7	59.1	63.7	71.1	79.1	79.5	80.6	73.8	67.7	60.0	52.1	(27)
		MCDB	54.4	61.9	68.2	74.9	85.5	92.0	90.2	93.0	83.5	72.7	62.5	54.1	(28)
	2%	WB	46.8	49.8	56.5	61.0	68.6	76.0	77.1	77.3	71.8	66.2	57.3	49.5	(29)
		MCDB	49.2	55.9	64.7	72.2	80.5	86.8	87.8	88.0	80.3	71.3	59.6	50.9	(30)
	5%	WB	44.8	47.7	54.6	59.4	66.8	73.9	75.4	75.4	69.7	64.5	55.6	47.3	(31)
		MCDB	47.2	52.4	62.6	69.4	77.7	84.5	86.0	85.2	77.7	69.6	57.8	48.8	(32)
	10%	WB	43.0	45.9	52.7	57.7	65.0	72.1	74.0	73.7	68.0	62.7	53.8	45.3	(33)
		MCDB	45.5	49.4	60.2	66.5	75.0	82.1	84.6	83.3	75.5	66.7	56.2	47.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.6	15.4	18.3	17.7	18.0	18.3	18.8	18.6	17.6	14.2	11.5	11.2	(35)
		MCDBR	17.7	23.2	25.3	23.6	23.3	21.3	20.5	21.5	21.2	19.0	15.3	14.8	(36)
		MCWBR	11.8	14.4	13.1	10.9	10.2	9.7	8.7	8.6	8.6	10.3	9.9	10.5	(37)
	5% WB	MCDBR	14.0	19.5	21.2	20.5	20.7	20.0	18.9	19.9	18.4	15.9	11.4	10.4	(38)
		MCWBR	10.3	12.7	11.9	10.2	10.0	10.0	9.1	9.2	8.5	9.4	8.2	8.5	(39)
(40) Clear-Sky Solar Irradiance	taub		0.349	0.377	0.423	0.465	0.462	0.484	0.465	0.456	0.450	0.433	0.378	0.343	(40)
	taud		2.379	2.270	2.147	2.062	2.124	2.108	2.168	2.197	2.184	2.187	2.309	2.402	(41)
	Ebn at Noon		236	249	252	252	258	252	255	252	241	224	220	225	(42)
	Edh at Noon		24	32	42	49	48	49	46	43	40	35	26	22	(43)
(44) All-Sky Solar Radiation	RadAvg		459	709	1133	1432	1769	2040	2080	1759	1317	772	456	382	(44)
	RadStd		65	104	144	159	144	118	127	108	89	121	80	55	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	-2.05	-2.90	N/A	N/A	N/A	N/A
Regional (68 neighbors)	+0.63	N/A	N/A	+1.19	+0.68	+0.52	N/A	N/A	+110	+18

Nomenclature: See separate page