

TREVISO SANT'ANGELO, Italy

WMO: 160990

Lat: 45.648N

Lon: 12.194E

Elev: 18

StdP: 101.11

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.2	-3.0	-11.9	1.3	2.4	-9.0	1.8	2.7	7.1	6.2	5.9	4.7	0.7	20	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	33.7	23.2	32.1	22.9	30.9	22.3	25.5	30.2	24.4	29.3	23.5	28.4	2.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	19.0	28.1	23.0	17.8	27.0	22.0	16.7	26.3	78.1	29.4	73.8	29.1	70.1	28.4	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.1	4.3	-6.6	35.3	2.3	1.6	-8.2	36.5	-9.6	37.4	-10.9	38.4	-12.6	39.6		
(5)			-7.2	26.7	2.3	1.3	-8.9	27.6	-10.2	28.4	-11.5	29.1	-13.1	30.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	3.9	5.5	9.6	13.8	18.5	22.6	24.8	24.5	19.6	14.8	9.6	4.8	(6)	
(7)		DBStd	7.96	2.75	2.91	3.06	3.15	2.99	3.10	2.53	2.97	2.88	3.09	3.42	3.07	(7)	
(8)		HDD10.0	580	191	128	43	6	0	0	0	0	3	47	163		(8)	
(9)		HDD18.3	2074	448	360	269	139	34	4	0	1	116	262	420		(9)	
(10)		CDD10.0	2180	1	1	31	119	264	379	460	450	288	151	35	1	(10)	
(11)		CDD18.3	633	0	0	0	3	41	133	202	192	57	5	0	0	(11)	
(12)		CDH23.3	5516	0	0	0	27	307	1123	1926	1786	337	11	0	0	(12)	
(13)		CDH26.7	2015	0	0	0	2	69	382	759	736	67	0	0	0	(13)	
(14)	Wind	WSAvg	1.4	1.0	1.4	1.6	1.6	1.6	1.6	1.5	1.4	1.1	1.1	1.0		(14)	
(15)	Precipitation	PrecAvg	958	50	51	61	87	100	92	78	75	95	102	101	67	(15)	
(16)		PrecMax	1675	259	240	270	147	223	184	209	155	181	194	208	163	(16)	
(17)		PrecMin	660	0	0	1	3	28	28	41	17	27	7	22	5	(17)	
(18)		PrecStd	243	53	61	59	38	54	39	36	37	47	54	49	44	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	16.1	21.2	26.0	31.0	34.2	35.0	30.3	24.8	19.7	13.3		(19)	
(20)			MCWB	10.0	9.7	12.6	16.4	20.3	22.9	23.9	23.9	20.8	18.6	15.4	10.5		(20)
(21)		2%	DB	11.0	13.9	19.1	23.9	28.7	32.0	33.1	34.0	28.6	23.0	17.1	12.0		(21)
(22)			MCWB	7.8	8.5	12.0	15.2	19.5	22.8	23.6	23.1	20.5	17.4	14.4	9.6		(22)
(23)		5%	DB	9.8	12.0	17.0	22.0	26.8	30.2	32.0	32.2	26.9	21.2	15.9	10.8		(23)
(24)			MCWB	7.4	7.7	11.2	14.4	18.5	21.8	23.1	22.8	19.9	16.7	13.7	8.5		(24)
(25)		10%	DB	8.2	10.2	15.2	20.0	24.9	29.0	30.8	30.8	25.1	19.8	14.7	9.2		(25)
(26)			MCWB	6.4	7.3	10.2	13.8	17.7	21.2	22.5	22.3	18.8	16.0	12.6	7.7		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	11.2	14.4	17.6	22.4	25.4	27.2	26.4	23.4	20.6	16.7	12.3		(27)
(28)			MCD B	12.4	14.6	18.4	22.6	27.4	30.5	32.0	31.2	27.1	22.7	18.2	13.0		(28)
(29)		2%	WB	9.1	9.9	13.2	16.3	20.7	24.1	25.8	25.2	22.1	19.1	15.3	10.5		(29)
(30)			MCD B	9.8	11.7	16.8	21.2	25.7	29.6	30.2	30.2	25.8	21.2	16.6	11.3		(30)
(31)		5%	WB	7.9	8.9	12.2	15.4	19.6	23.1	24.6	24.4	21.1	17.9	14.2	9.0		(31)
(32)			MCD B	8.8	10.9	15.6	20.0	24.6	28.0	29.2	29.3	24.9	20.0	15.5	9.7		(32)
(33)		10%	WB	6.8	7.9	11.2	14.5	18.6	22.3	23.6	23.4	20.2	16.7	13.0	8.0		(33)
(34)			MCD B	7.7	9.6	14.0	18.7	23.2	27.1	28.3	28.4	23.8	18.7	14.3	9.0		(34)
(35)	Mean Daily Temperature Range	MDBR	7.4	8.7	9.6	9.6	9.7	9.8	10.2	10.3	9.7	8.5	7.2	7.4		(35)	
(36)		5% DB	MCD BR	9.3	11.6	12.6	12.8	12.4	11.2	11.1	11.9	11.2	10.2	8.1	8.7		(36)
(37)			MCWBR	6.3	6.9	6.7	5.7	5.1	4.6	4.4	4.2	4.9	5.5	5.3	5.9		(37)
(38)		5% WB	MCD BR	6.6	8.9	10.1	10.7	10.6	10.5	10.4	10.9	9.6	7.9	6.2	6.0		(38)
(39)			MCWBR	5.3	6.0	6.0	5.7	5.3	4.9	5.0	5.0	5.3	5.0	4.7	4.7		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.348	0.375	0.422	0.465	0.471	0.492	0.475	0.465	0.448	0.430	0.381	0.343		(40)	
(41)		taud	2.383	2.290	2.166	2.078	2.115	2.106	2.161	2.203	2.214	2.218	2.305	2.411		(41)	
(42)		Ebn at Noon	742	787	796	795	804	787	795	787	763	710	685	706		(42)	
(43)		Edh at Noon	76	100	129	153	153	155	145	134	122	106	82	67		(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.36	2.22	3.50	4.60	5.64	6.40	6.51	5.58	4.07	2.52	1.45	1.19		(44)	
(45)		RadStd	0.22	0.36	0.46	0.52	0.55	0.36	0.35	0.43	0.32	0.30	0.21	0.16		(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	+0.42	N/A	N/A	N/A	+0.35	N/A	N/A	-115	+83	+38

Nomenclature: See separate page