

TRIESTE, Italy

WMO: 161100

Lat: 45.677N

Lon: 13.755E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.6	0.1	-15.9	0.9	1.4	-13.0	1.2	3.1	14.8	0.2	13.6	1.4	7.2	60	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	32.0	23.5	30.8	23.4	29.7	22.9	25.6	30.1	24.6	29.4	23.6	28.6	2.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	19.0	29.5	22.9	17.7	28.6	21.8	16.5	27.7	78.4	30.2	74.4	29.5	70.4	28.7	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.3	8.7	-3.6	34.9	2.2	2.2	-5.2	36.5	-6.5	37.8	-7.8	39.1	-9.4	40.7		
(5)			-6.1	27.3	1.8	1.3	-7.4	28.3	-8.5	29.1	-9.5	29.9	-10.7	30.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.5	6.4	7.0	10.3	14.1	18.7	22.6	25.1	25.0	20.6	16.3	11.7	7.7	(6)
(7)		DBStd	7.28	2.88	3.09	2.93	2.91	2.77	2.97	2.54	2.79	2.93	3.09	3.36	3.17	(7)
(8)		HDD10.0	343	116	89	31	3	0	0	0	0	0	2	21	82	(8)
(9)		HDD18.3	1714	370	317	248	129	28	3	0	1	11	77	199	330	(9)
(10)		CDD10.0	2359	4	6	41	127	270	379	469	466	319	196	73	10	(10)
(11)		CDD18.3	688	0	0	0	3	40	133	211	208	80	13	1	0	(11)
(12)		CDH23.3	4996	0	0	0	10	140	888	1851	1774	322	12	0	0	(12)
(13)		CDH26.7	1383	0	0	0	1	14	199	564	559	45	1	0	0	(13)
(14)	Wind	WSAvg	2.5	3.0	3.0	2.5	2.1	1.9	1.9	2.1	2.1	2.6	2.7	2.8	3.1	(14)
(15)	Precipitation	PrecAvg	1008	63	69	68	78	79	89	64	88	107	99	112	84	(15)
(16)		PrecMax	1538	172	243	199	180	236	176	177	316	290	321	316	238	(16)
(17)		PrecMin	633	0	0	1	0	7	0	10	6	0	0	2	0	(17)
(18)		PrecStd	215	41	54	46	40	47	40	42	64	64	74	61	52	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.8	15.2	19.2	24.8	28.6	32.1	33.9	34.3	29.7	24.9	20.3	16.1	(19)
(20)			MCWB	12.0	10.0	11.7	14.6	19.9	23.6	23.6	22.6	22.1	18.3	16.2	12.8	(20)
(21)		2%	DB	12.8	13.3	16.9	21.9	26.3	30.1	32.0	32.1	28.0	22.9	18.8	14.0	(21)
(22)			MCWB	10.3	9.2	11.1	14.9	19.5	23.1	23.5	23.6	20.9	18.0	15.1	11.2	(22)
(23)		5%	DB	11.2	12.1	15.3	20.1	24.9	28.9	30.8	30.9	26.7	21.7	17.4	12.7	(23)
(24)			MCWB	9.0	8.9	10.4	14.0	18.5	22.5	23.6	23.5	20.3	17.4	14.4	10.0	(24)
(25)		10%	DB	10.2	11.0	14.2	18.7	23.5	27.7	29.7	29.8	25.2	20.4	16.1	11.7	(25)
(26)			MCWB	8.1	8.1	10.2	13.4	17.6	21.6	23.1	22.9	19.4	16.6	13.5	9.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.5	11.9	13.5	17.5	22.6	25.6	27.2	26.9	24.3	20.4	17.1	13.7	(27)
(28)			MCD B	14.3	13.1	16.5	21.6	26.4	29.7	31.6	31.1	28.0	22.9	19.3	15.3	(28)
(29)		2%	WB	10.9	10.6	12.5	15.9	20.7	24.2	25.6	25.7	22.6	19.2	15.7	12.0	(29)
(30)			MCD B	12.3	12.1	15.1	19.9	24.9	29.1	30.2	30.3	26.6	21.6	17.8	13.2	(30)
(31)		5%	WB	9.7	9.7	11.8	14.9	19.3	23.1	24.6	24.6	21.3	18.3	14.9	10.8	(31)
(32)			MCD B	10.7	11.3	14.2	18.6	23.7	27.9	29.4	29.6	25.1	20.6	16.8	12.0	(32)
(33)		10%	WB	8.8	8.7	11.1	14.0	18.2	22.0	23.5	23.6	20.2	17.4	14.1	9.9	(33)
(34)			MCD B	9.8	10.4	13.5	17.5	22.5	27.0	28.5	28.7	24.0	19.7	15.9	11.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.0	6.0	6.3	7.0	7.3	7.6	7.3	6.7	5.6	4.8	4.6	(35)
(36)			MCDBR	5.5	6.0	7.2	8.5	8.3	8.2	8.3	8.2	7.7	6.3	5.5	5.7	(36)
(37)			MCWBR	4.2	4.4	4.8	5.1	5.4	5.9	6.1	5.9	5.1	4.3	4.0	4.5	(37)
(38)		5% WB	MCD BR	4.0	4.9	6.0	7.1	7.7	7.7	7.8	7.7	7.0	5.5	4.4	4.4	(38)
(39)			MCWBR	3.7	4.3	4.6	5.1	5.7	6.2	6.5	6.5	5.6	4.4	3.5	4.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.344	0.369	0.417	0.461	0.465	0.476	0.465	0.456	0.440	0.419	0.376	0.340	(40)	
(41)		taud	2.401	2.320	2.196	2.101	2.140	2.159	2.198	2.238	2.247	2.270	2.336	2.430	(41)	
(42)		Ebn at Noon	748	795	802	799	809	800	804	795	771	725	694	711	(42)	
(43)		Edh at Noon	74	97	125	150	149	147	140	129	118	101	79	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.30	2.15	3.39	4.54	5.59	6.35	6.44	5.54	3.97	2.48	1.40	1.14	(44)	
(45)		RadStd	0.21	0.38	0.46	0.52	0.56	0.37	0.36	0.49	0.38	0.28	0.20	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	+0.46	N/A	N/A	+0.69	+0.42	N/A	-76	-119	+92	+61

Nomenclature: See separate page