

GENOVA SESTRI, Italy

WMO: 161200

Lat: 44.412N

Lon: 8.842E

Elev: 13

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 35.2	(c) 37.4	(d) 9.4	(e) 8.9	(f) 42.8	(g) 14.1	(h) 11.3	(i) 43.3	(j) 27.5	(k) 45.8	(l) 25.5	(m) 45.5	(n) 14.7	(o) 40	(p) 0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 10.0	(c) 86.3	(d) 73.1	(e) 84.3	(f) 73.7	(g) 82.6	(h) 73.5	(i) 78.9	(j) 82.2	(k) 77.3	(l) 81.4	(m) 75.8	(n) 80.5	(o) 8.4	(p) 40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.4	142.7	81.1	75.6	134.2	80.2	73.8	126.1	79.2	42.3	82.4	40.6	81.3	39.1	80.4	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 24.3	(b) 21.6	(c) 19.5	(e) 32.0	(f) 91.6	(g) 3.3	(h) 3.3	(i) 29.7	(j) 94.0	(k) 27.8	(l) 95.9	(m) 25.9	(n) 97.8	(o) 23.6	(p) 100.2		
			DB													
			WB													
				26.4	79.9	3.0	2.4	24.3	81.6	22.5	83.0	20.8	84.3	18.6	86.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.9	48.2	49.3	53.7	58.5	65.2	71.9	76.5	77.0	71.0	64.0	55.9	50.2	(6)
(7)		DBStd	11.13	5.05	5.08	4.36	4.23	4.20	4.37	3.60	3.68	4.07	4.79	5.30	5.49	(7)
(8)		HDD50	262	95	65	19	1	0	0	0	0	0	1	15	66	(8)
(9)		HDD65	2369	521	440	350	200	48	2	0	0	4	72	273	459	(9)
(10)		CDD50	4588	38	45	134	256	470	656	823	836	630	436	192	72	(10)
(11)		CDD65	1223	0	0	0	6	53	208	358	371	185	42	0	0	(11)
(12)		CDH74	7099	0	0	0	11	114	905	2615	2802	630	22	0	0	(12)
(13)		CDH80	1224	0	0	0	1	10	112	475	559	67	0	0	0	(13)
(14)	Wind	WSAvg	9.2	11.5	10.4	9.0	8.5	7.9	7.2	7.4	7.5	8.4	9.7	11.2	11.4	(14)
(15)	Precipitation	PrecAvg	43.7	4.3	3.7	4.2	3.1	3.1	2.1	1.1	3.1	4.3	6.5	4.3	3.1	(15)
(16)		PrecMax	65.1	14.3	12.1	10.1	10.4	7.8	8.4	3.7	8.3	17.2	19.6	14.5	8.7	(16)
(17)		PrecMin	28.3	0.2	0.6	0.7	0.1	0.3	0.2	0.0	0.0	0.2	0.3	0.0	0.0	(17)
(18)		PrecStd	9.4	3.5	3.1	2.6	2.4	2.1	1.9	1.1	2.4	3.7	5.1	3.0	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.0	62.7	68.2	75.2	80.8	86.2	89.6	91.3	85.9	76.6	68.3	62.9	(19)
(20)			MCWB	51.3	51.2	52.9	58.8	65.8	72.8	71.4	72.4	69.3	66.3	59.9	54.3	(20)
(21)		2%	DB	58.8	59.1	64.1	70.0	77.0	82.7	86.1	86.9	81.5	73.7	66.3	60.9	(21)
(22)			MCWB	52.8	51.7	51.8	57.9	65.3	72.6	74.5	72.4	68.7	65.5	59.9	54.7	(22)
(23)		5%	DB	57.3	57.4	61.2	67.6	74.2	80.7	84.2	84.5	79.1	71.9	64.7	59.2	(23)
(24)			MCWB	52.3	51.6	53.2	57.4	64.1	71.7	74.5	74.0	69.3	65.1	59.0	53.4	(24)
(25)		10%	DB	55.7	56.2	59.4	64.7	71.7	78.8	82.5	82.7	77.3	70.4	63.0	57.6	(25)
(26)			MCWB	50.8	50.9	53.0	56.7	63.5	71.1	73.8	74.1	68.5	64.1	57.7	52.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.1	57.0	59.5	63.0	70.2	78.1	80.9	80.7	76.0	71.5	64.1	59.5	(27)
(28)			MCD B	59.0	58.4	61.4	68.0	74.5	82.1	83.8	83.0	78.4	73.2	66.1	61.3	(28)
(29)		2%	WB	55.2	55.2	57.5	61.2	68.4	75.9	78.7	79.2	73.9	69.1	62.0	56.8	(29)
(30)			MCD B	57.5	57.5	60.0	66.2	73.4	80.4	82.5	82.2	77.5	71.6	64.9	59.6	(30)
(31)		5%	WB	53.6	53.8	56.1	59.7	66.7	73.8	77.0	77.9	72.2	67.4	60.2	55.0	(31)
(32)			MCD B	56.3	56.4	59.1	64.4	71.9	78.6	81.5	81.5	76.8	70.6	63.7	58.3	(32)
(33)		10%	WB	51.8	52.2	54.9	58.6	65.1	72.1	75.5	76.3	70.6	65.5	58.7	53.2	(33)
(34)			MCD B	55.4	55.4	58.4	63.0	70.3	77.2	80.7	80.7	75.7	69.6	62.6	57.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.5	9.6	9.9	9.7	9.6	9.4	9.5	10.0	10.5	9.3	9.0	9.2	(35)
(36)			MCDBR	10.7	10.8	12.0	12.9	13.1	11.6	11.2	11.7	12.3	10.2	9.7	10.2	(36)
(37)			MCWBR	8.9	9.3	9.3	8.9	9.0	9.2	9.3	9.2	8.8	7.4	7.8	8.4	(37)
(38)		5% WB	MCDBR	8.4	8.2	8.9	9.7	9.8	9.2	9.0	8.5	9.2	8.0	8.3	8.6	(38)
(39)			MCWBR	8.4	8.8	8.8	8.7	8.9	9.4	9.5	9.3	8.8	7.4	8.1	8.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.338	0.361	0.403	0.441	0.444	0.460	0.449	0.442	0.428	0.408	0.367	0.334	(40)	
(41)		taud	2.443	2.366	2.260	2.173	2.214	2.214	2.255	2.286	2.292	2.319	2.395	2.470	(41)	
(42)		Ebn at Noon	246	259	262	261	264	259	260	258	251	238	231	236	(42)	
(43)		Edh at Noon	23	30	38	44	44	44	42	39	36	31	24	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	483	730	1147	1499	1857	2133	2199	1876	1402	829	499	409	(44)	
(45)		RadStd	60	106	151	138	151	109	113	106	89	113	68	56	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) -3.89	(g) N/A	(h) -1.66	(i) -2.16	(j) N/A	(k) N/A	(l) N/A
(47) Regional (33 neighbors)		+0.65	N/A	N/A	N/A	N/A	N/A	N/A	+140	+65

Nomenclature: See separate page