

MONTE CIMONE, Italy

WMO: 161340

Lat: 44.1936N

Lon: 10.7000E

Elev: 7129

StdP: 11.28

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.6	10.4	-11.1	3.9	23.7	-5.4	5.4	24.7	63.8	18.1	59.2	19.8	39.2	20	0.945

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	66.5	56.3	64.4	55.1	62.3	53.6	58.4	63.8	56.7	62.3	55.2	60.7	7.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.3	88.3	61.4	54.3	82.1	59.9	52.5	76.7	58.3	28.9	63.8	27.5	62.5	26.3	60.8	70.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
57.5	50.4	45.1	4.2	71.1	4.9	3.6	0.6	73.7	-2.3	75.8	-5.0	77.8	-8.6	80.5		
			3.2	62.3	4.6	2.8	-0.2	64.3	-2.9	65.9	-5.5	67.5	-8.9	69.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	38.6	26.7	25.5	29.4	33.6	41.6	49.8	54.4	54.2	45.8	40.7	33.2	27.9	(6)
	DBStd	12.26	7.12	7.75	6.99	5.86	6.16	7.13	5.89	5.83	6.30	6.91	7.60	7.64	(7)
	HDD50	4591	722	687	638	493	271	92	27	26	152	292	506	685	(8)
	HDD65	9624	1187	1107	1103	943	727	456	331	338	575	752	955	1150	(9)
	CDD50	445	0	0	0	0	9	86	162	154	28	4	2	0	(10)
	CDD65	3	0	0	0	0	0	0	1	2	0	0	0	0	(11)
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
	WSAvg	18.1	22.3	21.5	20.5	19.0	17.2	14.4	12.9	13.1	16.4	18.2	20.7	21.6	(14)
(15) Precipitation	PrecAvg	30.6	2.2	1.8	2.2	2.0	2.2	2.4	2.2	3.0	3.1	3.3	3.2	2.2	(15)
	PrecMax	42.6	6.5	5.2	6.8	5.4	5.4	5.6	6.1	6.2	8.8	9.7	8.4	4.2	(16)
	PrecMin	17.2	0.1	0.2	0.0	0.1	0.6	0.8	0.2	0.0	0.3	0.4	0.2	0.1	(17)
	PrecStd	7.1	1.6	1.3	1.6	1.1	1.2	1.1	1.5	1.7	2.2	2.7	2.3	1.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.5	46.7	47.7	50.5	60.5	67.5	69.8	70.2	62.5	56.7	54.9	47.9	(19)
		MCWB	34.3	35.5	37.1	42.7	49.7	56.2	59.4	56.9	53.0	45.4	39.8	33.0	(20)
	2%	DB	41.1	41.2	43.2	46.8	55.7	64.2	66.6	66.4	59.1	53.4	48.7	44.0	(21)
		MCWB	32.2	32.3	35.0	40.5	47.2	55.1	57.1	55.4	51.7	44.0	38.8	32.3	(22)
	5%	DB	38.3	37.7	40.8	44.4	52.9	61.8	64.5	64.1	56.3	51.2	45.3	39.8	(23)
		MCWB	30.2	30.8	34.4	39.1	45.9	53.2	56.0	54.4	49.7	42.8	37.3	31.0	(24)
	10%	DB	35.5	34.6	38.0	41.4	50.0	59.3	62.3	61.8	53.9	49.1	42.5	36.7	(25)
		MCWB	29.7	29.9	33.1	36.6	44.3	51.1	53.5	53.4	47.7	42.4	37.1	31.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.9	36.5	39.4	44.8	51.6	60.2	62.2	59.6	55.6	50.1	44.1	37.0	(27)
		MCDB	41.4	42.3	43.6	49.2	57.0	64.2	66.2	64.7	59.5	53.0	47.8	39.6	(28)
	2%	WB	34.2	34.2	37.0	41.9	48.9	57.3	58.9	57.6	53.1	48.1	41.9	35.4	(29)
		MCDB	37.3	37.7	40.4	45.6	53.6	61.9	64.5	63.6	57.4	50.2	44.7	37.5	(30)
	5%	WB	32.6	32.8	35.5	39.4	46.7	55.0	57.0	56.1	51.0	46.5	40.1	34.0	(31)
		MCDB	35.2	35.5	39.1	42.8	51.2	60.2	62.5	62.0	54.7	48.8	43.0	36.1	(32)
	10%	WB	31.1	31.1	33.9	37.6	45.0	52.7	55.3	54.6	49.3	44.7	38.3	32.6	(33)
		MCDB	33.6	33.4	36.7	40.5	49.1	57.7	60.9	60.1	52.6	46.9	41.0	35.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	6.9	6.8	6.4	7.4	8.1	8.7	8.2	7.1	6.8	6.1	6.4	(35)
		MCDBR	8.1	8.6	8.6	8.3	9.9	9.9	10.7	10.1	9.1	8.6	8.5	8.2	(36)
		MCWBR	6.2	6.9	8.1	8.7	10.8	12.3	11.9	10.8	11.4	9.4	8.3	6.3	(37)
	5% WB	MCDBR	6.4	6.8	7.4	7.5	9.1	9.1	9.2	9.0	8.3	7.2	6.7	6.0	(38)
		MCWBR	6.3	6.7	7.8	8.5	10.6	12.8	12.0	10.9	10.6	8.8	7.4	6.2	(39)
(40) Clear-Sky Solar Irradiance	taub		0.253	0.268	0.294	0.312	0.314	0.322	0.317	0.311	0.302	0.297	0.275	0.252	(40)
	taud		2.577	2.532	2.476	2.438	2.452	2.447	2.460	2.492	2.508	2.534	2.561	2.596	(41)
	Ebn at Noon		287	299	302	302	303	300	300	299	295	283	274	277	(42)
	Edh at Noon		20	25	30	34	35	35	34	32	29	24	20	18	(43)
(44) All-Sky Solar Radiation	RadAvg		465	725	1119	1475	1837	2106	2173	1869	1372	841	495	402	(44)
	RadStd		62	103	163	149	167	122	119	118	84	106	64	50	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		+1.84	N/A	N/A	N/A	N/A	N/A	-605	-698	N/A	N/A
(47)	Regional (24 neighbors)	+0.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+128	N/A

Nomenclature: See separate page