

RIMINI, Italy

WMO: 161490

Lat: 44.0244N

Lon: 12.6128E

Elev: 13

StdP: 101.17

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.1	-1.9	-7.1	2.1	2.4	-5.2	2.4	1.8	10.4	5.1	9.4	5.1	1.9	200	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	32.1	24.4	30.9	24.7	29.9	24.3	27.5	29.4	26.4	28.9	25.4	28.3	4.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.0	22.8	28.8	25.8	21.2	28.2	24.3	19.3	27.4	87.4	29.8	82.4	29.1	77.7	28.5	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.5	6.5	DB	-5.9	35.2	2.7	1.9	-7.9	36.6	-9.4	37.7	-10.9	38.7	-12.9	40.1	(4)
(5)			WB	-6.2	29.0	2.7	1.3	-8.1	30.0	-9.7	30.7	-11.3	31.4	-13.2	32.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	4.8	5.7	9.1	12.6	17.3	21.8	24.2	24.1	19.8	15.6	10.5	5.6	(6)	
	DBStd	7.51	2.88	3.02	3.16	2.66	2.75	2.85	2.44	2.40	2.80	2.87	3.58	3.20	(7)	
	HDD10.0	524	164	123	53	7	0	0	0	0	0	1	36	139	(8)	
	HDD18.3	2028	421	354	286	172	53	5	0	0	16	93	235	393	(9)	
	CDD10.0	2099	2	3	26	86	227	354	442	437	293	174	51	4	(10)	
	CDD18.3	561	0	0	0	1	22	109	183	178	59	8	1	0	(11)	
	CDH23.3	5106	0	0	1	3	151	956	1904	1721	350	20	1	0	(12)	
(13)	CDH26.7	1494	0	0	0	1	24	234	638	546	52	1	0	0	(13)	
(14)	Wind	WSAvg	2.5	2.5	2.6	2.7	2.6	2.5	2.6	2.5	2.5	2.2	2.5	2.6	(14)	
(15) Precipitation	PrecAvg	716	37	42	49	59	49	56	59	65	64	89	81	60	(15)	
	PrecMax	1144	105	125	217	164	177	158	230	226	209	318	174	115	(16)	
	PrecMin	443	0	0	4	14	0	16	4	2	8	2	2	0	(17)	
	PrecStd	153	30	31	40	38	40	34	50	55	42	78	49	30	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	16.2	20.5	22.9	29.1	32.1	34.2	34.2	30.1	25.5	21.2	17.1	(19)	
		MCWB	12.1	11.7	14.0	16.0	21.0	23.7	23.2	23.5	22.9	20.3	17.0	13.6	(20)	
	2%	DB	13.2	14.1	18.2	20.9	26.9	30.2	32.2	32.0	28.1	23.2	19.1	14.2	(21)	
		MCWB	9.9	10.2	12.6	15.9	20.3	23.6	24.2	25.0	23.5	19.7	16.1	11.2	(22)	
	5%	DB	11.1	12.6	16.2	19.4	24.9	29.1	31.0	30.8	26.8	22.0	17.3	12.1	(23)	
		MCWB	8.5	9.4	12.0	15.0	19.6	23.2	24.5	25.2	22.6	18.9	15.3	10.4	(24)	
	10%	DB	9.2	11.0	14.9	18.1	23.2	27.9	29.9	29.7	25.2	20.8	16.0	10.6	(25)	
		MCWB	7.6	8.5	11.4	14.5	18.8	22.8	24.4	24.7	21.1	18.2	14.2	9.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.5	12.7	15.1	18.2	23.7	27.2	28.8	29.7	27.0	21.9	18.3	14.2	(27)	
		MCDB	15.2	15.2	18.6	20.3	25.7	29.2	30.1	30.6	28.1	23.9	19.6	16.1	(28)	
	2%	WB	10.5	11.1	13.7	17.1	22.0	25.9	27.4	27.7	24.8	20.6	16.8	12.1	(29)	
		MCDB	12.4	13.0	16.5	19.3	24.9	28.3	29.5	29.5	26.8	22.4	18.3	13.5	(30)	
	5%	WB	9.1	10.0	12.8	16.1	20.5	24.7	26.3	26.4	23.1	19.6	15.7	10.7	(31)	
		MCDB	10.5	11.7	15.2	18.3	23.5	27.6	29.0	28.9	25.4	21.3	17.1	11.9	(32)	
	10%	WB	8.0	9.0	11.9	15.1	19.4	23.6	25.3	25.3	21.9	18.5	14.6	9.4	(33)	
		MCDB	9.1	10.6	14.3	17.4	22.5	26.8	28.5	28.4	24.5	20.2	15.9	10.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	8.0	8.7	8.7	9.3	9.2	9.3	9.1	8.8	7.7	6.8	6.8	(35)	
		MCDBR	9.9	10.4	11.1	10.7	11.6	10.5	10.8	10.4	9.8	9.2	8.2	8.9	(36)	
	5% WB	MCWBR	7.2	7.1	6.9	6.9	7.1	6.7	7.2	7.4	6.4	6.2	5.9	6.7	(37)	
		MCWBR	8.6	8.7	9.8	9.4	10.6	9.5	9.4	9.5	8.9	8.5	7.2	7.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.357	0.377	0.411	0.449	0.447	0.452	0.443	0.438	0.425	0.411	0.380	0.352	(40)	
		taud	2.393	2.311	2.231	2.146	2.204	2.239	2.267	2.298	2.308	2.324	2.338	2.421	(41)	
	Edn at Noon	Edn at Noon	752	799	818	816	829	825	827	818	796	751	710	719	(42)	
		Edh at Noon	79	100	123	145	141	136	131	123	113	98	82	71	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.36	2.21	3.48	4.65	5.79	6.61	6.77	5.80	4.20	2.66	1.54	1.21	(44)	
	RadStd	RadStd	0.20	0.32	0.45	0.42	0.48	0.34	0.31	0.38	0.29	0.27	0.17	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	-78	+82	N/A
(47)	Regional (17 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-86	+77	N/A

Nomenclature: See separate page