

IMPERIA, Italy

WMO: 161500

Lat: 43.884N

Lon: 8.029E

Elev: 6

StdP: 101.25

Time Zone: 1.00 (EUC)

Period: 95-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.7	5.1	-15.8	0.9	9.0	-12.3	1.3	8.1	11.5	11.2	9.8	10.7	3.2	340	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.8	28.4	22.6	27.5	22.5	26.7	22.3	25.7	27.0	24.8	26.2	24.1	25.5	3.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	20.4	26.7	24.4	19.4	25.9	23.6	18.5	25.2	79.1	27.1	75.6	26.3	72.5	25.6	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.8	8.4	7.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	10.0	10.4	12.2	13.8	17.9	21.7	23.1	23.8	20.6	17.6	13.2	10.8
	DBStd	5.41	2.25	2.19	2.08	2.45	2.41	2.33	1.95	1.72	2.06	2.31	2.61	2.55
	HDD10.0	81	27	19	7	2	0	0	0	0	0	0	6	20
	HDD18.3	1279	258	222	192	139	37	2	0	0	4	41	153	232
	CDD10.0	2376	28	31	73	114	244	351	405	427	318	235	103	46
	CDD18.3	534	0	0	0	2	23	103	147	168	73	18	1	0
	CDH23.3	2151	0	0	0	1	48	378	670	902	145	8	0	0
	CDH26.7	156	0	0	0	0	1	24	48	79	4	0	0	0
Wind	WSAvg	2.8	2.9	2.8	2.8	3.0	2.8	2.8	2.8	2.7	2.7	2.8	2.9	3.0
Precipitation	PrecAvg	704	58	43	50	69	40	25	17	17	73	92	129	91
	PrecMax	1229	278	195	222	176	124	124	64	82	226	228	406	256
	PrecMin	368	0	0	6	9	6	0	1	0	0	20	15	1
	PrecStd	188	61	43	49	49	27	26	17	19	67	52	96	64
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	17.7	19.1	22.5	26.5	28.7	29.1	31.1	27.1	24.2	20.5	17.2
		MCWB	9.9	9.7	10.3	14.0	16.0	23.4	20.5	20.5	19.7	18.0	13.4	10.9
	2%	DB	14.9	15.4	17.2	20.4	24.7	27.4	28.0	28.8	25.9	23.1	18.7	16.1
		MCWB	10.2	9.2	10.4	13.7	16.3	23.7	21.4	23.5	20.5	18.6	14.6	10.7
	5%	DB	14.1	14.4	16.1	19.0	23.1	26.5	27.2	27.8	24.9	22.0	17.8	15.1
		MCWB	10.4	10.0	11.0	13.8	17.3	23.2	21.5	23.3	20.1	18.3	14.2	11.1
	10%	DB	13.4	13.5	15.2	17.6	21.7	25.6	26.3	26.9	24.0	21.0	16.9	14.3
		MCWB	10.1	10.2	11.1	13.3	16.8	22.2	21.6	23.0	19.3	17.5	13.6	10.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	13.7	15.0	18.3	21.3	26.1	25.9	27.2	23.7	21.1	17.7	15.0
		MCDB	14.7	15.4	15.6	19.3	22.6	27.5	27.2	28.2	25.2	22.2	18.8	15.3
	2%	WB	13.2	12.7	14.0	16.7	19.9	25.2	25.0	26.1	22.3	20.2	16.7	13.8
		MCDB	13.8	13.4	14.9	18.0	21.2	26.5	26.4	27.6	24.1	21.7	17.7	14.6
	5%	WB	12.2	12.0	13.3	15.5	18.8	24.4	24.2	25.1	21.7	19.3	15.6	12.9
		MCDB	13.0	13.0	14.4	16.8	20.7	25.7	25.5	26.4	23.4	20.9	16.8	14.0
	10%	WB	11.2	11.2	12.7	14.5	18.1	23.5	23.5	24.3	21.0	18.5	14.6	11.9
		MCDB	12.5	12.7	13.9	16.0	20.0	24.9	25.0	25.8	22.9	20.2	16.0	13.4
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.8	4.9	4.8	4.9	5.1	4.9	4.8	5.0	4.4	4.6	4.3
		MCDBR	4.7	5.6	5.6	5.9	5.9	5.5	5.4	5.0	5.3	5.1	4.9	4.7
		MCWBR	4.0	4.7	4.7	4.3	4.2	4.4	5.0	4.8	4.5	4.3	4.0	4.1
	5% WB	MCDBR	4.3	4.7	4.7	5.1	4.8	5.0	5.0	4.5	4.6	4.5	4.2	4.2
		MCWBR	4.0	4.6	4.3	4.2	4.3	4.0	4.5	4.4	4.1	4.3	3.9	4.0
Clear-Sky Solar Irradiance	taub	0.336	0.360	0.402	0.441	0.445	0.457	0.449	0.441	0.427	0.407	0.365	0.332	
	taud	2.445	2.371	2.267	2.176	2.223	2.237	2.268	2.300	2.307	2.326	2.400	2.467	
	Ebn at Noon	784	823	829	824	832	820	822	816	795	756	735	752	
	Edh at Noon	75	95	119	140	138	137	131	123	113	98	78	67	
All-Sky Solar Radiation	RadAvg	1.65	2.50	3.80	4.95	5.99	6.87	7.02	6.08	4.57	2.89	1.77	1.43	
	RadStd	0.17	0.30	0.40	0.38	0.44	0.34	0.33	0.27	0.27	0.28	0.19	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.27	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page