

FALCONARA, Italy

WMO: 161910

Lat: 43.616N

Lon: 13.362E

Elev: 49

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.6	31.5	17.9	13.6	36.4	21.3	16.0	37.5	24.7	45.5	21.9	45.9	5.7	200	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	91.3	72.2	88.1	71.9	85.9	71.6	76.4	85.0	74.9	84.0	73.5	82.6	9.6	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.7	125.6	82.0	71.8	117.9	80.7	70.1	111.0	79.5	39.9	84.6	38.4	84.2	37.1	83.0	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.3	16.9	14.5	DB	25.1	97.2	3.1	2.9	22.9	99.4	21.1	101.1	19.4	102.7	17.1	104.9
			WB	23.3	79.3	3.0	1.6	21.2	80.4	19.4	81.3	17.7	82.2	15.5	83.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.6	42.5	44.1	49.7	55.5	63.5	71.2	75.3	75.1	67.9	60.5	52.2	44.6
	DBStd	12.70	5.25	5.67	5.64	4.78	4.90	5.18	4.31	4.43	5.00	4.89	5.95	5.37
	HDD50	734	242	180	74	10	0	0	0	0	0	1	44	183
	HDD65	3337	698	586	474	285	89	9	0	0	26	154	384	632
	CDD50	3869	9	14	65	176	417	635	785	779	536	327	110	16
	CDD65	998	0	0	0	0	41	194	321	314	112	15	1	0
	CDH74	8929	0	0	2	10	312	1710	3227	2947	670	50	1	0
	CDH80	2760	0	0	0	0	49	466	1126	995	123	1	0	0
(14) Wind	WSAvg	6.1	5.9	6.6	7.0	6.2	6.2	6.5	6.2	6.1	6.1	5.6	5.5	5.8
(15) Precipitation	PrecAvg	31.9	1.7	1.8	2.4	2.4	2.8	2.2	2.1	3.3	2.6	2.7	3.3	2.9
	PrecMax	43.4	4.7	4.0	5.7	4.8	6.7	6.8	5.6	8.2	6.3	7.0	6.9	7.8
	PrecMin	19.5	0.0	0.0	0.4	0.6	0.1	0.4	0.1	0.1	0.7	0.0	1.2	0.7
	PrecStd	6.9	1.5	1.3	1.4	1.2	1.7	1.7	1.6	2.6	1.6	2.0	1.5	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.0	63.8	71.7	75.4	84.5	91.6	94.9	96.4	87.6	78.7	71.7	64.7
		MCWB	54.4	53.3	57.6	60.7	68.0	71.7	72.2	71.4	69.8	66.2	61.0	55.1
	2%	DB	58.9	60.5	66.4	71.7	80.6	87.6	91.4	91.4	83.0	75.2	67.6	60.4
		MCWB	51.2	51.3	54.9	58.9	66.4	71.5	72.0	72.6	69.3	65.1	59.0	52.8
	5%	DB	54.2	57.1	63.2	68.4	77.3	84.6	88.2	87.9	80.5	71.9	64.2	56.4
		MCWB	48.2	49.9	53.6	58.0	64.8	70.5	71.7	72.6	69.3	64.0	58.4	51.0
	10%	DB	51.4	53.9	60.5	65.9	74.5	82.5	86.0	85.6	77.6	69.5	61.6	53.3
		MCWB	46.9	48.5	52.6	56.7	63.7	69.9	71.3	72.5	67.9	63.0	56.7	49.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.4	54.8	59.3	63.4	71.3	77.8	78.2	79.1	74.1	69.1	62.8	57.0
		MCDB	61.2	60.8	67.1	70.6	80.0	85.2	85.0	86.5	81.3	73.8	67.9	62.4
	2%	WB	52.2	52.6	56.5	61.0	68.6	74.8	76.1	76.8	72.0	67.0	60.8	53.9
		MCDB	57.8	58.0	63.8	68.1	76.8	83.5	84.9	85.3	79.7	72.1	65.5	59.2
	5%	WB	49.7	50.9	54.8	59.5	66.6	72.8	74.6	75.1	70.3	65.4	59.1	51.7
		MCDB	53.1	55.6	61.6	66.3	74.6	81.3	84.3	84.0	77.9	70.5	63.2	55.7
	10%	WB	47.4	49.1	53.0	57.7	64.7	71.2	73.2	73.7	68.9	63.8	57.3	49.7
		MCDB	50.5	53.6	59.3	64.0	72.2	80.0	83.1	82.5	76.1	68.4	61.3	52.4
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	14.4	16.0	16.6	17.1	17.3	17.8	17.2	16.0	14.4	12.8	12.6
		MCDBR	18.8	18.9	20.8	21.5	21.6	21.1	22.0	21.6	18.9	17.7	16.2	17.6
		MCWBR	12.7	12.2	12.3	12.4	11.2	10.8	10.8	11.4	10.2	10.4	10.3	12.1
		MCDBR	16.2	16.4	18.6	18.6	18.9	18.2	18.7	17.8	16.4	15.5	14.1	15.0
	5% WB	MCWBR	11.5	11.3	11.9	11.8	11.0	10.9	11.1	11.4	10.2	10.2	9.6	10.8
(40) Clear-Sky Solar Irradiance	taub		0.349	0.370	0.402	0.441	0.440	0.439	0.433	0.430	0.416	0.399	0.373	0.346
	taud		2.419	2.345	2.265	2.171	2.230	2.279	2.298	2.319	2.338	2.367	2.374	2.444
	Ebn at Noon		244	258	264	262	265	265	266	262	256	244	231	233
	Edh at Noon		24	31	38	45	43	42	40	38	35	30	25	22
(44) All-Sky Solar Radiation	RadAvg		442	706	1111	1489	1836	2087	2144	1856	1333	856	512	400
	RadStd		62	93	141	132	151	104	90	111	81	88	55	53

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	+2.66	N/A	-1.31	-1.57	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)	+0.49	N/A	N/A	N/A	N/A	-0.76	N/A	N/A	N/A	N/A

Nomenclature: See separate page