

FALCONARA, Italy

WMO: 161910

Lat: 43.616N

Lon: 13.362E

Elev: 15

StdP: 101.15

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.9	-0.3	-7.8	1.9	2.5	-5.9	2.3	3.0	11.1	7.5	9.8	7.7	2.6	200	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	33.0	22.3	31.2	22.2	29.9	22.0	24.7	29.4	23.8	28.9	23.1	28.1	4.3	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	17.9	27.8	22.1	16.8	27.0	21.2	15.9	26.4	74.9	29.2	71.5	29.0	68.4	28.4	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	7.6	6.5	-3.8	36.2	1.7	1.6	-5.1	37.4	-6.1	38.4	-7.0	39.3	-8.3	40.5		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-4.8	26.3	1.7	0.9	-6.0	26.9	-7.0	27.4	-8.0	27.9	-9.2	28.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.8	5.8	6.7	9.8	13.1	17.5	21.8	24.1	24.0	19.9	15.8	11.2	7.0
	DBStd	7.06	2.92	3.15	3.13	2.66	2.72	2.88	2.40	2.46	2.78	2.72	3.30	2.99
	HDD10.0	408	134	100	41	6	0	0	0	0	0	1	24	102
	HDD18.3	1854	388	326	263	158	49	5	0	0	14	86	213	351
	CDD10.0	2149	5	8	36	98	232	353	436	433	298	182	61	9
	CDD18.3	554	0	0	0	0	23	108	178	174	62	8	1	0
	CDH23.3	4961	0	0	1	6	173	950	1793	1637	372	28	1	0
	CDH26.7	1533	0	0	0	0	27	259	626	553	68	1	0	0
Wind	WSAvg	2.7	2.6	2.9	3.1	2.8	2.8	2.8	2.9	2.8	2.7	2.5	2.5	2.6
Precipitation	PrecAvg	809	43	45	60	62	71	56	53	83	67	69	83	74
	PrecMax	1102	120	101	146	123	170	173	143	208	161	177	174	197
	PrecMin	495	1	1	9	16	2	10	3	3	17	1	30	19
	PrecStd	176	37	33	35	31	42	42	41	65	41	50	39	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.2	17.7	22.1	24.1	29.2	33.1	35.0	35.8	30.9	25.9	22.1	18.2
		MCWB	12.4	11.8	14.2	15.9	20.0	22.0	22.4	21.9	21.0	19.0	16.1	12.8
	2%	DB	14.9	15.8	19.1	22.0	27.0	30.9	33.0	33.0	28.3	24.0	19.8	15.8
		MCWB	10.7	10.7	12.7	14.9	19.1	21.9	22.2	22.6	20.7	18.4	15.0	11.5
	5%	DB	12.3	14.0	17.3	20.2	25.1	29.2	31.2	31.1	26.9	22.1	17.9	13.6
		MCWB	9.0	10.0	12.0	14.4	18.2	21.4	22.1	22.6	20.7	17.8	14.7	10.5
	10%	DB	10.8	12.2	15.8	18.8	23.6	28.0	30.0	29.8	25.4	20.8	16.4	11.9
		MCWB	8.3	9.1	11.4	13.7	17.6	21.1	21.8	22.5	20.0	17.2	13.7	9.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	12.7	15.2	17.4	21.9	25.4	25.7	26.2	23.4	20.6	17.1	13.9
		MCDB	16.2	16.0	19.5	21.5	26.7	29.6	29.5	30.3	27.4	23.2	19.9	16.9
	2%	WB	11.2	11.4	13.6	16.1	20.3	23.8	24.5	24.9	22.2	19.4	16.0	12.2
		MCDB	14.4	14.4	17.7	20.0	24.9	28.6	29.4	29.6	26.5	22.3	18.6	15.1
	5%	WB	9.8	10.5	12.7	15.3	19.2	22.7	23.7	24.0	21.3	18.6	15.1	11.0
		MCDB	11.7	13.1	16.4	19.0	23.6	27.4	29.1	28.9	25.5	21.4	17.3	13.1
	10%	WB	8.5	9.5	11.7	14.3	18.2	21.8	22.9	23.1	20.5	17.7	14.1	9.8
		MCDB	10.3	12.0	15.2	17.8	22.4	26.7	28.4	28.0	24.5	20.2	16.3	11.3
Mean Daily Temperature Range	5% DB	MDBR	6.9	8.0	8.9	9.2	9.5	9.6	9.9	9.6	8.9	8.0	7.1	7.0
		MCDBR	10.4	10.5	11.6	12.0	12.0	11.7	12.2	12.0	10.5	9.8	9.0	9.8
		MCWBR	7.0	6.8	6.8	6.9	6.2	6.0	6.0	6.3	5.7	5.8	5.7	6.7
	5% WB	MCDBR	9.0	9.1	10.3	10.3	10.5	10.1	10.4	9.9	9.1	8.6	7.8	8.3
		MCWBR	6.4	6.3	6.6	6.5	6.1	6.1	6.2	6.3	5.7	5.7	5.3	6.0
Clear-Sky Solar Irradiance	taub	0.349	0.370	0.402	0.441	0.440	0.439	0.433	0.430	0.416	0.399	0.373	0.346	
	taud	2.419	2.345	2.265	2.171	2.230	2.279	2.298	2.319	2.338	2.367	2.374	2.444	
	Ebn at Noon	768	813	831	825	836	836	837	826	807	769	728	736	
	Edh at Noon	77	98	119	141	137	131	127	121	110	95	80	70	
All-Sky Solar Radiation	RadAvg	1.39	2.23	3.50	4.70	5.79	6.58	6.76	5.85	4.20	2.70	1.61	1.26	
	RadStd	0.20	0.29	0.44	0.42	0.48	0.33	0.28	0.35	0.26	0.28	0.17	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	+1.48	N/A	-0.73	-0.87	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	+0.27	N/A	N/A	N/A	N/A	-0.42	N/A	N/A	N/A	N/A

Nomenclature: See separate page