

MONTE TERMINILLO, Italy

WMO: 162190

Lat: 42.460N

Lon: 12.985E

Elev: 6152

StdP: 11.71

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.8	14.0	-8.0	4.5	31.9	-1.3	6.4	28.3	58.7	22.6	53.5	20.7	34.4	70	0.760

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	72.5	58.8	69.7	57.6	67.4	56.9	61.8	68.1	60.0	66.3	58.4	64.8	7.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.4	95.3	64.7	57.5	88.8	63.0	55.7	83.3	61.8	30.9	68.0	29.5	66.3	28.3	64.9	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 50.0	42.6	34.6	9.3	76.2	5.1	5.1	5.6	79.9	2.6	82.9	-0.3	85.7	-4.0	89.4		
(5)			7.9	65.5	4.9	2.5	4.5	67.2	1.6	68.7	-1.1	70.1	-4.6	71.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.5	29.2	29.5	32.9	37.2	46.0	53.0	58.4	59.1	50.3	45.4	36.2	31.6		
	DBStd	12.52	6.64	6.66	7.47	6.72	6.83	7.27	5.67	5.52	6.03	6.62	7.52	6.90		
	HDD50	3584	645	575	532	386	162	53	6	3	68	169	416	569		
	HDD65	8241	1110	995	997	833	588	362	215	195	440	608	864	1034		
	CDD50	842	0	0	0	3	39	143	265	285	78	26	3	0		
	CDD65	25	0	0	0	0	0	2	10	13	0	0	0	0		
	CDH74	38	0	0	0	0	0	2	14	22	0	0	0	0		
	CDH80	2	0	0	0	0	0	0	1	1	0	0	0	0		
	WSAvg	13.1	15.4	14.4	15.8	13.3	11.9	11.0	10.1	9.7	12.2	12.3	15.3	15.6		
	PrecAvg	31.0	1.5	1.7	2.0	2.7	3.0	3.6	2.2	2.8	3.7	4.2	4.1	1.9		
(15) Precipitation	PrecMax	45.7	6.0	5.0	5.4	6.3	6.8	6.7	6.2	9.3	18.2	16.2	10.7	4.4		
	PrecMin	20.2	0.0	0.2	0.3	0.3	0.0	0.9	0.0	0.0	0.4	0.0	0.0	0.0		
	PrecStd	7.3	1.7	1.2	1.5	1.6	1.7	1.6	1.6	2.1	3.3	3.8	2.9	1.3		
	PrecStd	7.3	1.7	1.2	1.5	1.6	1.7	1.6	1.6	2.1	3.3	3.8	2.9	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	49.8	52.1	59.1	68.1	73.0	75.5	76.7	68.1	62.4	57.4	50.0		
		MCWB	38.5	38.1	42.1	47.6	55.3	60.1	60.4	58.7	57.4	51.1	47.7	36.2		
	2%	DB	43.4	45.1	48.5	53.5	62.4	68.8	71.9	73.3	64.4	59.0	52.5	44.7		
		MCWB	34.7	35.4	40.8	44.9	52.9	57.8	59.5	58.5	55.3	49.8	45.0	33.9		
	5%	DB	40.3	41.1	46.0	49.8	59.0	65.9	69.4	70.0	61.4	56.6	48.3	41.6		
		MCWB	33.4	33.3	39.3	43.1	51.2	56.9	58.5	57.0	54.2	48.6	43.1	34.8		
	10%	DB	37.6	37.4	42.7	46.6	55.9	63.1	66.5	67.7	58.9	53.8	45.0	39.6		
		MCWB	32.6	31.9	36.9	41.2	49.4	55.0	57.0	56.5	53.1	47.4	41.7	35.0		
	0.4%	WB	39.5	39.6	45.0	51.2	58.3	63.8	63.7	63.8	60.0	54.9	50.3	41.7		
		MCDB	45.7	45.1	49.5	55.8	64.6	68.7	71.0	69.9	63.6	58.1	54.4	43.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	37.2	37.4	42.4	46.7	54.5	60.7	61.6	61.2	57.3	52.5	47.4	39.5		
		MCDB	40.8	41.5	46.8	51.5	59.8	65.8	68.4	67.9	61.8	55.8	50.3	40.8		
	5%	WB	35.3	35.2	40.3	43.8	52.2	58.2	60.0	59.4	55.5	50.7	44.8	37.8		
		MCDB	38.0	38.8	44.0	48.8	57.3	63.8	66.8	66.0	60.0	53.8	46.5	39.5		
	10%	WB	33.6	33.3	38.1	41.8	50.2	56.1	58.3	57.9	53.7	49.0	42.3	36.1		
		MCDB	36.3	35.9	41.5	45.8	55.1	61.9	65.0	64.7	57.7	52.2	44.6	37.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	8.1	8.4	9.2	10.2	10.2	10.7	10.8	9.1	8.5	7.3	7.4		
		MCDBR	10.6	12.6	12.4	12.9	13.8	13.2	13.4	13.9	12.1	11.5	11.3	10.0		
		MCWBR	8.7	10.8	11.4	11.1	12.4	12.0	11.2	10.9	10.6	11.4	10.3	8.1		
	5% WB	MCDBR	9.4	10.0	10.8	11.6	12.2	11.2	11.6	11.6	10.5	9.3	9.0	7.5		
		MCWBR	8.4	9.3	10.5	10.6	11.9	11.9	11.4	11.0	9.8	10.2	9.5	7.5		
(40) Clear-Sky Solar Irradiance	taub	0.254	0.270	0.296	0.320	0.325	0.324	0.317	0.316	0.308	0.295	0.278	0.256	0.256		
	taud	2.581	2.533	2.486	2.429	2.433	2.457	2.479	2.488	2.514	2.553	2.567	2.585	2.585		
	Ebn at Noon	292	302	303	301	300	300	301	299	295	287	278	281	281		
	Edh at Noon	21	25	30	35	36	35	34	32	29	25	21	19	19		
(44) All-Sky Solar Radiation	RadAvg	534	790	1147	1491	1817	2106	2214	1947	1402	960	595	476	476		
	RadStd	62	89	147	137	180	113	126	131	76	95	64	62	62		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (19 neighbors)	+0.77	N/A	N/A	+1.03	N/A	N/A	N/A	-155	+234	+122

Nomenclature: See separate page