

MONTE TERMINILLO, Italy

WMO: 162190

Lat: 42.460N

Lon: 12.985E

Elev: 1875

StdP: 80.74

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.8	-10.0	-22.2	0.6	0.0	-18.5	0.9	-2.0	26.2	-5.2	23.9	-6.3	15.4	70	0.760

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	22.5	14.9	21.0	14.2	19.6	13.8	16.5	20.1	15.6	19.0	14.7	18.2	3.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	13.6	18.2	14.2	12.7	17.2	13.2	11.9	16.6	53.9	20.0	50.8	19.0	48.0	18.3	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.3	19.0	15.5	DB	-12.6	24.6	2.9	2.8	-14.7	26.6	-16.4	28.3	-18.0	29.9	-20.0	31.9	(4)
(5)			WB	-13.4	18.6	2.7	1.4	-15.3	19.6	-16.9	20.4	-18.4	21.2	-20.4	22.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	-1.6	-1.4	0.5	2.9	7.8	11.7	14.6	15.1	10.2	7.4	2.3	-0.2	(6)	
	DBStd	6.96	3.69	3.70	4.15	3.73	3.79	4.04	3.15	3.06	3.35	3.68	4.18	3.83	(7)	
	HDD10.0	1991	358	319	296	214	90	29	3	2	38	94	231	316	(8)	
	HDD18.3	4578	617	553	554	463	327	201	119	108	244	338	480	574	(9)	
	CDD10.0	468	0	0	0	2	22	79	147	158	43	14	2	0	(10)	
	CDD18.3	14	0	0	0	0	0	1	6	7	0	0	0	0	(11)	
	CDH23.3	21	0	0	0	0	0	1	8	12	0	0	0	0	(12)	
	CDH26.7	1	0	0	0	0	0	0	1	1	0	0	0	0	(13)	
(14) Wind	WSAvg	5.8	6.9	6.4	7.1	5.9	5.3	4.9	4.5	4.4	5.4	5.5	6.8	7.0	(14)	
(15) Precipitation	PrecAvg	787	37	44	51	69	75	91	56	71	93	106	105	47	(15)	
	PrecMax	1162	152	128	137	160	172	170	158	236	463	412	273	111	(16)	
	PrecMin	514	0	4	8	8	0	23	0	0	11	1	1	0	(17)	
	PrecStd	185	43	30	37	41	44	40	41	53	84	96	74	34	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	9.9	11.2	15.1	20.0	22.8	24.2	24.9	20.1	16.9	14.1	10.0	(19)	
		MCWB	3.6	3.4	5.6	8.7	13.0	15.6	15.8	14.8	14.1	10.6	8.7	2.3	(20)	
	2%	DB	6.3	7.3	9.2	11.9	16.9	20.4	22.2	22.9	18.0	15.0	11.4	7.0	(21)	
		MCWB	1.5	1.9	4.9	7.2	11.6	14.4	15.3	14.7	12.9	9.9	7.2	1.0	(22)	
	5%	DB	4.6	5.0	7.8	9.9	15.0	18.8	20.8	21.1	16.3	13.7	9.1	5.3	(23)	
		MCWB	0.8	0.7	4.1	6.2	10.7	13.8	14.7	13.9	12.3	9.2	6.2	1.6	(24)	
	10%	DB	3.1	3.0	6.0	8.1	13.3	17.3	19.2	19.8	14.9	12.1	7.2	4.2	(25)	
		MCWB	0.3	0.0	2.7	5.1	9.7	12.8	13.9	13.6	11.7	8.5	5.4	1.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.2	4.2	7.2	10.7	14.6	17.6	17.6	17.6	15.6	12.7	10.2	5.4	(27)	
		MCDB	7.6	7.3	9.7	13.2	18.1	20.4	21.7	21.0	17.6	14.5	12.4	6.4	(28)	
	2%	WB	2.9	3.0	5.8	8.1	12.5	15.9	16.4	16.2	14.0	11.4	8.5	4.2	(29)	
		MCDB	4.9	5.3	8.2	10.8	15.4	18.8	20.2	19.9	16.6	13.2	10.2	4.9	(30)	
	5%	WB	1.8	1.8	4.6	6.5	11.2	14.6	15.5	15.2	13.1	10.4	7.1	3.2	(31)	
		MCDB	3.4	3.8	6.7	9.3	14.1	17.6	19.3	18.9	15.6	12.1	8.1	4.2	(32)	
	10%	WB	0.9	0.7	3.4	5.4	10.1	13.4	14.6	14.4	12.1	9.5	5.7	2.3	(33)	
		MCDB	2.4	2.2	5.3	7.7	12.8	16.6	18.3	18.2	14.3	11.2	7.0	3.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.1	4.5	4.7	5.1	5.7	5.7	5.9	6.0	5.0	4.7	4.0	4.1	(35)	
		MCDBR	5.9	7.0	6.9	7.2	7.7	7.3	7.5	7.7	6.7	6.4	6.3	5.6	(36)	
	5% WB	MCWBR	4.8	6.0	6.3	6.1	6.9	6.7	6.2	6.0	5.9	6.3	5.7	4.5	(37)	
		MCWBR	5.2	5.6	6.0	6.4	6.8	6.2	6.5	6.4	5.9	5.2	5.0	4.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.254	0.270	0.296	0.320	0.325	0.324	0.317	0.316	0.308	0.295	0.278	0.256	(40)	
		taud	2.581	2.533	2.486	2.429	2.433	2.457	2.479	2.488	2.514	2.553	2.567	2.585	(41)	
	Edn at Noon	Edn at Noon	919	951	956	949	947	945	949	942	930	905	876	885	(42)	
		Edh at Noon	65	80	96	109	112	110	106	102	92	78	66	60	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.68	2.49	3.62	4.70	5.73	6.64	6.98	6.14	4.42	3.03	1.88	1.50	(44)	
	RadStd	RadStd	0.20	0.28	0.46	0.43	0.57	0.36	0.40	0.41	0.24	0.30	0.20	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		+0.43	N/A	N/A	+0.57	N/A	N/A	N/A	-86	+130	+68

Nomenclature: See separate page