

ROMA FIUMICINO, Italy

WMO: 162420

Lat: 41.800N

Lon: 12.239E

Elev: 3

StdP: 101.29

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.1	(c) 1.0	(d) -7.8	(e) 1.9	(f) 3.9	(g) -5.8	(h) 2.3	(i) 4.1	(j) 13.0	(k) 12.1	(l) 11.4	(m) 11.1	(n) 2.8	(o) 40	(p) 0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 10.0	(c) 31.6	(d) 21.9	(e) 30.3	(f) 22.1	(g) 29.5	(h) 22.1	(i) 25.1	(j) 28.4	(k) 24.3	(l) 27.9	(m) 23.6	(n) 27.3	(o) 4.9	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	19.0	27.0	23.2	17.9	26.5	22.2	16.9	25.9	76.4	28.5	73.3	27.6	70.5	27.5	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
10.4	9.0	7.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-2.7	34.1	1.4	1.3	-3.7	35.0	-4.5	35.8	-5.3	36.5	-6.3	37.4		
			-4.2	26.0	1.4	1.1	-5.2	26.8	-6.0	27.4	-6.9	28.0	-7.9	28.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	8.6	8.9	11.0	13.6	17.6	21.5	24.0	24.5	21.0	17.5	13.3	9.7
	DBStd	6.15	2.79	2.77	2.39	2.36	2.26	2.44	1.82	1.91	2.33	2.47	3.15	2.98
	HDD10.0	178	60	49	17	2	0	0	0	0	0	0	8	42
	HDD18.3	1450	301	264	227	142	41	3	0	0	5	44	153	269
	CDD10.0	2359	17	18	48	111	236	345	435	448	330	233	107	32
	CDD18.3	589	0	0	0	1	19	98	177	190	84	19	2	0
	CDH23.3	4901	0	0	0	6	122	793	1662	1777	491	49	1	0
CDH26.7	1321	0	0	0	1	14	181	489	570	64	1	0	0	
Wind	WSAvg	3.4	3.5	3.6	3.6	3.4	3.2	3.3	3.3	3.2	3.2	3.1	3.5	3.5
Precipitation	PrecAvg	708	75	71	62	50	33	20	8	29	71	90	102	90
	PrecMax	1184	213	173	161	142	118	108	104	119	280	270	365	223
	PrecMin	404	3	11	2	1	0	0	0	0	0	0	6	6
	PrecStd	179	52	47	40	36	29	23	19	32	63	70	74	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	17.5	20.2	23.9	28.3	31.8	32.6	33.9	30.0	26.1	22.2	18.1
		MCWB	13.5	12.2	12.9	15.9	18.0	21.2	21.3	21.9	21.2	19.6	17.8	14.7
	2%	DB	15.6	15.9	18.2	21.9	26.1	30.0	31.1	32.1	28.2	24.8	20.9	16.9
		MCWB	12.7	12.1	12.7	14.9	18.1	21.2	21.8	22.3	21.1	19.4	17.2	14.2
	5%	DB	14.7	15.0	17.0	20.1	24.5	28.9	30.2	30.9	27.1	23.7	19.8	16.0
		MCWB	12.0	11.6	12.7	14.6	17.8	21.0	22.1	22.6	21.0	18.9	16.4	13.4
	10%	DB	13.8	14.0	16.0	18.9	23.1	27.3	29.2	29.8	26.1	22.5	18.5	15.0
		MCWB	11.2	11.0	12.2	14.3	17.3	20.7	22.2	22.7	20.5	18.3	15.4	12.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.4	14.0	15.0	17.1	20.6	24.3	25.9	26.2	24.5	21.9	19.1	15.7
		MCDB	16.1	15.6	17.8	21.1	24.4	27.6	28.8	28.9	26.9	24.0	20.9	17.2
	2%	WB	13.2	13.0	14.1	16.1	19.6	23.3	24.9	25.4	23.1	20.6	17.8	14.7
		MCDB	15.1	14.9	16.6	19.9	23.4	27.1	28.3	28.6	26.2	23.0	20.1	16.4
	5%	WB	12.4	12.2	13.4	15.4	18.8	22.5	24.2	24.6	22.2	19.7	16.7	13.8
		MCDB	14.3	14.3	15.9	18.9	22.7	26.6	27.8	28.2	25.6	22.5	19.0	15.6
	10%	WB	11.4	11.4	12.8	14.8	18.1	21.6	23.5	23.9	21.4	18.9	15.7	12.7
		MCDB	13.4	13.6	15.3	18.0	22.0	25.9	27.3	27.7	24.9	21.9	18.1	14.7
Mean Daily Temperature Range	5% DB	MDBR	8.5	9.0	9.3	9.6	9.9	10.1	9.9	10.0	9.4	9.2	8.3	8.3
		MCDBR	8.6	9.2	10.6	11.3	12.2	11.8	11.2	11.4	10.1	9.8	8.3	7.9
		MCWBR	6.4	6.6	6.8	6.4	6.0	5.7	5.8	5.8	5.7	6.0	5.5	6.0
	5% WB	MCDBR	7.5	7.8	9.3	9.9	10.5	10.2	9.8	9.9	9.0	8.7	7.3	6.7
		MCWBR	6.1	6.1	6.6	6.4	6.1	5.7	5.9	5.9	5.7	5.9	5.5	5.7
Clear-Sky Solar Irradiance	taub	0.345	0.366	0.402	0.432	0.438	0.430	0.424	0.424	0.416	0.402	0.378	0.346	
	taud	2.452	2.371	2.270	2.202	2.235	2.305	2.326	2.338	2.354	2.368	2.365	2.446	
	Ebn at Noon	795	831	839	839	842	847	849	838	816	780	741	758	
	Edh at Noon	78	98	121	138	137	129	125	120	110	97	84	73	
All-Sky Solar Radiation	RadAvg	1.77	2.71	3.96	5.30	6.48	7.34	7.48	6.53	4.79	3.26	2.00	1.60	
	RadStd	0.17	0.26	0.44	0.35	0.52	0.31	0.33	0.33	0.24	0.28	0.18	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.38	N/A	N/A	+0.63	N/A	N/A	N/A	N/A	+122	+66
(47) Regional (16 neighbors)		+0.42	N/A	N/A	+0.53	N/A	N/A	N/A	-78	+135	+69

Nomenclature: See separate page