

LATINA, Italy

WMO: 162430

Lat: 41.5458N

Lon: 12.9097E

Elev: 86

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 90-02

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.6	33.5	21.1	15.8	42.9	24.8	18.9	41.6	19.7	54.4	16.9	52.1	1.8	320	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.2	91.1	74.7	88.2	74.4	86.2	73.7	78.9	85.7	77.2	84.4	75.7	83.0	8.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.9	140.7	83.0	75.1	132.3	81.5	73.5	124.9	80.1	42.4	85.5	40.7	84.1	39.2	81.9	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.2	15.1	12.8	DB	27.7	96.3	2.3	3.7	26.0	98.9	24.7	101.1	23.4	103.2	21.8	105.9	
			WB	26.3	82.0	2.2	2.3	24.7	83.6	23.5	85.0	22.2	86.3	20.7	87.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.5	47.0	47.3	52.1	55.2	63.7	70.6	75.5	77.0	69.7	63.6	55.1	48.0
	DBStd	11.45	4.95	4.43	4.24	4.04	4.21	3.64	3.51	3.57	3.67	4.71	5.68	5.09
	HDD50	356	116	91	27	6	0	0	0	0	0	0	16	100
	HDD65	2743	557	494	401	295	76	3	0	0	5	85	301	526
	CDD50	4183	24	17	91	161	424	618	791	837	591	421	169	39
	CDD65	1096	0	0	0	0	35	172	326	373	146	41	3	0
	CDH74	9499	0	0	0	1	226	1371	3212	3696	856	134	3	0
	CDH80	3075	0	0	0	0	14	275	1156	1502	116	12	0	0
Wind	WSAvg	3.6	3.1	3.4	4.0	4.3	3.5	4.0	3.9	3.4	3.9	3.4	3.6	3.2
Precipitation	PrecAvg	38.1	4.1	3.1	3.2	3.1	2.0	1.4	0.7	1.8	3.4	4.7	5.9	4.4
	PrecMax	52.8	8.1	6.1	7.9	9.4	4.4	4.1	3.1	4.6	9.8	13.5	11.4	9.0
	PrecMin	28.0	0.2	0.2	0.4	0.9	0.0	0.1	0.0	0.0	0.1	0.8	0.7	
	PrecStd	7.6	2.3	1.9	2.0	2.2	1.1	1.2	0.9	1.4	2.5	3.6	3.3	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.4	62.6	71.1	72.0	82.2	88.2	93.1	94.9	85.0	81.0	73.1	62.7
		MCWB	56.9	54.0	56.7	61.7	67.3	73.0	74.7	75.3	70.2	67.4	66.7	57.9
	2%	DB	59.3	60.4	66.4	69.5	78.8	85.7	90.0	91.6	82.7	77.3	68.4	60.6
		MCWB	54.3	53.4	56.7	60.2	65.6	71.4	74.9	74.6	70.5	68.2	62.5	56.1
	5%	DB	57.4	58.6	64.0	66.6	76.8	82.8	88.0	89.6	80.9	75.1	66.5	58.8
		MCWB	52.8	52.1	55.8	58.9	65.8	70.4	74.4	74.4	70.3	68.2	61.9	55.0
	10%	DB	55.6	56.9	61.0	64.6	73.8	80.8	86.1	87.5	79.0	72.8	64.5	57.0
		MCWB	51.5	50.9	55.1	57.9	65.3	69.5	73.6	74.6	69.5	66.7	60.1	53.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.1	57.3	61.3	64.5	71.1	76.7	80.9	81.6	75.9	72.8	67.4	59.4
		MCDB	61.1	60.5	65.9	68.9	77.4	83.5	87.1	87.4	79.9	76.1	70.8	61.5
	2%	WB	55.7	54.9	58.9	61.9	69.1	74.6	78.6	79.5	74.2	71.1	64.7	57.6
		MCDB	58.6	58.3	62.9	66.8	75.2	81.6	85.6	86.1	79.2	74.8	67.5	59.7
	5%	WB	54.0	53.5	57.2	60.1	67.5	72.9	77.0	77.9	72.6	69.3	63.0	55.9
		MCDB	56.9	56.8	61.7	65.2	73.7	79.5	84.6	84.9	78.0	72.8	66.1	58.1
	10%	WB	52.2	52.0	55.8	58.8	66.2	71.4	75.4	76.4	71.1	67.4	60.5	54.3
		MCDB	55.2	55.5	60.2	63.5	72.5	78.4	83.0	83.7	76.7	71.4	63.9	56.7
Mean Daily Temperature Range	5% DB	MDBR	15.4	16.5	17.0	16.4	17.6	18.8	19.3	19.2	16.9	15.5	14.3	14.2
		MCDBR	15.5	18.5	20.6	19.7	21.0	21.7	21.5	22.6	19.0	17.3	14.0	14.4
		MCWBR	11.4	13.1	13.2	13.0	11.5	11.7	10.7	10.7	10.7	11.0	9.9	10.9
	5% WB	MCDBR	14.1	15.9	17.7	17.5	18.5	19.1	19.3	19.5	16.5	14.8	12.3	12.3
		MCWBR	11.1	12.8	12.7	12.6	11.9	12.1	11.4	11.5	10.7	10.9	9.7	10.6
Clear-Sky Solar Irradiance	taub	0.354	0.380	0.422	0.452	0.456	0.449	0.441	0.441	0.432	0.416	0.390	0.355	
	taud	2.395	2.295	2.175	2.117	2.156	2.230	2.258	2.269	2.282	2.290	2.292	2.385	
	Ebn at Noon	248	258	259	260	262	264	264	261	254	242	229	236	
	Edh at Noon	26	34	42	48	47	44	43	41	38	33	29	25	
All-Sky Solar Radiation	RadAvg	562	841	1230	1639	1999	2281	2339	2043	1486	1028	636	511	
	RadStd	56	85	143	107	163	102	115	118	74	90	61	56	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (16 neighbors)		+0.74	N/A	N/A	+0.95	N/A	N/A	N/A	-142	+236	+122

Nomenclature: See separate page