

CAMPOBASSO, Italy

WMO: 162520

Lat: 41.5634N

Lon: 14.6554E

Elev: 2648

StdP: 13.34

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.3	26.9	10.0	10.1	41.5	15.3	13.2	39.1	34.1	41.6	29.1	40.3	6.7	340	0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.3	89.5	65.3	86.3	65.2	83.9	64.7	71.1	79.4	69.5	78.0	68.1	77.2	4.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.7	116.3	73.8	66.9	109.1	73.1	65.2	102.8	72.2	36.8	79.9	35.3	78.4	34.0	76.1	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.5	20.7	16.9	DB	21.4	93.9	3.6	3.2	18.8	96.2	16.8	98.1	14.8	100.0	12.2	102.3	(4)
(5)			WB	19.9	73.6	3.0	2.8	17.7	75.6	15.9	77.3	14.2	78.9	12.0	80.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.6	40.0	40.6	45.9	52.3	59.7	68.4	73.3	73.5	64.0	57.5	49.1	42.4
	DBStd	13.60	6.57	6.99	7.45	6.66	6.78	7.26	6.23	6.04	6.53	6.79	6.84	6.52
	HDD50	1166	314	270	169	49	6	0	0	0	1	18	96	243
	HDD65	4205	775	684	592	383	193	47	8	6	94	245	479	699
	CDD50	3222	4	5	42	118	306	551	721	729	421	249	67	9
	CDD65	786	0	0	0	2	27	148	264	270	64	11	0	0
	CDH74	5207	0	0	0	3	100	931	1972	1919	265	16	1	0
	CDH80	1586	0	0	0	0	15	236	653	628	54	0	0	0
Wind	WSAvg	4.4	4.8	5.3	5.7	4.2	4.3	4.2	4.3	3.5	3.9	3.8	4.5	5.0
Precipitation	PrecAvg	25.0	2.1	2.2	2.0	2.1	1.9	1.3	1.3	1.6	1.8	2.3	3.3	2.8
	PrecMax	33.0	5.0	5.7	5.6	7.4	7.3	3.7	4.8	4.8	4.2	10.0	8.8	7.1
	PrecMin	16.4	0.1	0.3	0.6	0.2	0.1	0.1	0.0	0.0	0.0	0.1	0.7	0.1
	PrecStd	4.8	1.4	1.4	1.0	1.5	1.4	0.9	1.1	1.1	1.2	1.9	2.0	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.4	60.2	66.4	73.5	82.1	89.4	92.8	94.6	85.8	76.4	67.5	59.0
		MCWB	46.8	45.5	51.0	56.4	63.6	67.0	65.8	65.5	63.6	58.8	53.8	49.7
	2%	DB	53.7	55.6	62.6	69.2	76.5	85.8	89.6	89.5	80.6	72.5	62.8	55.5
		MCWB	46.0	44.5	49.9	53.8	61.4	65.9	65.2	65.2	62.4	58.6	53.1	49.0
	5%	DB	51.3	52.1	59.3	65.0	73.2	82.5	86.4	86.2	76.8	69.5	60.4	53.1
		MCWB	44.9	43.9	48.9	52.3	59.4	64.6	65.2	65.1	61.8	57.3	52.5	47.2
	10%	DB	48.4	49.7	55.8	62.2	70.0	79.2	83.8	83.5	73.5	66.4	57.5	50.4
		MCWB	43.7	43.6	47.5	51.7	58.1	63.7	64.7	64.5	61.0	57.2	51.6	46.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.4	50.4	55.2	60.5	67.3	72.6	73.3	72.8	69.1	64.3	59.3	54.7
		MCDB	54.0	54.6	60.9	68.1	73.5	81.9	82.3	80.1	75.2	69.3	62.9	56.2
	2%	WB	48.2	48.0	52.8	57.4	64.4	70.2	71.0	70.8	66.7	62.1	56.0	51.0
		MCDB	51.7	51.2	58.2	63.4	72.3	78.7	80.1	78.3	72.6	66.9	60.0	53.2
	5%	WB	46.5	46.3	50.8	55.3	62.0	68.3	69.4	69.1	65.1	60.7	54.1	48.9
		MCDB	49.3	49.8	55.9	61.6	70.0	77.3	78.6	77.5	71.6	65.8	57.9	51.2
	10%	WB	44.7	44.6	49.0	53.3	60.0	66.3	67.9	67.7	63.5	59.0	52.4	47.1
		MCDB	47.7	48.4	54.0	59.5	67.6	75.8	77.6	77.1	70.1	63.5	56.1	49.7
Mean Daily Temperature Range	5% DB	MDBR	8.3	9.8	11.3	12.3	13.2	14.3	15.1	15.3	12.5	11.1	8.7	8.0
		MCDBR	11.5	13.3	15.3	15.4	15.6	16.4	17.0	16.9	15.4	14.3	11.5	10.2
		MCWBR	7.3	8.1	8.2	8.7	8.3	8.8	7.9	7.4	6.8	7.0	7.1	7.1
	5% WB	MCDBR	9.8	11.1	13.5	13.7	14.8	15.5	16.1	15.8	13.9	12.6	10.3	8.4
		MCWBR	7.9	8.4	8.4	8.9	9.2	9.2	8.5	8.6	8.0	7.4	7.7	7.5
Clear-Sky Solar Irradiance	taub	0.301	0.322	0.351	0.387	0.388	0.386	0.384	0.383	0.373	0.346	0.327	0.304	
	taud	2.508	2.436	2.357	2.262	2.303	2.337	2.349	2.361	2.394	2.463	2.474	2.509	
	Ebn at Noon	272	281	284	280	282	281	281	278	273	269	258	260	
	Edh at Noon	23	29	35	41	41	39	39	37	33	28	24	22	
All-Sky Solar Radiation	RadAvg	539	776	1158	1535	1873	2139	2218	1971	1409	979	622	491	
	RadStd	65	81	134	136	149	115	129	132	88	97	62	67	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (17 neighbors)		+0.79	N/A	N/A	N/A	N/A	-0.61	N/A	-164	+254	+119

Nomenclature: See separate page