

MONTE SANT'ANGELO, Italy

WMO: 162580

Lat: 41.708N

Lon: 15.948E

Elev: 2782

StdP: 13.28

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.9	28.0	4.8	7.8	44.2	11.5	10.9	39.8	37.2	29.9	31.7	34.2	16.2	340	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.3	87.2	63.0	84.3	62.5	81.6	62.0	68.6	77.5	66.9	76.5	65.5	75.5	6.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.9	106.1	72.0	63.9	98.8	70.9	62.1	92.6	69.8	34.6	77.5	33.1	76.4	32.0	75.6	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.4	24.2	21.0	DB	21.3	90.4	3.0	4.0	19.1	93.3	17.4	95.6	15.7	97.9	13.5	100.8	(4)
(5)			WB	19.4	73.7	2.5	2.5	17.6	75.5	16.2	77.0	14.8	78.4	13.0	80.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.5	39.2	39.8	44.5	51.0	58.2	66.8	71.7	72.0	63.1	56.1	48.9	41.6		
	DBStd	13.34	5.95	6.39	6.94	6.37	7.50	7.88	6.68	6.51	6.72	6.60	6.00	6.07		
	HDD50	1270	336	289	197	60	11	1	0	0	1	23	88	264		
	HDD65	4499	798	704	635	422	237	71	16	14	113	281	484	724		
	CDD50	2915	2	5	27	89	266	505	673	682	395	212	54	5		
	CDD65	673	0	0	0	1	27	126	224	232	57	6	0	0		
	CDH74	3794	0	0	0	0	80	652	1402	1447	211	2	0	0		
	CDH80	921	0	0	0	0	11	145	349	384	32	0	0	0		
	WSAvg	9.3	10.7	11.5	10.7	9.6	8.7	8.0	7.9	7.8	8.3	8.6	9.4	10.9		
	PrecAvg	27.3	3.0	2.0	2.2	2.2	1.9	1.9	2.0	1.5	2.8	2.6	2.6	3.0		
(15) Precipitation	PrecMax	61.8	13.1	7.1	5.8	8.0	6.7	5.9	7.4	3.7	8.5	7.2	6.1	8.7		
	PrecMin	11.3	0.0	0.3	0.3	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.6		
	PrecStd	11.9	3.1	2.0	1.8	1.8	1.5	1.7	1.9	1.1	2.2	2.0	1.7	2.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.9	58.4	62.5	69.8	81.3	88.4	91.1	90.6	84.0	72.9	65.5	56.3		
		MCWB	46.6	44.5	50.1	53.9	60.2	64.7	62.7	62.4	62.1	60.6	51.6	47.6		
	2%	DB	51.8	54.1	59.1	66.2	75.8	84.1	86.7	87.4	79.6	69.6	61.0	53.5		
		MCWB	44.8	43.5	48.1	51.5	58.3	63.0	63.1	62.6	61.6	57.4	51.9	46.3		
	5%	DB	49.4	50.6	56.6	63.1	72.2	80.7	83.9	84.3	75.9	66.8	58.5	51.4		
		MCWB	43.7	43.4	46.7	50.1	57.3	62.5	62.3	62.5	60.7	57.0	51.7	45.5		
	10%	DB	46.9	48.0	54.1	60.0	68.9	77.6	81.0	81.4	72.3	64.5	56.0	49.4		
		MCWB	42.6	43.0	45.5	48.7	55.8	60.9	61.4	61.9	60.0	55.8	50.9	45.0		
	0.4%	WB	49.5	48.8	53.5	56.0	63.7	69.8	70.5	71.2	68.3	63.5	58.1	51.0		
		MCDB	54.4	52.6	58.6	66.3	74.2	78.9	78.8	77.4	74.7	67.8	60.4	53.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	47.3	46.8	50.7	53.9	61.2	67.0	68.0	68.7	65.7	61.2	55.4	48.9		
		MCDB	49.7	50.2	55.9	62.3	71.0	78.8	77.9	76.5	71.9	65.7	58.0	51.3		
	5%	WB	45.3	45.2	48.7	52.1	59.3	64.9	66.5	66.8	64.0	59.5	53.7	47.3		
		MCDB	47.7	48.6	53.8	59.5	69.5	76.3	77.0	76.1	71.4	64.2	56.1	50.0		
	10%	WB	43.3	43.6	47.1	50.4	57.4	63.2	65.0	65.5	62.1	57.8	52.0	45.6		
		MCDB	45.8	47.0	52.2	57.0	67.0	74.3	75.8	75.3	69.2	62.2	54.5	48.5		
	5% DB	MDBR	6.8	7.6	8.8	10.2	11.1	11.7	12.1	12.3	10.1	8.6	7.3	6.6		
		MCDBR	9.9	10.9	11.3	12.0	13.6	14.2	13.9	13.8	12.7	10.6	9.9	8.4		
		MCWBR	8.7	8.4	9.2	10.0	9.8	10.4	9.4	9.2	10.5	9.9	8.9	7.6		
		MCWBR	8.4	9.1	10.0	11.3	12.9	13.1	12.7	13.0	11.1	9.6	8.4	7.1		
(35) Mean Daily Temperature Range	5% WB	MCWBR	8.3	8.1	8.9	10.0	10.0	10.0	10.6	10.9	10.8	9.9	8.3	7.4		
	taub		0.307	0.327	0.354	0.398	0.395	0.390	0.387	0.389	0.377	0.350	0.329	0.308		
		taud	2.514	2.444	2.372	2.245	2.313	2.355	2.367	2.364	2.398	2.469	2.482	2.516		
(40) Clear-Sky Solar Irradiance	Ebn at Noon		269	279	283	276	279	280	280	276	272	267	257	259		
		Edh at Noon	23	29	35	42	40	39	38	37	33	28	23	21		
	RadAvg		546	790	1209	1610	1980	2216	2261	1988	1436	996	628	486		
(44) All-Sky Solar Radiation	RadStd		64	81	117	126	133	109	109	121	81	85	51	64		

Historical Trends

Station Only	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-180	+259	+121

Nomenclature: See separate page