

AMENDOLA, Italy

WMO: 162610

Lat: 41.541N

Lon: 15.718E

Elev: 183

StdP: 14.60

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.4	32.9	20.9	15.8	42.2	24.5	18.7	41.1	31.0	47.2	27.6	47.6	7.2	300	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.2	96.9	72.3	93.7	71.5	91.2	71.0	76.9	86.3	75.4	85.4	74.1	84.6	11.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.8	131.4	80.3	73.0	123.3	79.3	71.3	116.1	78.4	40.5	85.9	38.9	85.4	37.7	84.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.2	22.1	19.6	DB	25.4	104.0	2.1	3.3	23.9	106.4	22.6	108.3	21.4	110.1	19.9	112.5
			WB	24.4	81.2	1.6	2.5	23.2	83.0	22.2	84.5	21.3	85.8	20.1	87.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.1	45.9	46.4	50.8	55.5	65.9	74.0	78.6	78.8	70.5	63.5	54.5	48.1	(6)
	DBStd	13.09	5.26	5.34	6.14	5.09	5.05	6.11	4.56	4.87	5.20	5.29	6.28	5.57	(7)
	HDD50	481	148	124	64	14	0	0	0	0	0	0	30	101	(8)
	HDD65	2841	593	520	443	286	49	6	0	0	11	91	317	525	(9)
	CDD50	4547	20	25	87	179	494	721	886	894	615	419	166	41	(10)
	CDD65	1433	0	0	2	2	79	278	421	429	175	45	2	0	(11)
	CDH74	14389	0	0	15	17	778	2987	4609	4484	1261	235	3	0	(12)
	CDH80	6393	0	0	4	1	194	1340	2243	2210	371	30	0	0	(13)
(14) Wind	WSAvg	8.6	9.4	9.5	8.9	8.6	8.4	8.9	9.4	8.6	8.2	7.2	7.6	8.8	(14)
(15) Precipitation	PrecAvg	18.1	1.5	1.2	1.5	1.7	1.3	1.3	0.7	1.0	2.0	1.7	2.2	2.0	(15)
	PrecMax	29.3	5.9	2.8	3.2	4.0	3.5	3.7	2.2	3.9	8.0	6.2	4.1	7.2	(16)
	PrecMin	11.3	0.2	0.2	0.0	0.4	0.0	0.0	0.1	0.0	0.5	0.0	0.3	0.1	(17)
	PrecStd	3.9	1.4	0.7	0.9	0.8	0.8	1.0	0.6	1.1	1.6	1.4	1.1	1.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.4	66.2	75.1	76.7	88.7	97.7	101.7	101.7	91.3	83.8	73.2	65.8	(19)
		MCWB	56.6	54.6	59.7	61.1	68.0	73.4	71.5	73.3	71.2	68.7	62.4	57.8	(20)
	2%	DB	60.2	62.3	68.4	71.9	84.6	94.7	96.9	96.9	87.4	79.2	69.5	62.3	(21)
		MCWB	53.9	53.0	57.0	58.5	65.7	71.8	72.2	72.0	69.3	65.8	61.4	56.5	(22)
	5%	DB	57.1	59.3	64.8	69.0	82.0	91.3	93.5	93.6	84.3	76.6	66.5	59.1	(23)
		MCWB	51.9	51.8	55.3	57.7	64.8	70.3	71.4	71.6	68.3	65.0	59.7	54.0	(24)
	10%	DB	54.0	56.4	61.2	66.2	78.5	87.8	90.2	91.0	81.0	73.4	64.1	56.9	(25)
		MCWB	49.6	50.2	54.2	56.5	63.3	69.5	70.9	71.2	67.8	63.7	58.4	52.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.6	57.3	61.8	63.5	70.8	77.8	78.9	79.2	75.4	72.2	67.3	59.3	(27)
		MCDB	62.1	61.8	70.7	69.9	81.3	89.0	87.1	86.4	82.8	77.8	69.6	63.2	(28)
	2%	WB	54.9	55.0	58.9	61.4	68.6	75.4	76.6	77.1	73.3	69.7	62.9	57.2	(29)
		MCDB	58.7	59.9	66.2	67.8	78.7	87.1	86.8	85.2	80.0	74.6	66.9	61.0	(30)
	5%	WB	52.8	52.9	56.8	59.6	67.1	73.5	75.0	75.5	71.8	67.7	60.8	55.1	(31)
		MCDB	56.5	58.0	63.1	66.4	76.9	84.9	85.8	84.7	78.7	73.0	64.7	58.4	(32)
	10%	WB	50.7	51.0	54.9	57.7	65.5	71.8	73.6	74.1	70.2	65.8	59.2	53.2	(33)
		MCDB	53.3	55.4	60.4	64.1	74.9	82.9	84.6	84.7	77.2	70.8	62.8	56.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.1	16.7	18.8	19.5	22.3	23.5	23.2	23.0	20.1	18.8	15.2	13.5	(35)
		MCDBR	17.5	20.8	23.9	24.1	27.7	27.9	27.2	26.7	23.5	21.9	17.4	16.3	(36)
	5% WB	MCWBR	12.3	13.5	14.5	13.4	12.1	11.4	10.8	11.4	11.0	11.5	10.9	11.8	(37)
		MCWBR	15.1	18.4	21.4	19.9	23.7	24.5	23.8	24.7	20.3	19.2	14.5	13.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.346	0.373	0.408	0.467	0.463	0.456	0.452	0.453	0.439	0.399	0.373	0.347	(40)
		taud	2.416	2.310	2.208	2.045	2.125	2.187	2.208	2.209	2.239	2.342	2.362	2.414	(41)
	Ebn at Noon		252	261	264	256	260	262	261	257	252	248	238	240	(42)
		Edh at Noon	26	33	41	51	49	46	44	43	39	32	27	24	(43)
(44) All-Sky Solar Radiation	RadAvg		544	784	1189	1585	1945	2187	2247	1985	1420	993	630	488	(44)
	RadStd		69	83	119	128	137	111	118	133	86	89	55	66	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-180	+259	+121

Nomenclature: See separate page