

PONZA, Italy

WMO: 162800

Lat: 40.912N

Lon: 12.957E

Elev: 607

StdP: 14.38

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	41.0	43.2	25.8	20.2	45.1	30.0	24.6	46.4	37.5	51.4	33.2	52.3	14.5	40	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.2	86.0	77.9	84.2	77.1	82.6	76.1	80.6	84.0	79.1	82.2	77.8	80.9	6.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.6	157.3	83.0	78.2	149.8	81.6	76.9	143.1	80.3	44.8	84.2	43.1	82.4	41.8	80.9	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
31.1	26.5	22.6	DB	38.0	89.4	2.9	2.9	35.9	91.5	34.2	93.2	32.6	94.9	30.5	97.0
			WB	33.3	82.0	2.6	2.8	31.4	84.0	29.9	85.6	28.4	87.2	26.6	89.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.2	51.5	50.9	53.4	58.0	64.3	71.9	77.2	78.3	72.7	66.4	59.4	53.9	(6)
	DBStd	10.32	3.51	3.82	3.49	3.59	3.72	4.23	3.33	3.10	3.59	3.79	4.42	3.88	(7)
	HDD50	86	25	33	13	1	0	0	0	0	0	0	2	12	(8)
	HDD65	1992	419	393	360	214	58	2	0	0	1	29	172	344	(9)
	CDD50	4910	71	59	118	239	443	657	843	876	681	507	283	133	(10)
	CDD65	1343	0	0	0	2	36	209	378	411	232	72	3	0	(11)
	CDH74	6945	0	0	0	1	27	746	2538	2952	659	22	0	0	(12)
	CDH80	1104	0	0	0	0	0	81	427	561	35	0	0	0	(13)
(14) Wind	WSAvg	9.9	11.9	11.4	10.8	9.5	9.0	8.0	7.9	8.0	8.6	9.4	11.6	12.1	(14)
(15) Precipitation	PrecAvg	24.8	3.2	2.3	2.2	1.5	0.8	0.4	0.2	0.9	1.9	4.0	3.6	3.7	(15)
	PrecMax	39.1	6.7	5.6	5.2	3.4	3.3	1.2	1.3	4.2	6.0	13.9	6.1	10.4	(16)
	PrecMin	10.4	0.1	0.3	0.4	0.2	0.0	0.0	0.0	0.0	0.0	0.5	0.0	0.9	(17)
	PrecStd	7.0	2.0	1.6	1.5	1.0	0.7	0.4	0.4	1.0	1.7	3.3	1.9	2.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.3	59.2	62.8	70.8	76.9	85.4	87.7	89.6	83.2	76.5	69.9	62.6	(19)
		MCWB	56.5	54.7	57.1	63.9	69.1	74.4	78.5	78.2	75.2	71.1	66.2	59.5	(20)
	2%	DB	57.6	57.4	60.4	66.9	74.0	82.3	85.6	86.5	80.9	73.9	67.6	60.8	(21)
		MCWB	55.0	54.3	55.7	60.8	67.2	74.0	77.3	79.0	74.5	69.3	64.6	58.4	(22)
	5%	DB	56.8	56.2	59.0	64.6	71.7	80.1	84.0	84.6	79.1	72.2	66.1	59.6	(23)
		MCWB	54.2	53.3	54.7	59.5	65.8	73.2	77.1	77.8	73.6	68.0	63.3	57.2	(24)
	10%	DB	55.6	55.3	57.5	62.7	69.7	78.2	82.4	83.1	77.4	70.8	64.5	58.8	(25)
		MCWB	53.0	52.5	54.0	58.4	64.4	72.2	76.3	76.8	72.8	67.0	61.6	56.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.6	56.6	58.9	65.6	72.0	79.1	82.2	83.5	78.1	72.9	67.4	60.4	(27)
		MCDB	59.0	57.9	61.2	69.1	74.7	82.1	85.3	86.6	80.9	75.1	68.8	61.3	(28)
	2%	WB	55.8	55.2	57.0	62.2	69.1	76.8	80.4	81.3	76.5	70.5	65.1	59.0	(29)
		MCDB	57.2	56.8	59.1	65.3	72.5	80.1	83.5	84.7	79.2	72.8	67.1	60.3	(30)
	5%	WB	54.7	54.0	55.8	60.5	67.0	75.1	79.1	79.6	75.2	69.2	63.6	57.7	(31)
		MCDB	56.3	55.7	57.7	63.6	70.4	78.5	82.1	82.9	77.7	71.3	65.5	59.3	(32)
	10%	WB	53.6	53.1	54.9	59.0	65.4	73.4	77.8	78.2	74.0	68.0	62.1	56.6	(33)
		MCDB	55.3	54.9	56.8	61.6	68.6	76.7	80.8	81.3	76.6	70.0	64.0	58.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	5.3	6.1	6.9	7.6	8.4	8.6	8.2	7.1	6.0	5.0	4.5	(35)
		MCDBR	5.0	5.9	7.4	9.3	9.6	10.3	9.8	9.9	8.2	7.3	5.6	4.8	(36)
	5% WB	MCWBR	4.9	5.2	6.3	7.7	8.1	9.1	8.5	8.1	6.3	5.9	5.0	4.9	(37)
		MCWBR	4.6	5.6	6.8	8.7	8.9	9.5	9.1	9.3	7.6	6.8	5.2	4.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.336	0.357	0.390	0.425	0.425	0.418	0.416	0.417	0.409	0.389	0.368	0.339	(40)
		taud	2.494	2.424	2.335	2.249	2.296	2.362	2.373	2.379	2.395	2.432	2.417	2.480	(41)
	Ebn at Noon		259	270	272	269	271	272	272	269	263	255	243	247	(42)
		Edh at Noon	24	30	36	42	41	39	38	36	34	29	26	23	(43)
(44) All-Sky Solar Radiation	RadAvg		594	879	1292	1725	2101	2379	2398	2092	1551	1076	675	530	(44)
	RadStd		55	82	136	103	145	89	101	114	62	89	55	54	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	+0.74	N/A	N/A	+0.95	N/A	N/A	N/A	-142	+236	+122

Nomenclature: See separate page