

CAPRI, Italy

WMO: 162940

Lat: 40.559N

Lon: 14.201E

Elev: 528

StdP: 14.42

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	38.9	41.2	17.4	13.5	44.0	22.5	17.3	46.0	21.8	50.2	19.0	50.0	6.8	60	0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.2	91.8	76.2	89.7	75.6	87.6	74.8	81.4	87.9	79.2	85.4	77.7	83.7	4.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.3	155.2	85.9	77.3	144.9	83.6	75.6	136.6	81.8	45.5	87.9	43.2	85.7	41.4	83.8	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.1	14.4	11.9	DB	35.0	94.9	2.3	4.1	33.3	97.9	32.0	100.2	30.6	102.5	28.9	105.5
			WB	30.0	83.9	2.6	2.9	28.1	86.0	26.6	87.7	25.2	89.3	23.3	91.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.2	51.5	51.7	55.2	61.1	67.6	75.1	80.4	81.3	74.9	67.9	60.3	54.0	(6)
	DBStd	11.44	4.32	4.81	4.54	4.34	4.97	5.09	3.33	3.29	4.42	4.44	5.12	4.44	(7)
	HDD50	102	34	35	12	1	0	0	0	0	0	0	4	16	(8)
	HDD65	1777	419	372	306	131	28	2	0	1	22	153	343		(9)
	CDD50	5632	80	83	172	334	546	752	942	970	747	555	312	139	(10)
	CDD65	1833	0	0	1	14	109	305	477	505	298	112	12	0	(11)
	CDH74	12349	0	0	1	38	348	1845	4017	4438	1474	177	11	0	(12)
	CDH80	3855	0	0	0	6	64	501	1351	1580	338	15	0	0	(13)
(14) Wind	WSAvg	4.2	5.3	5.4	5.0	4.1	3.8	3.1	3.1	3.0	3.5	3.6	5.1	5.1	(14)
(15) Precipitation	PrecAvg	28.3	3.1	2.4	2.6	2.5	1.1	0.9	0.6	0.9	2.7	3.8	4.2	3.5	(15)
	PrecMax	45.1	10.4	6.4	9.1	5.4	3.3	2.4	3.0	5.3	5.8	13.1	11.3	6.6	(16)
	PrecMin	18.2	0.4	0.2	0.0	0.9	0.2	0.1	0.0	0.0	0.3	0.1	1.1	0.0	(17)
	PrecStd	8.1	2.2	1.8	1.9	1.1	0.7	0.7	0.7	1.3	1.3	2.9	2.2	1.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.4	66.4	70.2	78.8	86.0	92.8	94.9	95.3	90.7	82.1	75.3	65.9	(19)
		MCWB	55.9	54.1	58.4	62.8	64.7	74.5	76.0	77.7	73.7	69.7	62.6	58.4	(20)
	2%	DB	60.0	61.1	66.4	73.2	80.8	88.6	91.7	92.1	86.4	78.4	71.1	62.7	(21)
		MCWB	55.1	54.2	56.5	60.8	66.2	75.8	76.3	77.1	72.7	68.1	63.5	56.9	(22)
	5%	DB	58.6	58.9	63.1	69.9	77.3	85.5	89.5	89.8	83.9	75.4	68.1	60.9	(23)
		MCWB	54.0	53.0	55.3	59.4	65.4	72.9	75.9	75.5	70.9	66.7	62.5	56.3	(24)
	10%	DB	56.9	57.1	60.7	67.8	75.0	82.5	87.1	87.7	80.8	73.3	66.2	59.2	(25)
		MCWB	52.6	52.5	53.8	58.6	64.7	71.5	74.7	75.3	70.1	65.9	60.9	54.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.0	58.2	62.1	66.6	72.6	83.5	83.6	84.9	79.1	74.4	68.0	60.3	(27)
		MCDB	60.2	62.0	66.5	72.0	78.5	89.1	90.4	91.4	86.0	79.0	70.6	63.2	(28)
	2%	WB	56.3	56.0	58.9	63.8	70.1	79.1	80.5	81.7	76.5	71.1	65.2	58.5	(29)
		MCDB	58.9	59.2	63.7	69.7	75.7	84.8	87.5	88.2	82.4	75.3	68.2	61.3	(30)
	5%	WB	54.9	54.7	57.1	61.9	68.4	76.1	78.7	79.6	74.6	69.3	63.3	57.1	(31)
		MCDB	57.5	57.8	61.0	67.7	74.0	81.8	85.1	85.8	79.8	73.1	66.8	60.0	(32)
	10%	WB	53.6	53.3	55.5	60.3	66.6	74.0	77.1	78.1	72.9	67.6	61.7	55.6	(33)
		MCDB	56.2	56.4	59.0	65.6	72.1	79.8	83.3	83.9	78.0	71.4	65.3	58.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	8.3	9.8	11.2	12.3	12.8	14.1	14.2	12.5	9.9	7.5	6.5	(35)
		MCDBR	8.3	10.1	13.1	14.1	15.5	15.8	17.1	16.7	15.5	12.5	8.8	7.6	(36)
	5% WB	MCWBR	7.0	7.5	8.9	9.5	9.3	11.4	10.8	10.3	8.8	7.9	6.6	6.4	(37)
		MCWBR	7.0	8.6	11.6	12.3	13.3	14.0	15.3	15.0	13.4	11.1	7.8	6.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.337	0.358	0.394	0.435	0.430	0.425	0.424	0.424	0.416	0.387	0.367	0.340	(40)
		taud	2.494	2.421	2.319	2.211	2.279	2.337	2.352	2.354	2.370	2.437	2.431	2.484	(41)
	Ebn at Noon		260	270	271	266	270	271	270	267	261	256	245	248	(42)
		Edh at Noon	24	30	37	44	42	40	39	38	35	29	26	23	(43)
(44) All-Sky Solar Radiation	RadAvg		590	861	1277	1714	2112	2404	2418	2122	1568	1090	681	533	(44)
	RadStd		54	96	142	118	125	91	114	120	56	94	58	54	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	N/A	-137	+243	+126

Nomenclature: See separate page