

CAPO PALINURO, Italy

WMO: 163100

Lat: 40.0252N

Lon: 15.2808E

Elev: 607

StdP: 14.38

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	37.3	39.9	8.9	8.9	43.9	14.7	11.8	45.0	33.1	52.4	29.0	51.2	9.6	20	0.382

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.1	88.0	75.8	86.2	75.7	84.6	74.9	81.1	85.0	79.3	83.6	77.8	82.3	6.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.0	159.3	84.4	78.1	149.0	82.8	76.4	141.0	81.5	45.3	85.2	43.4	83.8	41.8	82.5	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	21.3	17.9	34.3	92.6	2.8	3.2	32.2	94.9	30.6	96.8	29.0	98.6	26.9	100.9
			27.5	82.9	2.9	2.7	25.4	84.8	23.7	86.3	22.1	87.8	20.0	89.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.6	50.8	50.6	54.1	59.4	66.0	72.9	77.9	78.8	72.6	66.9	59.4	53.5	(6)
	DBStd	10.87	4.66	4.64	4.62	4.53	4.65	4.72	3.24	3.25	4.49	4.49	5.44	4.91	(7)
	HDD50	137	47	45	17	1	0	0	0	0	0	0	4	23	(8)
	HDD65	1973	440	403	338	177	43	4	0	0	3	32	176	357	(9)
	CDD50	5119	72	62	145	282	495	686	864	892	678	524	288	131	(10)
	CDD65	1477	0	0	1	8	73	239	399	427	230	90	10	0	(11)
	CDH74	9487	0	0	1	18	200	1298	3183	3590	1076	112	9	0	(12)
	CDH80	2249	0	0	0	1	23	235	815	1005	166	4	0	0	(13)
(14) Wind	WSAvg	6.9	8.1	8.4	7.9	7.3	6.1	5.6	5.6	5.4	6.1	6.3	8.3	8.3	(14)
(15) Precipitation	PrecAvg	30.2	3.5	3.1	2.9	2.4	1.4	0.8	0.6	0.8	2.4	3.5	4.4	4.2	(15)
	PrecMax	47.4	7.3	9.1	10.3	5.9	4.7	2.5	2.5	2.6	6.1	9.1	10.4	12.3	(16)
	PrecMin	13.5	0.0	0.4	0.4	0.5	0.1	0.0	0.0	0.0	0.0	0.0	0.6	0.8	(17)
	PrecStd	7.9	1.9	2.2	2.1	1.5	1.1	0.7	0.6	0.8	1.7	2.4	2.4	2.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.7	63.9	70.4	76.6	82.9	89.2	90.8	91.5	86.8	79.3	74.5	66.8	(19)
		MCWB	54.1	52.8	53.9	58.7	64.5	70.6	72.0	70.5	72.6	66.2	58.3	56.9	(20)
	2%	DB	60.4	60.4	65.1	71.6	78.6	85.3	87.9	88.1	84.1	76.8	71.0	63.5	(21)
		MCWB	53.3	53.5	55.3	58.3	63.9	71.9	77.0	76.5	72.1	67.2	60.7	56.7	(22)
	5%	DB	58.7	58.6	62.6	68.5	75.8	82.6	86.0	86.4	81.9	75.0	68.6	61.5	(23)
		MCWB	52.8	52.8	55.4	58.5	65.0	72.1	76.1	76.6	72.0	66.8	60.5	55.8	(24)
	10%	DB	56.9	56.9	60.6	66.2	73.6	80.4	84.2	84.9	79.8	73.3	66.5	59.5	(25)
		MCWB	52.1	51.8	54.6	57.6	64.7	71.7	75.2	76.0	71.2	66.2	60.1	54.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.5	58.3	61.0	65.9	73.1	81.7	83.4	83.5	79.3	72.9	66.5	61.7	(27)
		MCDB	60.1	60.8	63.7	69.9	76.9	84.2	87.2	86.9	83.1	76.5	69.4	64.1	(28)
	2%	WB	55.7	56.0	59.0	63.5	70.5	77.8	80.9	81.4	77.0	70.8	64.7	58.7	(29)
		MCDB	58.3	58.6	62.0	67.7	74.4	81.6	84.9	85.3	81.0	74.4	68.0	61.5	(30)
	5%	WB	54.3	54.2	57.2	61.6	68.7	75.6	79.1	79.7	75.1	69.2	63.0	57.2	(31)
		MCDB	57.0	57.0	60.5	65.8	72.8	79.6	83.5	84.0	79.4	73.0	66.5	60.0	(32)
	10%	WB	53.0	52.8	55.6	60.0	66.8	73.8	77.6	78.1	73.3	67.7	61.2	55.7	(33)
		MCDB	55.8	55.6	58.8	64.0	71.0	78.2	82.1	82.7	77.8	71.7	65.0	58.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	9.3	10.0	10.6	11.2	12.0	12.2	12.1	11.5	10.0	9.1	8.3	(35)
		MCDBR	8.9	10.1	11.8	12.6	13.2	13.1	13.2	13.0	12.1	10.6	9.9	8.8	(36)
	5% WB	MCWBR	8.1	8.9	10.1	10.5	10.6	10.8	11.5	11.0	9.8	9.0	8.9	7.9	(37)
		MCWBR	7.7	8.9	10.4	10.9	11.7	11.5	12.0	11.7	11.3	9.5	8.8	7.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.334	0.356	0.395	0.442	0.436	0.428	0.424	0.426	0.420	0.388	0.363	0.338	(40)
		taud	2.487	2.413	2.299	2.166	2.239	2.307	2.332	2.326	2.339	2.415	2.432	2.481	(41)
	Ebn at Noon		263	272	271	265	269	270	270	266	260	257	248	251	(42)
		Edh at Noon	25	30	38	46	44	41	40	39	36	30	26	23	(43)
(44) All-Sky Solar Radiation	RadAvg		600	857	1263	1667	2033	2321	2374	2100	1535	1082	695	548	(44)
	RadStd		61	89	131	126	122	109	114	116	69	93	65	60	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+1.01	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-139	+234	+121

Nomenclature: See separate page