

CAPO PALINURO, Italy

WMO: 163100

Lat: 40.0252N

Lon: 15.2808E

Elev: 185

StdP: 99.12

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.0	4.4	-12.8	1.3	6.6	-9.6	1.7	7.2	14.8	11.3	13.0	10.7	4.3	20	0.382

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	31.1	24.4	30.1	24.3	29.2	23.8	27.3	29.5	26.3	28.6	25.5	27.9	2.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.8	29.1	25.6	21.3	28.2	24.7	20.1	27.5	87.6	29.6	83.0	28.8	79.3	28.1	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	9.5	8.0	1.3	33.7	1.6	1.8	0.1	34.9	-0.8	36.0	-1.7	37.0	-2.8	38.3		
(5)			-2.5	28.3	1.6	1.5	-3.7	29.3	-4.6	30.2	-5.5	31.0	-6.7	32.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.6	10.4	10.3	12.3	15.2	18.9	22.7	25.5	26.0	22.6	19.4	15.2	11.9		
	DBStd	6.04	2.59	2.58	2.57	2.51	2.58	2.62	1.80	1.80	2.49	2.49	3.02	2.73		
	HDD10.0	76	26	25	9	1	0	0	0	0	0	0	2	13		
	HDD18.3	1096	244	224	188	98	24	2	0	0	2	18	98	198		
	CDD10.0	2844	40	34	81	157	275	381	480	496	377	291	160	73		
	CDD18.3	821	0	0	1	4	41	133	222	237	128	50	6	0		
	CDH23.3	5271	0	0	1	10	111	721	1768	1994	598	62	5	0		
	CDH26.7	1249	0	0	0	1	13	131	453	558	92	2	0	0		
(14) Wind	WSAvg	3.1	3.6	3.8	3.5	3.3	2.7	2.5	2.5	2.4	2.7	2.8	3.7	3.7		
(15) Precipitation	PrecAvg	766	90	80	73	62	36	20	14	20	61	88	112	107		
	PrecMax	1205	185	230	261	150	120	63	64	66	156	231	264	312		
	PrecMin	344	1	9	10	12	2	0	0	0	0	0	16	21		
	PrecStd	201	48	55	54	39	29	18	15	20	44	60	62	68		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	17.7	21.3	24.8	28.3	31.8	32.7	33.1	30.5	26.3	23.6	19.3		
		MCWB	12.3	11.6	12.2	14.8	18.1	21.5	22.2	21.4	22.5	19.0	14.6	13.8		
	2%	DB	15.8	15.8	18.4	22.0	25.9	29.6	31.0	31.1	28.9	24.9	21.7	17.5		
		MCWB	11.8	11.9	12.9	14.6	17.7	22.2	25.0	24.7	22.3	19.5	15.9	13.7		
	5%	DB	14.8	14.8	17.0	20.3	24.4	28.1	30.0	30.2	27.7	23.9	20.3	16.4		
		MCWB	11.6	11.5	13.0	14.7	18.3	22.3	24.5	24.8	22.2	19.3	15.9	13.2		
	10%	DB	13.8	13.8	15.9	19.0	23.1	26.9	29.0	29.4	26.6	22.9	19.2	15.3		
		MCWB	11.2	11.0	12.6	14.2	18.2	22.1	24.0	24.5	21.8	19.0	15.6	12.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	14.6	16.1	18.8	22.8	27.6	28.6	28.6	26.3	22.7	19.2	16.5		
		MCDB	15.6	16.0	17.6	21.0	25.0	29.0	30.7	30.5	28.4	24.7	20.8	17.8		
	2%	WB	13.2	13.3	15.0	17.5	21.4	25.4	27.2	27.5	25.0	21.6	18.2	14.8		
		MCDB	14.6	14.8	16.7	19.9	23.6	27.6	29.4	29.6	27.2	23.6	20.0	16.4		
	5%	WB	12.4	12.4	14.0	16.4	20.4	24.2	26.2	26.5	23.9	20.7	17.2	14.0		
		MCDB	13.9	13.9	15.8	18.8	22.6	26.4	28.6	28.9	26.3	22.8	19.2	15.6		
	10%	WB	11.7	11.6	13.1	15.6	19.3	23.2	25.3	25.6	22.9	19.9	16.2	13.2		
		MCDB	13.2	13.1	14.9	17.8	21.7	25.7	27.8	28.2	25.5	22.0	18.3	14.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	5.1	5.5	5.9	6.2	6.7	6.8	6.7	6.4	5.6	5.1	4.6		
		MCDBR	5.0	5.6	6.5	7.0	7.3	7.3	7.3	7.2	6.7	5.9	5.5	4.9		
	5% WB	MCWBR	4.5	4.9	5.6	5.8	5.9	6.0	6.4	6.1	5.4	5.0	4.9	4.4		
		MCWBR	4.3	5.0	5.8	6.1	6.5	6.4	6.6	6.5	6.3	5.3	4.9	4.2		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.356	0.395	0.442	0.436	0.428	0.424	0.426	0.420	0.388	0.363	0.338		
	taud		2.487	2.413	2.299	2.166	2.239	2.307	2.332	2.326	2.339	2.415	2.432	2.481		
	Ebn at Noon		828	857	855	835	847	851	851	840	820	809	781	791		
	Edh at Noon		78	96	119	145	138	129	125	122	114	95	82	73		
(44) All-Sky Solar Radiation	RadAvg		1.89	2.70	3.98	5.25	6.41	7.32	7.48	6.62	4.84	3.41	2.19	1.73		
	RadStd		0.19	0.28	0.41	0.40	0.38	0.34	0.36	0.37	0.22	0.29	0.20	0.19		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-77	+130	+67

Nomenclature: See separate page