

BRINDISI, Italy

WMO: 163200

Lat: 40.6578N

Lon: 17.9517E

Elev: 14

StdP: 101.15

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.0	4.2	-5.2	2.4	7.3	-3.0	2.9	7.4	13.9	10.3	12.5	10.1	3.6	230	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	32.9	23.8	31.2	24.3	30.0	24.3	27.1	29.9	26.3	29.2	25.5	28.5	4.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.6	29.4	25.2	20.4	28.5	24.5	19.5	27.9	85.6	30.3	82.0	29.6	78.4	28.6	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.1	10.4	9.3	DB	0.4	37.3	1.3	2.9	-0.5	39.4	-1.2	41.1	-2.0	42.7	-2.9	44.8	
			WB	-1.2	28.4	1.1	1.4	-2.0	29.4	-2.6	30.2	-3.2	31.0	-4.0	32.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	9.9	10.2	12.2	14.7	18.8	23.2	25.8	26.1	22.5	18.5	14.7	11.2
	DBStd	6.26	2.52	2.70	2.48	2.30	2.50	2.64	2.06	1.94	2.57	2.51	2.78	2.62
	HDD10.0	88	32	27	9	1	0	0	0	0	0	0	2	17
	HDD18.3	1179	261	227	192	111	24	1	0	0	2	27	113	222
	CDD10.0	2772	29	34	76	142	273	396	489	498	375	265	142	53
	CDD18.3	823	0	0	1	2	39	147	231	239	127	34	3	0
	CDH23.3	6449	0	0	1	5	156	1001	2192	2307	712	74	2	0
	CDH26.7	1806	0	0	0	0	24	249	676	708	144	6	0	0
Wind	WSAvg	4.1	4.3	4.7	4.3	4.0	3.8	3.8	4.0	3.8	3.7	3.7	4.1	4.5
Precipitation	PrecAvg	601	65	67	68	42	31	19	12	26	54	73	76	71
	PrecMax	893	143	170	185	119	80	71	50	104	170	176	274	183
	PrecMin	293	10	3	4	0	1	0	0	0	1	2	7	3
	PrecStd	131	38	43	47	26	21	18	13	30	44	48	62	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.1	19.2	21.2	24.0	29.2	33.8	36.0	35.1	32.3	27.2	23.1	19.1
		MCWB	14.7	15.5	14.6	16.3	19.5	21.8	23.1	23.9	23.9	20.9	18.7	15.9
	2%	DB	16.2	17.1	18.9	21.8	26.6	30.9	32.9	32.9	30.0	25.1	21.2	17.4
		MCWB	13.6	14.0	14.2	16.0	19.2	22.2	23.6	24.7	23.7	20.9	17.9	15.1
	5%	DB	15.0	15.8	17.4	20.1	25.0	29.1	31.1	31.1	28.1	23.9	20.0	16.2
		MCWB	12.8	13.2	13.9	15.4	18.8	22.2	24.5	25.0	22.8	20.2	17.4	14.1
	10%	DB	14.0	14.4	16.1	18.9	23.6	27.9	29.9	30.0	26.9	22.8	18.9	15.2
		MCWB	12.0	12.1	13.3	14.9	18.9	22.5	24.4	25.0	22.4	19.6	16.6	13.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.6	17.3	16.7	19.0	23.1	26.5	28.2	28.7	26.7	23.0	20.5	17.1
		MCDB	17.2	18.2	19.0	21.4	25.7	28.8	30.7	31.5	30.2	25.1	21.9	18.3
	2%	WB	14.2	14.7	15.4	17.4	21.6	25.3	27.0	27.3	25.2	21.7	19.0	15.6
		MCDB	15.6	16.3	17.4	19.9	24.3	28.0	29.8	30.1	28.4	24.0	20.6	17.0
	5%	WB	13.2	13.4	14.6	16.4	20.6	24.3	26.2	26.5	24.1	20.8	17.8	14.6
		MCDB	14.7	15.2	16.6	18.7	23.2	27.1	29.1	29.5	26.8	23.0	19.4	16.1
	10%	WB	12.2	12.5	13.8	15.6	19.6	23.4	25.4	25.7	23.0	19.9	16.7	13.6
		MCDB	13.8	14.2	15.7	17.9	22.2	26.4	28.4	28.7	25.8	22.1	18.4	15.1
Mean Daily Temperature Range	5% DB	MDBR	5.9	6.2	6.6	6.9	7.3	7.1	7.0	6.9	6.8	6.3	6.2	5.8
		MCDBR	7.4	7.9	8.5	9.0	9.8	9.6	9.7	9.3	8.5	7.8	7.1	6.8
		MCWBR	5.8	6.0	6.0	5.8	5.8	5.8	6.7	6.6	6.0	5.5	5.3	5.5
	5% WB	MCDBR	6.8	7.5	7.4	7.6	7.9	7.5	7.6	7.6	7.8	7.2	6.4	6.2
		MCWBR	5.9	6.2	5.9	5.8	5.9	6.0	6.4	6.4	6.4	5.7	5.4	5.4
Clear-Sky Solar Irradiance	taub	0.345	0.368	0.405	0.450	0.441	0.427	0.422	0.433	0.424	0.400	0.373	0.349	
	taud	2.454	2.367	2.262	2.145	2.233	2.317	2.335	2.305	2.331	2.373	2.405	2.446	
	Ebn at Noon	806	837	841	825	841	852	852	832	813	790	762	768	
	Edh at Noon	80	100	123	148	138	127	124	124	114	98	83	75	
All-Sky Solar Radiation	RadAvg	1.86	2.63	3.96	5.23	6.41	7.24	7.30	6.40	4.73	3.29	2.12	1.66	
	RadStd	0.17	0.26	0.38	0.38	0.33	0.33	0.24	0.30	0.28	0.26	0.17	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	+0.32	N/A	N/A	N/A	N/A	N/A	N/A	-67	+92	N/A

Nomenclature: See separate page