

LECCE, Italy

WMO: 163320

Lat: 40.2383N

Lon: 18.1386E

Elev: 48

StdP: 100.76

Time Zone: 1.00 (EUC)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.6	0.9	-5.1	2.5	3.8	-3.1	2.9	3.4	14.0	7.9	12.4	8.5	2.5	320	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.6	35.8	23.2	34.2	23.0	32.9	22.9	26.1	31.3	25.4	30.5	24.6	29.7	4.7	0

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.9	20.1	28.6	24.0	19.0	27.8	23.1	18.0	27.1	81.4	31.2	77.9	30.4	74.8	29.9	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.4	11.4	9.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB												
			WB	-3.2	27.5	1.8	1.3	-4.5	28.4	-5.5	29.1	-6.5	29.9	-7.8	30.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	8.3	9.1	11.5	14.3	18.1	23.8	25.8	26.1	22.2	18.4	13.6	9.2
	DBStd	6.93	3.05	3.16	2.60	2.56	3.04	2.93	2.14	2.17	2.42	2.77	3.24	2.90
	HDD10.0	189	70	48	15	1	0	0	0	0	0	5	50	
	HDD18.3	1411	313	258	211	122	42	1	0	2	33	147	282	
	CDD10.0	2651	16	23	62	131	250	414	489	501	366	260	113	26
	CDD18.3	831	0	0	0	3	33	166	231	242	117	34	4	0
	CDH23.3	8675	0	0	0	34	329	1826	2696	2771	881	133	6	0
	CDH26.7	3831	0	0	0	4	77	809	1317	1379	234	11	0	0
Wind	WSAvg	3.8	3.5	4.4	4.3	4.0	3.8	3.7	4.0	3.6	3.3	3.1	3.8	3.7
Precipitation	PrecAvg	662	75	54	70	51	28	21	19	32	59	81	88	85
	PrecMax	1134	239	122	168	274	88	86	115	93	196	183	279	207
	PrecMin	292	6	11	9	5	1	0	0	0	14	6	3	37
	PrecStd	216	54	29	45	58	24	25	29	31	50	56	80	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	18.8	21.2	27.0	31.1	37.0	38.0	38.0	32.5	28.0	24.1	18.1
		MCWB	14.4	15.2	15.1	18.2	19.5	21.9	21.6	24.6	22.9	20.5	19.2	15.7
	2%	DB	15.3	17.0	19.3	23.9	28.9	34.8	35.7	35.8	30.8	26.0	21.9	17.0
		MCWB	13.3	13.9	14.5	16.7	19.6	22.1	22.4	24.4	22.9	20.6	19.8	15.3
	5%	DB	14.5	15.7	18.0	21.9	26.9	32.8	34.1	34.1	29.2	24.9	20.2	15.9
		MCWB	12.9	13.3	13.7	16.0	19.2	21.8	22.5	23.9	22.3	20.7	17.8	14.0
	10%	DB	13.6	14.8	16.9	20.1	25.0	31.0	32.8	32.9	28.1	23.6	19.0	14.8
		MCWB	12.0	12.6	13.4	15.2	18.0	21.3	22.6	23.7	21.9	20.2	17.0	13.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	16.1	16.9	19.4	23.4	25.7	26.3	27.7	26.1	24.0	21.1	16.5
		MCDB	16.3	17.6	19.4	24.4	27.8	31.3	31.8	32.7	29.4	25.5	22.6	17.7
	2%	WB	14.1	14.8	15.7	17.9	21.4	24.6	25.5	26.6	25.0	22.5	19.8	15.5
		MCDB	15.0	16.3	17.8	22.5	25.9	30.2	30.9	31.8	28.7	24.5	21.4	16.7
	5%	WB	13.2	13.8	14.7	16.8	20.3	23.6	24.7	25.8	24.0	21.4	18.5	14.5
		MCDB	14.3	15.3	16.7	20.4	24.6	29.3	30.3	31.2	27.3	23.8	20.1	15.6
	10%	WB	12.2	12.9	13.9	15.8	19.1	22.7	23.9	25.0	23.1	20.5	17.2	13.2
		MCDB	13.5	14.3	16.0	19.2	23.5	28.3	29.5	30.3	26.2	22.8	18.9	14.5
Mean Daily Temperature Range	5% DB	MDBR	8.5	8.7	9.4	10.1	11.2	12.4	12.1	12.6	10.8	9.2	8.4	8.2
		MCDBR	8.9	9.5	11.1	13.5	13.9	15.1	15.4	15.0	12.0	10.1	8.9	8.5
		MCWBR	7.2	7.1	7.3	7.9	6.6	6.0	6.1	6.4	6.3	6.2	6.4	6.8
	5% WB	MCDBR	7.7	7.9	9.4	11.6	11.9	12.6	12.3	12.6	10.6	8.8	8.0	7.5
		MCWBR	6.7	6.4	6.8	7.4	6.7	6.1	5.9	6.2	6.2	6.2	6.3	6.5
Clear-Sky Solar Irradiance	taub	0.343	0.365	0.402	0.446	0.437	0.423	0.418	0.430	0.422	0.398	0.371	0.348	
	taud	2.461	2.379	2.274	2.154	2.243	2.325	2.345	2.313	2.336	2.380	2.413	2.453	
	Ebn at Noon	813	843	846	830	845	856	856	836	817	795	769	775	
	Edh at Noon	80	99	122	147	137	127	123	124	114	98	83	75	
All-Sky Solar Radiation	RadAvg	1.90	2.70	4.03	5.29	6.47	7.32	7.35	6.45	4.81	3.34	2.16	1.70	
	RadStd	0.17	0.26	0.37	0.38	0.30	0.32	0.24	0.28	0.27	0.28	0.17	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	+0.34	N/A	N/A	N/A	N/A	N/A	N/A	-82	+127	N/A

Nomenclature: See separate page