

CROTONE, Italy

WMO: 163500

Lat: 38.997N

Lon: 17.080E

Elev: 159

StdP: 99.43

Time Zone: 1.00 (EUC)

Period: 86-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.8	3.0	-6.7	2.2	4.4	-4.1	2.7	5.9	15.3	8.4	14.1	7.3	7.5	0	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	34.1	21.4	32.8	21.1	31.3	20.6	24.2	29.5	23.4	28.7	22.6	28.0	4.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.8	17.9	26.5	21.9	16.8	25.9	20.9	15.9	25.7	73.7	29.4	70.5	28.5	67.5	28.1	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	10.6	9.3	-1.1	37.5	2.2	3.0	-2.7	39.6	-4.0	41.4	-5.2	43.0	-6.9	45.2		
(5)			-2.2	26.1	1.2	1.3	-3.1	27.1	-3.8	27.9	-4.5	28.6	-5.4	29.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	9.5	9.4	11.0	13.6	17.8	22.1	25.9	26.1	22.5	18.5	13.5	10.2	(6)
(7)		DBStd	6.61	2.47	2.75	2.97	2.01	2.87	2.92	2.40	2.29	2.38	2.41	2.81	2.84	(7)
(8)		HDD10.0	139	39	39	23	1	0	0	0	0	0	0	5	31	(8)
(9)		HDD18.3	1369	276	252	226	141	46	3	0	0	1	27	146	252	(9)
(10)		CDD10.0	2596	22	21	56	111	242	363	493	500	376	264	111	37	(10)
(11)		CDD18.3	784	0	0	0	0	29	117	235	242	127	33	2	0	(11)
(12)		CDH23.3	6751	0	0	0	1	163	944	2385	2446	743	68	1	0	(12)
(13)		CDH26.7	2508	0	0	0	0	19	283	1019	1002	178	7	0	0	(13)
(14)	Wind	WSAvg	3.7	4.2	4.7	4.1	3.8	3.2	3.2	3.1	3.2	3.9	3.9	4.2	(14)	
(15)	Precipitation	PrecAvg	928	114	88	82	59	43	26	22	72	141	128	127	(15)	
(16)		PrecMax	2042	243	194	177	110	74	70	61	79	116	1301	226	212	(16)
(17)		PrecMin	623	52	27	6	3	16	2	2	2	25	19	56	14	(17)
(18)		PrecStd	255	45	46	43	23	18	18	15	24	25	222	42	47	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.8	18.1	20.3	22.0	28.9	34.7	38.5	32.7	27.7	22.1	19.1	(19)	
(20)			MCWB	12.8	11.8	13.0	15.3	18.6	21.0	22.4	22.1	19.8	19.4	18.1	14.4	(20)
(21)		2%	DB	15.8	16.0	18.9	20.2	26.8	31.4	34.3	34.1	30.1	25.0	20.4	17.1	(21)
(22)			MCWB	12.2	11.5	13.1	14.5	18.2	19.8	21.5	21.4	19.8	19.0	17.1	14.2	(22)
(23)		5%	DB	14.6	14.8	17.1	19.2	25.1	29.5	32.8	32.8	28.8	23.8	19.2	15.9	(23)
(24)			MCWB	11.7	11.4	12.5	14.1	17.6	19.3	20.9	21.4	19.8	19.2	16.2	13.6	(24)
(25)		10%	DB	13.8	13.9	15.8	18.1	23.5	28.0	31.5	31.3	27.2	22.6	18.2	14.7	(25)
(26)			MCWB	11.3	11.0	12.2	13.7	16.9	18.9	20.6	21.0	19.8	18.6	15.4	12.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	13.8	15.2	17.1	20.9	23.0	25.4	25.7	23.6	22.3	20.0	16.0	(27)
(28)			MCD B	16.2	15.8	17.9	20.1	25.2	30.7	30.7	29.8	27.1	24.3	21.0	17.4	(28)
(29)		2%	WB	13.1	13.0	14.2	15.9	19.7	21.7	24.2	24.3	22.6	21.2	18.1	14.9	(29)
(30)			MCD B	15.0	14.5	16.7	18.7	24.2	27.8	30.5	28.8	25.9	23.3	19.6	16.5	(30)
(31)		5%	WB	12.3	12.1	13.5	15.0	18.8	20.9	23.4	23.6	21.8	20.3	16.8	14.0	(31)
(32)			MCD B	14.2	14.1	15.8	17.9	23.2	26.7	29.6	28.4	25.5	22.5	18.6	15.6	(32)
(33)		10%	WB	11.5	11.4	12.7	14.2	17.8	20.1	22.5	22.8	21.0	19.5	15.7	12.7	(33)
(34)			MCD B	13.4	13.4	15.0	16.9	22.2	25.6	28.5	28.3	25.1	21.9	17.9	14.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	6.5	7.1	7.8	8.8	9.8	9.5	8.2	6.8	6.6	6.4	(35)	
(36)			MCDBR	8.1	8.3	9.6	9.5	10.7	11.3	11.2	10.9	10.0	7.7	7.7	7.8	(36)
(37)			MCWBR	6.1	6.0	6.5	6.1	5.2	5.1	5.2	5.4	5.3	5.1	5.8	6.0	(37)
(38)		5% WB	MCDBR	6.9	7.0	7.9	8.1	9.6	10.1	9.9	9.4	8.2	6.9	6.6	6.9	(38)
(39)			MCWBR	5.7	5.7	6.0	6.0	5.5	5.5	5.7	5.6	5.3	5.1	5.5	5.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.345	0.369	0.408	0.447	0.441	0.423	0.421	0.431	0.430	0.404	0.375	0.351	(40)	
(41)		taud	2.439	2.351	2.240	2.144	2.218	2.313	2.333	2.305	2.298	2.342	2.384	2.426	(41)	
(42)		Ebn at Noon	821	845	845	832	844	857	856	838	813	795	774	781	(42)	
(43)		Edh at Noon	83	103	127	149	141	129	125	125	119	103	88	79	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.06	2.84	4.15	5.42	6.56	7.37	7.46	6.62	4.92	3.46	2.30	1.83	(44)	
(45)		RadStd	0.19	0.27	0.35	0.38	0.29	0.38	0.27	0.29	0.28	0.29	0.18	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		+0.26	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page