

SANTA MARIA DI LEUCA, Italy

WMO: 163600

Lat: 39.811N

Lon: 18.342E

Elev: 112

StdP: 99.99

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.2	4.7	-5.4	2.4	6.4	-3.3	2.9	7.2	13.6	11.1	12.4	11.0	5.9	20	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.7	32.1	22.0	30.9	22.2	29.8	21.9	26.0	28.6	25.2	27.9	24.5	27.4	4.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.3	20.7	27.7	24.4	19.6	27.1	23.5	18.6	26.6	81.4	28.6	77.8	28.0	74.7	27.4	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.5	10.1	9.0	0.7	34.9	1.9	2.0	-0.6	36.3	-1.7	37.5	-2.8	38.7	-4.2	40.2		
			-1.1	27.4	1.6	1.2	-2.2	28.2	-3.1	29.0	-4.0	29.6	-5.1	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	10.1	10.3	11.9	14.5	18.5	22.9	26.0	26.2	22.4	18.7	14.9	11.4
	DBStd	6.24	2.68	2.49	2.34	2.23	2.52	2.75	2.16	2.09	2.40	2.39	2.82	2.79
	HDD10.0	87	32	24	10	1	0	0	0	0	0	0	3	18
	HDD18.3	1169	257	224	198	116	28	1	0	0	1	25	105	214
	CDD10.0	2777	33	34	71	137	264	387	496	502	373	268	151	62
	CDD18.3	817	0	0	0	2	34	138	237	243	124	35	3	0
	CDH23.3	5773	0	0	0	2	74	789	2132	2219	534	23	0	0
	CDH26.7	1501	0	0	0	0	3	171	633	631	61	1	0	0
Wind	WSAvg	4.6	5.0	5.3	4.9	4.4	4.1	4.1	4.2	4.2	4.3	4.5	4.9	5.1
Precipitation	PrecAvg	662	75	61	71	38	25	17	18	24	49	101	105	96
	PrecMax	1116	289	174	226	121	87	78	113	106	128	386	323	240
	PrecMin	232	3	6	10	6	0	0	0	0	4	5	11	27
	PrecStd	208	59	46	52	26	18	21	25	30	38	80	90	54
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	16.2	18.3	22.8	27.1	32.0	34.1	34.3	30.0	25.3	21.5	17.2
		MCWB	13.1	12.6	13.1	15.6	18.6	20.2	21.5	22.6	20.8	20.8	18.9	15.2
	2%	DB	14.9	15.1	16.9	20.6	25.2	30.2	32.2	32.2	28.2	23.9	20.4	16.5
		MCWB	12.8	12.5	12.9	14.7	17.7	21.3	21.7	22.9	21.5	20.3	18.2	14.6
	5%	DB	14.2	14.2	15.8	19.0	23.9	28.7	31.0	30.9	27.0	22.9	19.6	15.9
		MCWB	12.3	12.2	12.7	13.8	18.1	20.9	22.0	22.8	22.1	19.6	17.5	13.9
	10%	DB	13.6	13.7	14.9	17.7	22.5	27.2	29.8	29.8	26.0	22.1	18.7	15.1
		MCWB	11.9	11.8	12.6	13.8	17.5	20.6	21.9	22.3	22.1	19.2	16.5	13.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	14.2	15.3	17.7	21.6	25.7	26.7	27.9	25.6	22.6	19.8	15.9
		MCDB	15.0	15.0	16.8	20.3	23.9	28.4	29.2	29.9	26.8	24.3	20.9	16.9
	2%	WB	13.3	13.3	14.2	16.2	20.2	24.4	25.6	26.5	24.6	21.4	18.7	15.0
		MCDB	14.3	14.4	15.7	18.5	23.0	27.2	28.6	28.9	26.2	23.1	20.0	16.1
	5%	WB	12.8	12.7	13.5	15.4	19.3	23.3	24.8	25.6	23.7	20.6	17.8	14.2
		MCDB	13.9	13.9	15.0	17.4	22.0	26.3	28.0	28.3	25.8	22.2	19.3	15.5
	10%	WB	12.1	12.1	12.9	14.7	18.5	22.3	24.1	24.8	22.8	19.8	16.8	13.6
		MCDB	13.4	13.4	14.4	16.6	21.3	25.4	27.5	27.7	25.1	21.5	18.4	15.0
Mean Daily Temperature Range	5% DB	MDBR	3.8	4.0	4.2	4.5	4.9	5.3	5.8	5.7	5.0	4.5	4.1	3.8
		MCDBR	3.8	4.3	5.1	6.6	6.7	7.2	7.1	7.2	5.6	4.9	4.1	3.7
		MCWBR	3.3	3.5	3.9	4.5	4.5	5.4	6.0	5.8	4.4	3.7	3.5	3.3
	5% WB	MCDBR	3.2	3.5	4.0	4.7	5.4	5.6	5.8	5.5	4.7	4.0	3.6	3.2
		MCWBR	3.3	3.3	3.8	3.9	4.3	5.0	5.7	5.5	4.4	3.9	3.4	3.2
Clear-Sky Solar Irradiance	taub	0.343	0.365	0.403	0.443	0.432	0.419	0.415	0.428	0.420	0.398	0.372	0.349	
	taud	2.471	2.392	2.284	2.179	2.270	2.351	2.369	2.333	2.354	2.386	2.417	2.456	
	Ebn at Noon	818	847	848	834	850	860	860	839	821	798	772	779	
	Edh at Noon	80	98	121	143	134	123	120	122	112	98	84	76	
All-Sky Solar Radiation	RadAvg	1.97	2.79	4.16	5.46	6.66	7.54	7.54	6.61	4.97	3.45	2.24	1.76	
	RadStd	0.17	0.26	0.36	0.40	0.27	0.32	0.26	0.28	0.26	0.30	0.17	0.22	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	+0.34	N/A	N/A	N/A	N/A	N/A	N/A	-82	+127	N/A

Nomenclature: See separate page