

COZZO SPADARO, Italy

WMO: 164800

Lat: 36.686N

Lon: 15.131E

Elev: 167

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	42.9	45.1	29.5	23.7	48.6	33.1	27.8	49.9	27.4	52.6	23.6	52.7	7.7	300	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.2	91.1	73.3	88.6	74.5	86.6	74.9	80.9	85.3	79.4	84.1	78.0	83.1	8.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.7	155.0	84.0	78.0	146.3	83.0	76.5	139.0	82.0	44.7	85.3	43.1	84.2	41.6	83.2	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	18.3	16.1	38.4	97.7	2.6	3.6	36.5	100.3	35.0	102.4	33.6	104.4	31.7	107.1
			34.6	84.2	2.2	1.9	33.0	85.5	31.8	86.6	30.6	87.7	29.0	89.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.4	54.8	54.3	56.8	60.7	67.2	74.4	79.9	81.1	76.0	70.2	63.4	57.5
	DBStd	10.07	3.56	3.82	3.49	3.11	3.56	4.36	3.19	2.99	3.42	3.62	3.98	3.78
	HDD50	20	7	9	2	0	0	0	0	0	0	0	0	2
	HDD65	1330	318	300	255	131	16	0	0	0	0	5	73	232
	CDD50	6020	154	130	213	321	532	733	928	963	780	627	403	236
	CDD65	1854	0	0	1	2	84	283	463	498	330	167	26	0
	CDH74	13991	0	0	3	3	178	1748	4485	5118	2076	371	9	0
	CDH80	3976	0	0	0	1	17	403	1472	1712	356	15	0	0
Wind	WSAvg	7.4	8.0	8.2	8.2	8.4	7.6	6.7	6.2	6.4	6.8	6.9	7.2	7.7
Precipitation	PrecAvg	14.3	2.4	1.8	1.3	0.7	0.4	0.1	0.0	0.2	1.0	3.3	1.5	2.6
	PrecMax	23.3	7.0	5.1	2.7	1.9	1.4	1.5	0.2	2.5	4.1	10.0	6.0	9.2
	PrecMin	6.0	0.5	0.2	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
	PrecStd	5.0	1.9	1.4	0.7	0.5	0.4	0.3	0.0	0.6	1.2	2.5	1.7	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.8	65.2	69.3	71.9	82.3	93.3	95.4	95.8	88.6	81.8	75.2	68.2
		MCWB	59.5	58.6	60.7	61.6	64.7	69.1	69.9	71.9	74.1	73.2	68.6	62.3
	2%	DB	63.0	63.1	65.8	69.6	78.2	87.2	91.1	91.0	85.7	79.5	73.1	66.3
		MCWB	58.3	57.6	58.7	60.7	65.6	70.7	73.1	74.2	75.2	72.8	68.1	61.3
	5%	DB	61.6	61.8	63.9	68.0	75.5	84.3	88.6	88.7	83.7	77.5	71.2	64.7
		MCWB	57.1	56.7	58.1	61.1	65.8	71.4	73.8	75.9	74.5	71.3	66.0	60.0
	10%	DB	60.4	60.4	62.5	66.4	73.6	82.0	86.3	87.0	82.0	76.0	69.6	63.4
		MCWB	56.1	55.7	57.4	60.4	65.6	70.7	74.0	76.3	73.9	70.3	64.7	58.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.7	61.6	62.9	65.6	72.6	78.7	83.1	83.2	80.0	76.5	71.4	64.7
		MCDB	63.8	63.3	67.7	69.3	76.5	83.1	86.6	86.6	83.9	79.9	73.5	66.8
	2%	WB	59.6	59.5	60.6	63.9	70.2	76.4	80.2	81.5	78.2	74.4	68.7	62.9
		MCDB	61.9	61.8	64.0	67.5	74.5	81.5	85.0	85.6	82.4	77.8	71.9	65.3
	5%	WB	58.2	57.8	59.3	62.7	68.6	74.8	78.6	80.2	76.8	72.7	67.0	61.0
		MCDB	60.6	60.6	62.6	66.3	73.0	80.2	83.7	84.8	81.3	76.3	70.2	63.9
	10%	WB	56.9	56.4	58.2	61.3	66.9	73.2	77.2	78.8	75.4	71.3	65.5	59.4
		MCDB	59.7	59.4	61.4	64.9	71.4	78.8	82.8	83.8	80.2	75.1	68.8	62.7
Mean Daily Temperature Range	5% DB	MDBR	9.3	10.1	10.4	10.4	11.0	11.4	12.2	11.2	10.4	9.4	9.3	9.3
		MCDBR	10.2	11.1	11.6	11.9	13.3	14.2	14.9	13.3	11.5	10.6	10.0	10.3
		MCWBR	8.1	8.6	8.4	8.5	8.6	9.5	10.6	10.1	8.3	8.2	7.8	7.8
	5% WB	MCDBR	9.0	9.8	10.2	10.2	11.1	11.6	12.1	11.2	10.4	9.4	8.8	9.1
		MCWBR	8.1	8.4	8.2	8.4	8.8	9.5	10.2	9.7	8.6	8.3	7.8	8.0
Clear-Sky Solar Irradiance	taub	0.354	0.376	0.425	0.464	0.466	0.447	0.454	0.459	0.452	0.424	0.388	0.358	
	taud	2.429	2.346	2.195	2.107	2.146	2.241	2.240	2.228	2.249	2.295	2.359	2.424	
	Ebn at Noon	263	270	265	261	262	266	263	259	254	250	247	252	
	Edh at Noon	28	34	43	49	49	44	44	43	40	35	30	26	
All-Sky Solar Radiation	RadAvg	781	1049	1465	1864	2192	2413	2448	2163	1663	1201	849	698	
	RadStd	55	89	89	102	102	94	47	88	73	74	62	50	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	+3.56	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	-0.49	-0.54	N/A	N/A	N/A	N/A

Nomenclature: See separate page