

COZZO SPADARO, Italy

WMO: 164800

Lat: 36.686N

Lon: 15.131E

Elev: 51

StdP: 100.71

Time Zone: 1.00 (EUC)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.0	7.3	-1.4	3.4	9.2	0.6	4.0	10.0	12.3	11.5	10.6	11.5	3.4	300	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.2	32.8	22.9	31.4	23.6	30.3	23.8	27.2	29.6	26.3	28.9	25.6	28.4	4.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	22.1	28.9	25.5	20.9	28.3	24.7	19.9	27.8	86.0	29.6	82.3	29.0	79.0	28.4	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.2	7.2	DB	3.6	36.5	1.4	2.0	2.5	37.9	1.7	39.1	0.9	40.2	-0.2	41.7	(4)
(5)			WB	1.4	29.0	1.2	1.1	0.6	29.7	-0.1	30.4	-0.8	31.0	-1.7	31.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.1	12.6	12.4	13.8	16.0	19.5	23.6	26.6	27.3	24.4	21.2	17.5	14.2	(6)	
	DBStd	5.60	1.98	2.12	1.94	1.73	1.98	2.42	1.77	1.66	1.90	2.01	2.21	2.10	(7)	
	HDD10.0	11	4	5	1	0	0	0	0	0	0	0	0	1	(8)	
	HDD18.3	739	177	167	142	73	9	0	0	0	0	3	41	129	(9)	
	CDD10.0	3344	86	72	118	178	296	407	516	535	433	348	224	131	(10)	
	CDD18.3	1030	0	0	1	1	47	157	257	277	183	93	14	0	(11)	
	CDH23.3	7773	0	0	2	2	99	971	2492	2843	1153	206	5	0	(12)	
	CDH26.7	2209	0	0	0	1	9	224	818	951	198	8	0	0	(13)	
(14) Wind	WSAvg	3.3	3.6	3.6	3.7	3.7	3.4	3.0	2.8	2.8	3.0	3.1	3.2	3.4	(14)	
(15) Precipitation	PrecAvg	364	62	45	34	18	10	3	0	6	25	85	39	66	(15)	
	PrecMax	591	177	129	68	47	35	37	4	64	105	253	152	233	(16)	
	PrecMin	152	13	5	0	4	0	0	0	0	0	1	1	5	(17)	
	PrecStd	126	48	36	19	12	9	8	1	14	30	63	43	51	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.2	18.4	20.7	22.2	27.9	34.0	35.2	35.4	31.4	27.7	24.0	20.1	(19)	
		MCWB	15.3	14.8	15.9	16.5	18.2	20.6	21.1	22.1	23.4	22.9	20.3	16.8	(20)	
	2%	DB	17.2	17.3	18.8	20.9	25.7	30.6	32.8	32.8	29.8	26.4	22.8	19.1	(21)	
		MCWB	14.6	14.2	14.9	16.0	18.7	21.5	22.8	23.5	24.0	22.7	20.1	16.3	(22)	
	5%	DB	16.4	16.5	17.7	20.0	24.2	29.0	31.4	31.5	28.7	25.3	21.8	18.2	(23)	
		MCWB	13.9	13.7	14.5	16.2	18.8	21.9	23.2	24.4	23.6	21.8	18.9	15.6	(24)	
	10%	DB	15.8	15.8	17.0	19.1	23.1	27.8	30.2	30.5	27.8	24.4	20.9	17.4	(25)	
		MCWB	13.4	13.1	14.1	15.8	18.6	21.5	23.3	24.6	23.3	21.3	18.2	14.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.5	16.4	17.2	18.7	22.6	25.9	28.4	28.5	26.7	24.7	21.9	18.2	(27)	
		MCDB	17.7	17.4	19.8	20.7	24.7	28.4	30.4	30.4	28.8	26.6	23.1	19.3	(28)	
	2%	WB	15.3	15.3	15.9	17.7	21.2	24.7	26.8	27.5	25.7	23.6	20.4	17.2	(29)	
		MCDB	16.6	16.6	17.8	19.7	23.6	27.5	29.4	29.8	28.0	25.4	22.2	18.5	(30)	
	5%	WB	14.5	14.3	15.2	17.0	20.3	23.8	25.9	26.8	24.9	22.6	19.4	16.1	(31)	
		MCDB	15.9	15.9	17.0	19.1	22.8	26.8	28.7	29.3	27.4	24.6	21.2	17.7	(32)	
	10%	WB	13.8	13.5	14.6	16.3	19.4	22.9	25.1	26.0	24.1	21.9	18.6	15.2	(33)	
		MCDB	15.4	15.2	16.3	18.3	21.9	26.0	28.2	28.8	26.8	23.9	20.4	17.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	5.6	5.8	5.8	6.1	6.3	6.8	6.2	5.8	5.2	5.2	5.2	(35)	
		MCDBR	5.7	6.2	6.4	6.6	7.4	7.9	8.3	7.4	6.4	5.9	5.5	5.7	(36)	
	5% WB	MCWBR	4.5	4.8	4.7	4.7	4.8	5.3	5.9	5.6	4.6	4.6	4.4	4.3	(37)	
		MCWBR	5.0	5.4	5.7	5.7	6.1	6.5	6.7	6.2	5.8	5.2	4.9	5.0	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.354	0.376	0.425	0.464	0.466	0.447	0.454	0.459	0.452	0.424	0.388	0.358	(40)	
		taud	2.429	2.346	2.195	2.107	2.146	2.241	2.240	2.228	2.249	2.295	2.359	2.424	(41)	
	Ebn at Noon	Ebn at Noon	829	851	836	823	826	839	830	818	801	787	778	795	(42)	
		Edh at Noon	88	107	136	156	153	139	138	137	127	111	94	83	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.46	3.31	4.62	5.88	6.91	7.61	7.72	6.82	5.24	3.79	2.67	2.20	(44)	
	RadStd	RadStd	0.17	0.28	0.28	0.32	0.32	0.29	0.15	0.28	0.23	0.23	0.20	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	+1.98	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	-0.27	-0.30	N/A	N/A	N/A	N/A	(47)	

Nomenclature: See separate page