

ALGHERO, Italy

WMO: 165200

Lat: 40.632N

Lon: 8.291E

Elev: 87

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.6	35.4	26.7	20.8	40.0	29.9	24.1	40.3	25.1	54.8	23.1	55.3	2.6	20	0.429

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.3	94.9	70.5	91.6	71.0	89.1	70.9	77.0	84.6	75.5	83.7	74.2	82.6	8.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.0	131.9	80.3	73.3	124.0	79.3	71.6	117.0	78.4	40.4	84.2	38.9	83.6	37.7	82.3	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.9	18.9	16.6	DB	28.6	100.9	2.0	2.3	27.2	102.6	26.0	104.0	24.9	105.3	23.5	107.0	(4)
(5)			WB	27.5	79.0	2.0	2.3	26.0	80.6	24.8	82.0	23.7	83.2	22.2	84.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.9	49.6	49.3	52.6	57.1	63.9	71.3	76.3	76.7	70.6	65.1	57.4	51.8
	DBStd	10.82	4.79	4.65	4.45	4.03	4.74	5.15	4.13	4.26	4.49	4.77	5.23	5.06
	HDD50	202	66	63	25	1	0	0	0	0	0	0	8	39
	HDD65	2333	477	440	385	240	78	7	0	0	7	58	232	409
	CDD50	4537	54	43	105	213	430	639	815	827	618	467	230	96
	CDD65	1192	0	0	0	2	43	196	350	362	175	60	4	0
	CDH74	11459	0	0	2	33	459	1907	3662	3759	1290	339	8	0
	CDH80	4530	0	0	0	5	109	723	1623	1682	332	56	0	0
Wind	WSAvg	6.8	7.1	7.2	7.7	7.5	6.8	6.6	6.5	6.0	6.2	6.0	6.9	7.1
Precipitation	PrecAvg	23.0	2.4	2.4	2.0	1.7	1.1	0.4	0.0	0.2	1.6	2.9	4.6	3.4
	PrecMax	32.7	5.2	6.3	4.4	3.5	5.5	1.6	0.4	2.0	5.4	8.9	14.6	7.1
	PrecMin	15.4	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0
	PrecStd	5.7	1.4	1.6	1.2	1.0	1.3	0.4	0.1	0.4	1.5	2.3	3.9	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.3	64.8	71.2	77.5	88.0	95.4	97.4	100.3	91.1	85.8	74.9	66.5
		MCWB	56.8	55.9	58.2	61.8	66.1	68.5	70.4	70.4	70.0	67.1	62.7	58.5
	2%	DB	61.1	61.2	66.3	73.3	82.5	91.4	94.2	95.2	86.3	80.8	71.7	64.0
		MCWB	56.1	54.6	56.4	60.1	65.0	69.3	70.5	71.5	70.2	67.5	62.4	58.0
	5%	DB	59.4	59.4	64.0	69.8	79.0	87.8	91.4	91.7	84.0	77.4	69.5	62.4
		MCWB	54.9	53.9	55.8	59.3	64.0	68.9	71.5	71.8	69.9	66.9	61.9	57.2
	10%	DB	58.1	57.8	61.5	66.5	75.4	84.1	88.2	88.2	80.9	75.0	66.6	60.7
		MCWB	53.7	53.0	55.2	58.3	62.8	68.8	71.4	72.1	69.2	65.9	60.5	56.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.6	58.1	60.7	64.4	69.6	75.1	78.2	80.0	77.0	72.4	66.7	61.1
		MCDB	61.6	61.5	66.4	72.7	79.5	83.8	86.0	85.5	81.4	77.4	70.4	63.8
	2%	WB	57.6	56.6	58.9	62.4	67.5	73.2	76.4	77.7	74.5	70.2	64.5	59.4
		MCDB	60.2	59.9	63.7	69.7	76.8	82.4	85.0	84.9	80.1	75.9	68.9	62.4
	5%	WB	55.8	55.3	57.4	60.8	66.0	71.8	75.1	76.0	72.7	68.7	62.7	58.1
		MCDB	58.9	58.8	61.9	66.8	74.6	81.0	83.9	84.2	79.4	74.8	67.7	61.4
	10%	WB	54.3	54.0	56.1	59.4	64.7	70.3	73.8	74.5	71.1	67.1	61.0	56.6
		MCDB	57.7	57.6	60.4	64.9	72.6	79.6	82.7	83.3	78.4	73.4	66.1	60.1
Mean Daily Temperature Range	5% DB	MDBR	15.0	15.8	17.2	17.9	19.7	21.1	21.6	22.3	19.3	18.5	15.8	14.7
		MCDBR	14.8	17.5	21.5	24.8	27.2	27.5	27.5	28.2	22.9	21.6	19.0	15.5
		MCWBR	11.4	12.6	13.9	14.5	12.8	10.4	10.4	11.0	10.8	11.2	11.7	11.3
	5% WB	MCDBR	12.9	14.4	17.2	20.2	22.3	22.6	22.4	22.9	19.0	18.6	15.9	13.4
		MCWBR	11.0	11.5	12.4	13.1	12.2	11.1	10.9	11.7	10.9	11.3	11.4	10.9
Clear-Sky Solar Irradiance	taub	0.340	0.359	0.389	0.421	0.435	0.419	0.425	0.419	0.415	0.395	0.372	0.344	
	taud	2.465	2.399	2.327	2.244	2.246	2.336	2.327	2.352	2.356	2.385	2.386	2.440	
	Ebn at Noon	258	269	272	270	269	272	270	268	261	252	241	245	
	Edh at Noon	25	30	36	43	43	40	40	38	35	31	27	24	
All-Sky Solar Radiation	RadAvg	595	877	1327	1714	2063	2396	2418	2086	1568	1097	675	534	
	RadStd	54	88	120	118	173	85	81	108	55	84	52	54	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page