

CAPO CACCIA, Italy

WMO: 165220

Lat: 40.561N

Lon: 8.163E

Elev: 669

StdP: 14.34

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	40.3	42.6	28.6	23.1	45.9	32.1	27.2	46.3	43.0	51.0	37.8	49.9	14.0	40	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	89.4	70.0	86.3	70.2	83.8	70.8	77.9	81.6	76.3	80.3	75.0	79.2	7.8	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.8	143.2	80.4	75.1	135.2	79.1	73.6	128.2	77.9	41.8	81.7	40.3	80.4	38.9	79.1	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.2	29.5	25.4	DB	36.4	96.7	2.5	3.4	34.6	99.2	33.2	101.2	31.8	103.1	30.0	105.6	(4)
(5)			WB	33.6	80.3	2.2	2.5	32.0	82.1	30.8	83.5	29.6	85.0	28.0	86.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.9	51.9	51.2	54.0	57.7	64.1	71.1	75.8	76.8	71.4	67.1	59.4	53.9	(6)
(7)		DBStd	10.09	3.89	4.10	3.90	4.11	5.03	5.55	4.56	4.56	4.18	4.40	5.02	4.58	(7)
(8)		HDD50	93	26	32	12	1	0	0	0	0	0	0	3	19	(8)
(9)		HDD65	1993	406	387	342	223	77	8	0	3	29	175	343	(9)	
(10)		CDD50	4816	84	64	136	231	437	634	799	832	643	529	286	141	(10)
(11)		CDD65	1242	0	0	0	4	49	192	334	367	196	93	7	0	(11)
(12)		CDH74	6677	0	0	0	14	188	988	2144	2553	629	159	2	0	(12)
(13)		CDH80	1654	0	0	0	1	37	262	544	713	85	12	0	0	(13)
(14)	Wind	WSAvg	10.4	13.1	12.1	11.4	10.2	9.2	8.0	8.3	9.2	9.4	12.4	13.0	(14)	
(15)	Precipitation	PrecAvg	19.1	2.0	1.7	1.4	1.6	1.3	0.7	0.2	0.3	1.6	2.6	3.4	2.4	(15)
(16)		PrecMax	30.8	5.7	5.7	3.1	4.4	4.4	2.6	1.1	1.6	4.4	7.8	9.2	5.9	(16)
(17)		PrecMin	12.6	0.0	0.1	0.1	0.3	0.0	0.0	0.0	0.0	0.2	0.1	0.7	0.1	(17)
(18)		PrecStd	4.5	1.3	1.3	0.8	1.0	1.1	0.7	0.3	0.3	1.2	1.8	1.9	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.9	64.2	68.6	75.2	84.6	91.3	92.7	94.9	87.0	81.5	72.0	64.8	(19)
(20)			MCWB	54.9	55.2	56.6	61.0	65.1	71.5	68.8	70.4	70.6	66.0	64.0	58.8	(20)
(21)		2%	DB	59.4	59.2	63.9	69.8	78.7	86.1	88.2	89.9	82.1	77.9	69.8	62.6	(21)
(22)			MCWB	55.1	53.6	55.6	58.5	63.3	68.9	69.4	69.9	70.7	66.5	63.0	58.4	(22)
(23)		5%	DB	58.1	57.4	61.0	66.2	75.0	82.6	85.6	86.5	79.3	75.2	67.8	61.0	(23)
(24)			MCWB	54.7	53.5	55.0	57.8	62.6	68.6	70.9	70.8	71.3	66.9	62.1	57.9	(24)
(25)		10%	DB	57.0	55.9	59.1	63.5	71.7	79.3	82.6	83.8	77.3	73.0	66.0	59.6	(25)
(26)			MCWB	54.0	52.5	54.7	57.4	62.0	69.0	71.7	71.8	70.7	66.6	61.2	56.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.3	57.5	59.6	63.8	69.4	77.1	79.9	80.8	77.2	72.5	67.4	61.2	(27)
(28)			MCD B	59.4	60.0	63.2	70.4	74.5	81.4	83.7	83.3	79.7	75.3	70.1	62.8	(28)
(29)		2%	WB	56.6	55.7	57.8	61.5	67.1	74.9	77.7	78.3	75.1	70.7	65.2	59.6	(29)
(30)			MCD B	58.0	57.6	60.9	66.0	72.7	79.4	81.8	81.7	77.9	74.0	67.8	61.5	(30)
(31)		5%	WB	55.3	54.4	56.5	59.8	65.4	73.0	76.2	76.6	73.4	69.3	63.4	58.4	(31)
(32)			MCD B	57.2	56.5	59.4	63.7	71.0	77.8	80.4	80.5	77.5	72.8	66.3	60.5	(32)
(33)		10%	WB	54.1	53.1	55.4	58.4	63.9	71.2	74.8	75.0	71.8	67.7	61.8	57.1	(33)
(34)			MCD B	56.3	55.5	58.1	62.1	69.2	76.8	79.1	79.5	75.9	71.4	65.0	59.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.9	6.7	7.6	8.3	9.2	9.8	9.4	9.4	8.4	8.1	6.4	6.0	(35)
(36)			MCD BR	6.5	8.2	10.7	13.0	15.0	15.4	14.6	14.6	11.3	11.1	8.1	6.7	(36)
(37)			MCWBR	6.0	6.9	8.3	8.9	8.8	9.2	9.3	9.5	8.2	7.5	7.0	5.8	(37)
(38)		5% WB	MCD BR	5.6	6.9	8.5	10.5	11.6	11.3	10.7	10.5	9.5	8.8	7.3	5.9	(38)
(39)			MCWBR	6.1	6.9	7.5	8.6	8.7	9.5	9.5	9.4	8.3	7.4	7.4	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.330	0.348	0.376	0.406	0.418	0.404	0.410	0.405	0.401	0.382	0.361	0.335	(40)	
(41)		taud	2.499	2.441	2.375	2.297	2.299	2.379	2.371	2.394	2.399	2.428	2.427	2.475	(41)	
(42)		Ebn at Noon	263	274	277	275	273	277	274	272	266	258	247	250	(42)	
(43)		Edh at Noon	24	30	35	40	41	38	38	36	34	30	26	23	(43)	
(44)	All-Sky Solar Radiation	RadAvg	602	885	1340	1726	2074	2404	2422	2091	1575	1104	682	541	(44)	
(45)		RadStd	54	88	119	119	171	84	79	107	56	84	52	54	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page