

CAPO FRASCA, Italy

WMO: 165390

Lat: 39.7399N

Lon: 8.4595E

Elev: 312

StdP: 14.53

Time Zone: 1.00 (EUC)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	38.6	41.0	31.2	25.8	41.6	34.2	29.3	43.2	38.1	50.3	34.3	49.3	9.0	50	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.1	89.7	74.3	86.1	75.7	83.5	75.9	80.7	83.6	79.1	82.3	77.8	81.1	14.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.0	157.3	82.9	78.3	148.8	81.3	76.8	141.2	80.0	44.7	84.1	42.9	82.6	41.4	81.1	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
32.5	28.5	24.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB	34.7	81.9	2.9	2.7	32.6	83.8	30.9	85.4	29.3	87.0	27.1	89.0
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.6	50.7	50.1	53.0	57.1	63.2	71.0	76.0	78.1	71.7	67.1	59.2	53.3		
	DBStd	10.45	4.09	4.42	3.84	3.20	3.85	4.61	4.01	4.04	3.85	4.35	4.86	4.20		
	HDD50	126	40	47	16	0	0	0	0	0	0	0	5	18		
	HDD65	2126	442	417	371	238	82	5	0	0	2	27	180	362		
	CDD50	4731	63	50	110	214	410	629	804	871	650	529	280	121		
	CDD65	1255	0	0	0	2	26	183	339	406	202	92	5	0		
	CDH74	7172	0	0	0	6	67	761	2205	3273	698	162	0	0		
	CDH80	1686	0	0	0	0	12	180	495	898	92	9	0	0		
(14) Wind	WSAvg	11.5	12.7	11.9	11.1	12.7	11.4	11.2	10.8	10.0	10.7	11.0	12.2	12.0		
(15) Precipitation	PrecAvg	21.3	2.2	2.6	1.9	1.9	1.1	0.6	0.2	0.2	1.5	2.8	3.9	2.8		
	PrecMax	31.1	6.7	6.6	6.3	4.3	5.6	2.4	1.1	1.5	5.0	11.3	10.3	6.7		
	PrecMin	6.5	0.1	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.2	0.5	0.1		
	PrecStd	6.2	1.6	1.7	1.3	1.3	1.2	0.6	0.3	0.4	1.3	2.5	2.3	1.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.2	61.7	66.7	73.2	79.5	91.2	92.5	95.4	86.5	81.3	71.7	63.5		
		MCWB	56.9	55.9	57.2	64.7	66.3	70.4	72.7	73.6	75.3	71.1	67.9	59.2		
	2%	DB	58.7	58.7	62.5	66.9	75.4	84.5	87.9	91.2	82.3	77.8	69.4	61.7		
		MCWB	56.4	54.8	56.0	60.3	65.5	69.8	74.7	75.0	74.3	70.7	64.9	58.2		
	5%	DB	57.4	57.2	60.3	64.2	72.0	80.5	84.6	87.3	79.6	75.4	67.5	60.2		
		MCWB	55.4	54.0	56.1	59.6	65.6	71.6	76.2	76.6	73.4	69.7	63.8	57.3		
	10%	DB	56.2	55.8	58.8	62.3	69.6	77.7	82.3	84.4	77.5	73.5	65.6	59.0		
		MCWB	54.1	53.1	55.5	58.8	65.0	71.3	76.4	77.1	72.2	68.7	62.1	56.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.3	57.6	59.6	66.0	72.7	78.3	82.6	83.6	79.5	74.8	68.7	60.4		
		MCDB	59.0	59.4	61.7	71.2	76.3	82.0	84.8	86.1	82.6	78.2	70.5	61.9		
	2%	WB	56.9	55.9	58.1	62.2	68.7	75.6	80.3	81.4	77.2	72.3	66.3	59.2		
		MCDB	58.0	57.5	60.6	65.1	71.8	78.8	82.8	84.3	79.5	75.6	68.4	60.7		
	5%	WB	55.8	54.9	57.0	60.5	67.0	74.0	78.6	79.8	75.1	70.6	64.4	57.9		
		MCDB	57.0	56.5	59.5	62.9	70.1	77.0	81.7	83.0	77.7	74.2	66.3	59.7		
	10%	WB	54.5	53.7	55.7	59.2	65.5	72.5	77.2	78.5	73.2	69.1	62.6	56.7		
		MCDB	55.9	55.4	58.1	61.7	68.4	75.7	80.2	81.9	76.5	72.7	65.0	58.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	7.9	9.6	9.0	9.7	10.5	10.4	11.1	10.3	9.8	7.8	7.1		
		MCDBR	7.4	8.8	12.2	12.6	14.8	16.9	15.2	16.6	13.2	11.9	9.4	7.7		
	5% WB	MCWBR	5.9	7.1	8.6	9.0	8.5	9.2	9.0	9.8	8.9	7.8	7.6	6.3		
		MCWBR	7.1	8.3	11.1	10.7	11.6	12.1	11.7	12.9	12.1	10.6	9.0	7.3		
(40) Clear-Sky Solar Irradiance	taub		0.344	0.366	0.402	0.438	0.453	0.432	0.443	0.433	0.429	0.405	0.380	0.351		
	taud		2.431	2.355	2.254	2.166	2.162	2.270	2.244	2.279	2.281	2.320	2.335	2.395		
	Ebn at Noon		258	268	269	266	264	269	265	265	257	250	240	244		
	Edh at Noon		26	32	40	46	47	43	43	41	38	33	29	25		
(44) All-Sky Solar Radiation	RadAvg		625	910	1345	1728	2077	2408	2433	2120	1588	1127	705	565		
	RadStd		55	91	133	116	153	77	74	102	55	83	53	55		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (9 neighbors)	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) -0.81	(i) -1.06	(j) N/A	(k) N/A	(l) N/A

Nomenclature: See separate page