

DECIMOMANNU, Italy

WMO: 165460

Lat: 39.3459N

Lon: 8.9704E

Elev: 31

StdP: 100.96

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.9	2.1	-3.2	2.9	11.2	-1.4	3.4	9.0	13.5	13.6	11.8	13.2	1.4	330	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	36.1	22.0	34.8	22.0	33.1	21.6	26.5	30.8	25.5	29.8	24.6	28.8	5.6	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.4	28.7	24.2	19.1	27.8	23.2	18.0	26.9	82.7	30.7	78.3	29.7	74.5	28.8	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.9	8.9	DB	-1.4	39.8	1.2	2.0	-2.2	41.2	-2.9	42.4	-3.6	43.5	-4.5	44.9	(4)
(5)			WB	-1.8	28.2	1.2	1.5	-2.6	29.3	-3.3	30.1	-3.9	31.0	-4.8	32.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.6	9.8	9.9	12.4	15.1	18.7	23.5	26.6	26.5	23.0	19.6	14.5	11.1
	DBStd	6.56	2.54	2.61	2.67	2.30	2.64	2.86	2.23	2.22	2.49	2.73	2.86	2.71
	HDD10.0	98	34	31	10	0	0	0	0	0	0	0	3	20
	HDD18.3	1172	264	236	185	98	27	1	0	0	1	18	117	226
	CDD10.0	2876	28	28	83	154	270	406	516	513	389	297	138	53
	CDD18.3	908	0	0	0	2	38	156	257	254	140	57	3	0
	CDH23.3	9026	0	0	5	35	379	1609	2876	2727	1076	312	7	0
	CDH26.7	3993	0	0	2	1	95	687	1456	1358	347	47	0	0
Wind	WSAvg	3.5	2.8	3.1	3.5	3.5	4.1	4.3	4.7	4.1	3.4	3.1	2.7	2.7
Precipitation	PrecAvg	531	52	54	47	54	31	15	7	10	37	57	94	74
	PrecMax	754	144	141	114	134	79	71	21	42	106	146	309	155
	PrecMin	311	11	9	6	11	4	2	2	1	2	8	15	21
	PrecStd	115	32	35	26	32	19	17	5	10	27	35	64	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.9	19.2	23.1	26.1	31.2	36.2	38.0	38.7	33.9	30.0	24.1	20.2
		MCWB	15.6	13.8	15.7	16.6	17.6	21.5	21.8	22.3	21.8	21.6	18.5	16.4
	2%	DB	17.0	17.8	20.9	24.2	29.1	34.1	36.0	36.2	31.8	27.9	22.2	18.2
		MCWB	14.1	13.2	14.4	15.3	17.7	20.7	22.3	21.9	22.0	20.5	17.9	15.1
	5%	DB	15.9	16.2	19.2	22.8	27.2	32.2	34.8	34.9	30.1	26.3	21.1	17.2
		MCWB	13.1	12.4	13.7	14.9	17.1	20.3	22.1	22.2	21.9	20.4	17.3	14.6
	10%	DB	14.8	15.1	18.0	21.0	25.2	30.8	33.1	33.0	28.8	25.0	19.9	16.1
		MCWB	12.3	11.8	13.4	15.0	16.5	19.9	21.7	22.0	21.2	19.8	16.5	13.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.3	15.8	17.4	19.7	22.1	26.0	27.9	28.1	26.2	24.4	20.5	17.2
		MCDB	18.0	18.0	20.4	23.3	26.1	31.0	32.2	32.1	29.7	27.1	22.7	19.2
	2%	WB	14.8	14.2	15.9	18.0	20.4	24.4	26.4	26.6	24.9	22.8	19.2	16.0
		MCDB	16.4	16.4	19.0	21.4	24.7	29.1	30.8	31.0	28.3	25.7	21.6	17.8
	5%	WB	13.6	13.2	14.9	16.8	19.2	23.2	25.3	25.6	23.9	21.8	18.0	15.0
		MCDB	15.4	15.5	18.0	20.2	23.7	28.0	29.6	30.0	27.3	24.6	20.3	16.8
	10%	WB	12.5	12.3	14.0	15.9	18.3	22.2	24.3	24.7	22.8	20.8	16.9	14.0
		MCDB	14.3	14.7	16.7	19.0	22.9	27.1	28.8	29.1	26.5	23.7	19.2	16.0
Mean Daily Temperature Range	5% DB	MDBR	9.3	9.8	10.4	11.1	11.9	12.8	12.9	12.9	11.4	10.7	9.3	9.1
		MCDBR	10.5	11.4	12.6	14.0	15.1	15.0	15.0	15.2	12.9	12.0	10.7	10.3
		MCWBR	8.2	7.9	7.6	7.0	6.1	5.8	6.3	6.7	6.6	7.1	7.4	8.1
	5% WB	MCDBR	9.6	10.7	10.7	11.4	12.6	13.1	13.5	13.3	11.4	10.4	9.7	9.6
		MCWBR	8.1	8.2	7.5	7.6	7.0	6.7	6.9	7.5	7.0	7.5	7.7	8.1
Clear-Sky Solar Irradiance	taub	0.346	0.366	0.406	0.445	0.460	0.435	0.449	0.438	0.435	0.410	0.382	0.353	
	taud	2.426	2.353	2.237	2.142	2.138	2.258	2.222	2.260	2.261	2.302	2.333	2.392	
	Ebn at Noon	815	847	845	833	826	846	831	830	806	784	758	772	
	Edh at Noon	84	103	127	149	153	136	139	131	123	107	91	81	
All-Sky Solar Radiation	RadAvg	2.07	2.95	4.24	5.45	6.54	7.54	7.62	6.68	5.00	3.59	2.29	1.86	
	RadStd	0.19	0.26	0.43	0.38	0.47	0.25	0.24	0.32	0.18	0.25	0.16	0.16	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	+0.29	N/A	N/A	N/A	-0.50	-0.61	N/A	N/A	N/A	N/A

Nomenclature: See separate page