

CAPO CARBONARA, Italy

WMO: 165640

Lat: 39.104N

Lon: 9.514E

Elev: 387

StdP: 14.49

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	42.8	45.1	29.8	24.2	47.1	33.5	28.4	48.7	57.0	53.9	52.8	53.6	21.3	290	0.590

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.8	89.7	79.8	87.9	79.0	86.2	77.6	82.4	87.6	80.7	86.4	79.2	85.0	10.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.8	162.2	87.3	79.0	152.7	85.9	77.3	143.9	84.4	46.5	88.4	44.7	86.8	43.0	85.7	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
49.0	42.1	36.1	DB	38.6	93.9	3.0	2.0	36.5	95.4	34.7	96.6	33.0	97.7	30.8	99.2
			WB	34.0	85.7	2.0	1.1	32.5	86.5	31.4	87.1	30.2	87.7	28.8	88.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.0	54.8	53.6	56.5	60.9	66.0	73.7	79.9	81.1	76.0	70.0	62.0	56.8	(6)
	DBStd	10.25	3.37	4.08	3.56	3.25	4.08	3.67	2.98	2.84	3.54	4.13	4.90	4.17	(7)
	HDD50	30	6	15	3	0	0	0	0	0	0	0	0	6	(8)
	HDD65	1434	315	320	265	127	34	0	0	0	0	9	110	254	(9)
	CDD50	5878	156	115	203	328	497	711	928	963	781	619	360	217	(10)
	CDD65	1808	0	0	0	5	66	261	463	498	331	164	19	1	(11)
	CDH74	12225	0	0	0	2	114	1229	4118	4630	1797	329	6	0	(12)
	CDH80	3346	0	0	0	0	9	200	1218	1555	345	19	0	0	(13)
(14) Wind	WSAvg	15.5	18.2	18.3	18.6	16.8	15.4	13.3	12.2	10.7	13.4	14.5	16.7	17.7	(14)
(15) Precipitation	PrecAvg	16.3	1.5	1.5	1.7	1.6	1.1	0.3	0.2	0.3	1.4	1.9	2.6	2.3	(15)
	PrecMax	28.7	3.6	3.6	4.4	5.2	2.4	1.4	1.1	1.1	2.9	3.8	6.9	5.8	(16)
	PrecMin	11.1	0.6	0.4	0.5	0.5	0.3	0.0	0.0	0.0	0.2	0.6	0.8	1.1	(17)
	PrecStd	3.9	0.8	0.8	1.1	1.1	0.5	0.3	0.3	0.3	0.8	0.9	1.4	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.5	65.9	67.8	73.0	80.8	87.4	91.6	93.3	87.9	82.3	74.8	68.4	(19)
		MCWB	58.9	59.3	60.8	62.9	69.8	75.7	79.8	80.5	78.4	74.3	66.4	62.2	(20)
	2%	DB	62.5	62.7	65.8	70.1	76.9	84.5	89.4	91.0	85.7	80.0	71.6	64.9	(21)
		MCWB	57.7	58.2	59.6	62.4	68.0	74.3	79.3	80.3	76.9	72.2	66.2	59.6	(22)
	5%	DB	60.8	60.8	63.4	68.2	74.8	82.4	87.6	88.8	83.9	77.3	69.7	63.0	(23)
		MCWB	56.2	56.2	58.4	61.4	67.4	73.5	78.6	79.9	75.1	69.9	64.6	58.2	(24)
	10%	DB	59.2	59.0	61.7	66.3	72.6	80.4	86.0	87.1	82.1	75.4	68.0	61.8	(25)
		MCWB	55.1	54.6	57.2	60.4	65.8	72.2	77.5	78.7	73.7	68.9	63.5	57.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.4	61.5	62.5	66.4	72.8	80.4	84.1	85.2	81.0	77.1	69.1	62.9	(27)
		MCDB	63.3	64.2	66.0	70.3	77.1	85.1	89.0	89.7	85.9	80.0	72.3	67.5	(28)
	2%	WB	58.5	58.9	60.5	64.4	70.6	77.1	81.9	83.1	78.7	73.8	67.1	60.8	(29)
		MCDB	61.4	62.2	64.0	68.3	75.0	82.0	87.0	88.1	84.0	77.8	70.3	64.7	(30)
	5%	WB	57.1	56.8	59.1	62.8	68.5	75.1	80.4	81.4	76.8	71.8	65.4	59.1	(31)
		MCDB	60.1	60.1	62.7	66.9	73.3	80.2	85.9	87.2	82.2	76.6	68.8	62.6	(32)
	10%	WB	55.5	55.2	57.4	61.1	66.4	73.3	78.9	79.9	75.1	70.0	63.9	57.6	(33)
		MCDB	58.9	58.6	60.9	65.4	71.4	78.9	84.7	86.1	80.3	74.6	67.5	61.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	9.1	9.6	10.2	11.1	11.7	12.2	12.8	11.3	10.1	8.8	8.1	(35)
		MCDBR	9.3	10.5	11.4	12.1	13.0	13.7	14.0	14.0	12.7	11.4	10.2	8.8	(36)
		MCWBR	8.2	9.4	10.0	9.9	10.8	12.2	12.3	12.5	10.4	9.4	8.4	7.6	(37)
	5% WB	MCDBR	8.9	10.1	10.7	11.4	11.5	12.2	13.1	12.9	11.5	10.8	9.4	8.3	(38)
		MCWBR	8.4	9.4	9.8	10.3	10.8	12.1	12.5	12.9	10.4	9.5	8.6	7.7	(39)
(40) Clear-Sky Solar Irradiance	taub		0.334	0.351	0.389	0.427	0.440	0.416	0.429	0.421	0.419	0.397	0.369	0.342	(40)
	taud		2.495	2.441	2.334	2.238	2.239	2.351	2.323	2.352	2.353	2.384	2.419	2.469	(41)
	Ebn at Noon		265	276	275	270	268	274	269	269	262	255	248	252	(42)
	Edh at Noon		25	30	37	43	44	39	40	38	36	31	27	24	(43)
(44) All-Sky Solar Radiation	RadAvg		686	968	1357	1749	2088	2384	2411	2123	1596	1157	752	620	(44)
	RadStd		64	75	139	129	146	83	78	97	62	79	51	49	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	+0.52	N/A	N/A	N/A	-0.90	-1.10	N/A	N/A	N/A	N/A

Nomenclature: See separate page