

CORFU KERKYRA, Greece

WMO: 166410

Lat: 39.602N

Lon: 19.912E

Elev: 6

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.6	36.1	20.3	15.2	44.2	25.1	19.1	44.7	27.6	56.2	23.3	55.5	1.6	290	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.1	95.2	74.5	93.0	74.2	90.6	73.9	79.2	89.0	77.4	87.4	75.9	86.0	8.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.5	138.0	86.5	74.2	127.5	83.9	73.0	122.4	82.6	42.7	88.9	40.8	87.6	39.3	86.0	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.3	19.1	16.5	DB	29.1	100.1	3.5	3.6	26.6	102.7	24.5	104.8	22.5	106.8	20.0	109.4
			WB	27.3	81.2	3.6	2.4	24.7	82.9	22.6	84.3	20.6	85.7	17.9	87.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.9	49.6	50.7	53.9	59.4	67.2	74.9	79.6	80.3	73.1	66.1	58.8	52.4	(6)
	DBStd	11.72	5.07	4.99	4.58	4.63	4.21	4.86	3.43	3.52	4.27	4.36	5.49	5.22	(7)
	HDD50	173	68	47	17	2	0	0	0	0	0	0	5	34	(8)
	HDD65	2054	478	401	344	175	26	1	0	0	1	40	196	392	(9)
	CDD50	5250	56	66	139	284	533	748	919	938	692	499	269	107	(10)
	CDD65	1654	0	0	0	7	94	299	454	473	244	74	9	0	(11)
	CDH74	15601	0	0	0	49	602	2802	4984	5145	1732	280	7	0	(12)
	CDH80	6418	0	0	0	7	94	1057	2326	2444	471	19	0	0	(13)
(14) Wind	WSAvg	5.2	5.6	6.1	5.8	5.3	4.8	4.6	5.0	4.5	4.7	4.4	6.0	5.8	(14)
(15) Precipitation	PrecAvg	42.4	5.2	5.2	3.8	2.4	1.5	0.6	0.4	0.8	3.3	5.3	7.2	7.0	(15)
	PrecMax	64.8	11.6	12.0	9.0	6.2	4.1	3.1	2.7	6.2	9.3	15.4	17.6	19.8	(16)
	PrecMin	24.6	0.0	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.3	0.2	(17)
	PrecStd	9.3	2.9	3.0	2.2	1.7	1.0	0.7	0.6	1.3	2.6	3.5	3.7	3.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.2	67.8	71.3	79.2	85.8	95.4	98.6	99.0	91.4	82.5	75.0	68.1	(19)
		MCWB	56.6	57.6	59.4	64.4	68.7	74.5	75.0	75.2	74.0	69.9	65.0	61.4	(20)
	2%	DB	62.1	63.2	67.3	73.8	82.5	91.8	95.1	95.5	87.8	79.1	71.9	64.8	(21)
		MCWB	56.4	55.4	57.6	61.7	68.1	74.1	74.8	74.4	73.7	68.3	64.6	59.1	(22)
	5%	DB	60.4	61.1	64.7	71.5	80.3	89.2	92.8	93.2	84.8	77.0	70.0	63.0	(23)
		MCWB	55.0	54.8	56.5	60.4	67.1	73.6	74.3	74.2	72.6	68.0	63.3	58.0	(24)
	10%	DB	58.7	59.3	62.8	68.5	77.2	86.0	90.0	91.0	82.5	75.1	68.0	61.2	(25)
		MCWB	53.6	53.8	55.7	59.2	65.9	71.9	73.7	74.0	71.3	66.8	61.8	56.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.2	59.3	61.3	66.6	72.1	79.8	82.4	82.2	79.1	73.3	68.4	62.9	(27)
		MCDB	62.2	64.2	67.7	77.1	81.2	90.0	93.5	93.1	86.5	78.2	71.8	66.5	(28)
	2%	WB	57.3	57.4	59.2	63.6	69.9	76.7	79.2	79.1	76.4	70.9	65.9	60.3	(29)
		MCDB	60.9	61.6	65.1	71.7	79.1	87.2	89.2	89.2	84.0	76.4	70.5	63.6	(30)
	5%	WB	55.5	55.8	57.7	61.8	68.3	74.9	77.2	77.2	74.6	69.3	64.0	59.0	(31)
		MCDB	59.3	60.0	63.1	68.9	77.3	85.6	87.7	87.4	81.6	75.0	68.9	62.6	(32)
	10%	WB	54.1	54.5	56.4	60.3	66.9	73.2	75.5	75.7	72.9	67.9	62.4	57.2	(33)
		MCDB	57.8	58.8	61.5	66.9	75.4	83.3	86.3	86.2	79.7	73.4	67.0	61.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.6	14.2	15.4	16.3	17.7	19.2	20.2	20.1	17.1	16.1	14.6	14.3	(35)
		MCDBR	15.1	16.5	17.9	20.2	21.5	22.8	23.8	23.7	19.9	18.3	15.2	15.1	(36)
		MCWBR	10.5	10.7	10.7	10.4	10.3	10.3	10.1	9.6	9.4	9.9	9.7	10.7	(37)
	5% WB	MCDBR	12.8	14.4	16.2	18.5	19.8	21.0	21.0	20.9	18.1	16.1	14.1	12.7	(38)
		MCWBR	9.9	10.2	10.4	10.4	10.5	10.7	11.3	10.4	10.1	10.1	9.8	9.9	(39)
(40) Clear-Sky Solar Irradiance	taub		0.350	0.378	0.423	0.472	0.458	0.442	0.445	0.463	0.439	0.413	0.381	0.357	(40)
	taud		2.444	2.338	2.204	2.084	2.187	2.281	2.275	2.220	2.282	2.324	2.375	2.414	(41)
	Ebn at Noon		257	264	262	256	263	266	265	256	255	248	241	243	(42)
	Edh at Noon		26	33	42	50	46	42	42	43	38	33	28	25	(43)
(44) All-Sky Solar Radiation	RadAvg		615	862	1292	1694	2087	2386	2433	2128	1581	1097	714	551	(44)
	RadStd		58	101	132	141	112	117	89	88	93	91	60	84	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) +0.83	(e) N/A	(f) N/A	(g) +1.37	(h) N/A	(i) N/A	(j) N/A	(k) -193	(l) +342	(m) +164
Regional (8 neighbors)	+0.68	N/A	N/A	+1.44	N/A	N/A	N/A	-173	+266	+137

Nomenclature: See separate page