

NEA ANCHIALOS, Greece

WMO: 166650

Lat: 39.220N

Lon: 22.794E

Elev: 83

StdP: 14.65

Time Zone: 2.00 (EUE)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.8	32.1	19.0	14.3	36.5	22.8	17.2	37.4	23.5	52.0	21.1	50.7	7.9	270	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.1	94.6	70.6	91.8	70.2	89.9	69.8	75.1	87.5	73.6	85.9	72.4	85.2	11.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.4	116.1	82.0	69.6	109.2	81.3	68.0	103.0	79.9	38.5	87.7	37.2	86.3	36.1	85.1	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.7	17.1	15.0	DB	24.9	101.2	3.6	5.1	22.3	104.9	20.2	107.8	18.1	110.7	15.5	114.4
			WB	22.5	77.5	3.4	1.7	20.0	78.7	18.0	79.7	16.1	80.7	13.7	81.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.6	45.0	47.4	51.5	57.9	66.4	74.8	79.0	78.7	71.6	63.2	55.2	47.6	
	DBStd	13.02	6.10	5.61	5.71	4.61	4.88	4.64	3.55	3.52	4.63	4.94	5.80	5.91	
	HDD50	460	172	103	48	2	0	0	0	0	0	0	20	115	
	HDD65	2724	619	494	419	217	42	0	0	0	7	91	296	539	
	CDD50	4698	18	29	95	239	509	743	899	891	648	409	177	41	
	CDD65	1485	0	0	1	4	85	293	434	426	205	35	2	0	
	CDH74	15706	0	0	17	44	696	3038	5151	4822	1715	210	12	1	
	CDH80	6612	0	0	5	4	122	1172	2478	2310	497	22	2	0	
Wind	WSAvg	6.7	6.7	6.7	6.9	6.5	6.9	7.2	7.2	7.2	6.8	5.9	6.0	6.5	
Precipitation	PrecAvg	18.6	2.2	1.5	1.7	1.3	1.3	0.6	0.7	0.6	1.3	2.3	2.4	3.0	
	PrecMax	26.8	5.2	3.7	3.1	3.4	3.1	2.3	2.2	1.9	4.3	9.1	6.9	7.2	
	PrecMin	12.3	0.4	0.1	0.6	0.1	0.4	0.0	0.0	0.0	0.0	0.0	0.4	0.6	
	PrecStd	3.5	1.5	0.8	0.6	0.8	0.7	0.6	0.7	0.6	1.2	2.0	1.9	1.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.0	68.0	75.2	78.7	86.4	95.4	98.6	97.2	91.6	82.6	75.0	69.4	
		MCWB	53.9	54.8	57.0	60.2	64.2	69.9	71.2	70.4	68.0	64.9	59.9	58.2	
	2%	DB	61.1	63.0	69.7	74.8	82.8	91.5	94.6	94.6	87.8	78.9	70.2	64.2	
		MCWB	52.7	53.6	55.1	59.0	64.2	69.3	70.6	70.9	68.4	64.9	60.8	55.4	
	5%	DB	58.6	60.7	66.1	71.7	80.6	89.2	91.7	91.8	84.6	75.6	67.9	60.6	
		MCWB	50.8	52.7	54.2	58.3	63.3	69.5	70.5	70.5	68.0	64.3	59.7	54.0	
	10%	DB	55.4	57.6	62.9	69.4	77.4	86.2	89.8	89.8	82.5	73.5	64.8	57.4	
		MCWB	49.4	50.9	53.4	57.7	63.1	68.4	70.0	70.0	67.5	63.4	58.0	51.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.5	56.9	59.6	63.1	69.5	75.1	76.6	77.0	74.1	69.7	65.3	59.7
			MCDB	62.6	63.7	71.0	72.1	81.1	87.6	89.1	88.5	83.1	75.6	69.9	66.2
2%		WB	53.9	54.9	57.2	61.4	67.2	72.9	75.0	75.3	71.9	67.6	62.6	57.1	
		MCDB	59.6	60.9	65.7	70.7	78.1	85.8	87.8	87.5	81.6	74.5	68.2	61.7	
5%		WB	51.7	53.4	55.5	60.1	65.7	71.3	73.5	73.8	70.3	66.0	60.6	54.7	
		MCDB	57.0	59.3	63.5	68.9	76.1	84.5	86.4	86.0	80.7	73.0	66.1	59.9	
10%		WB	50.0	51.8	54.0	58.7	64.5	69.9	72.3	72.4	69.1	64.6	59.0	52.4	
		MCDB	54.4	57.2	62.0	66.7	74.5	83.1	85.7	85.3	79.6	71.5	64.4	56.9	
Mean Daily Temperature Range		5% DB	MDBR	14.9	15.8	18.3	19.1	19.7	20.5	21.1	20.9	18.8	16.7	15.4	14.5
			MCDBR	20.5	20.9	23.5	23.7	23.5	23.7	23.8	23.4	22.3	20.5	18.7	19.0
	MCWBR		13.5	13.4	12.9	12.4	10.8	10.4	10.6	10.5	11.5	11.5	11.6	12.5	
	5% WB	MCDBR	18.4	18.6	21.3	21.0	20.6	21.6	21.6	21.1	20.2	17.9	16.2	16.7	
		MCWBR	13.1	12.7	13.6	12.5	10.8	10.7	10.9	11.2	11.5	11.2	11.0	11.8	
Clear-Sky Solar Irradiance	taub	0.358	0.385	0.427	0.471	0.458	0.446	0.452	0.463	0.446	0.418	0.389	0.367		
	taud	2.396	2.283	2.165	2.059	2.166	2.244	2.234	2.197	2.227	2.280	2.315	2.355		
	Ebn at Noon	254	261	261	257	263	266	263	256	252	246	238	239		
	Edh at Noon	28	35	43	51	47	44	44	44	41	35	30	27		
All-Sky Solar Radiation	RadAvg	586	829	1224	1636	1971	2248	2319	2062	1509	1007	676	511		
	RadStd	89	102	117	159	102	134	89	80	109	107	77	84		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	+0.63	N/A	N/A	+1.12	N/A	N/A	N/A	-149	+175	N/A

Nomenclature: See separate page