

NEA ANCHIALOS, Greece

WMO: 166650

Lat: 39.220N

Lon: 22.794E

Elev: 25

StdP: 101.02

Time Zone: 2.00 (EUE)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.2	0.0	-7.2	2.0	2.5	-5.1	2.5	3.0	10.5	11.1	9.4	10.4	3.5	270	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	34.8	21.5	33.2	21.2	32.2	21.0	24.0	30.8	23.1	30.0	22.5	29.5	4.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	16.6	27.8	20.9	15.6	27.4	20.0	14.7	26.6	71.6	30.9	68.7	30.2	66.0	29.5	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	7.6	6.7	-3.9	38.5	2.0	2.8	-5.4	40.5	-6.6	42.1	-7.7	43.7	-9.2	45.8		
			(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-5.3	25.3	1.9	1.0	-6.6	25.9	-7.8	26.5	-8.8	27.0	-10.2	27.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	7.2	8.5	10.8	14.4	19.1	23.8	26.1	26.0	22.0	17.3	12.9	8.7
	DBStd	7.23	3.39	3.11	3.17	2.56	2.71	2.58	1.97	1.95	2.57	2.75	3.22	3.28
	HDD10.0	256	96	57	27	1	0	0	0	0	0	0	11	64
	HDD18.3	1513	344	274	233	121	23	0	0	0	4	51	164	299
	CDD10.0	2610	10	16	53	133	283	413	499	495	360	227	98	23
	CDD18.3	825	0	0	1	2	47	163	241	237	114	19	1	0
	CDH23.3	8726	0	0	9	24	387	1688	2862	2679	953	117	7	1
	CDH26.7	3673	0	0	3	2	68	651	1377	1283	276	12	1	0
Wind	WSAvg	3.0	3.0	3.0	3.1	2.9	3.1	3.2	3.2	3.2	3.0	2.6	2.7	2.9
Precipitation	PrecAvg	472	55	38	43	33	33	15	19	15	34	58	62	77
	PrecMax	680	132	95	80	86	78	58	57	47	108	230	174	184
	PrecMin	313	9	2	15	3	9	1	0	0	0	1	11	16
	PrecStd	89	38	21	16	20	18	14	17	14	30	51	47	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.9	20.0	24.0	26.0	30.2	35.2	37.0	36.2	33.1	28.1	23.9	20.8
		MCWB	12.2	12.7	13.9	15.7	17.9	21.1	21.8	21.3	20.0	18.3	15.5	14.6
	2%	DB	16.2	17.2	21.0	23.8	28.2	33.1	34.8	34.8	31.0	26.1	21.2	17.9
		MCWB	11.5	12.0	12.8	15.0	17.9	20.7	21.4	21.6	20.2	18.3	16.0	13.0
	5%	DB	14.8	16.0	19.0	22.0	27.0	31.8	33.2	33.2	29.2	24.2	19.9	15.9
		MCWB	10.4	11.5	12.4	14.6	17.4	20.8	21.4	21.4	20.0	17.9	15.4	12.2
	10%	DB	13.0	14.2	17.1	20.8	25.2	30.1	32.1	32.1	28.1	23.0	18.2	14.1
		MCWB	9.6	10.5	11.9	14.3	17.3	20.2	21.1	21.1	19.7	17.5	14.4	10.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.6	13.8	15.4	17.3	20.8	23.9	24.8	25.0	23.4	20.9	18.5	15.4
		MCDB	17.0	17.6	21.7	22.3	27.3	30.9	31.7	31.4	28.4	24.2	21.0	19.0
	2%	WB	12.2	12.7	14.0	16.4	19.6	22.7	23.9	24.1	22.1	19.8	17.0	13.9
		MCDB	15.3	16.1	18.7	21.5	25.6	29.9	31.0	30.8	27.5	23.6	20.1	16.5
	5%	WB	10.9	11.9	13.1	15.6	18.7	21.8	23.1	23.2	21.3	18.9	15.9	12.6
		MCDB	13.9	15.2	17.5	20.5	24.5	29.2	30.2	30.0	27.0	22.8	18.9	15.5
	10%	WB	10.0	11.0	12.2	14.9	18.0	21.1	22.4	22.5	20.6	18.1	15.0	11.3
		MCDB	12.4	14.0	16.7	19.3	23.6	28.4	29.8	29.6	26.4	22.0	18.0	13.9
Mean Daily Temperature Range	5% DB	MDBR	8.3	8.8	10.1	10.6	10.9	11.4	11.7	11.6	10.5	9.3	8.6	8.0
		MCDBR	11.4	11.6	13.1	13.1	13.0	13.2	13.2	13.0	12.4	11.4	10.4	10.5
		MCWBR	7.5	7.4	7.1	6.9	6.0	5.8	5.9	5.8	6.4	6.4	6.5	7.0
	5% WB	MCDBR	10.2	10.3	11.8	11.7	11.4	12.0	12.0	11.7	11.2	10.0	9.0	9.3
		MCWBR	7.3	7.1	7.6	7.0	6.0	6.0	6.0	6.2	6.4	6.2	6.1	6.5
Clear-Sky Solar Irradiance	taub	0.358	0.385	0.427	0.471	0.458	0.446	0.452	0.463	0.446	0.418	0.389	0.367	
	taud	2.396	2.283	2.165	2.059	2.166	2.244	2.234	2.197	2.227	2.280	2.315	2.355	
	Ebn at Noon	800	823	824	809	829	837	828	808	796	776	750	754	
	Edh at Noon	87	110	137	162	149	138	138	140	128	109	93	85	
All-Sky Solar Radiation	RadAvg	1.85	2.61	3.86	5.16	6.21	7.09	7.31	6.50	4.76	3.17	2.13	1.61	
	RadStd	0.28	0.32	0.37	0.50	0.32	0.42	0.28	0.25	0.34	0.34	0.24	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.35	N/A	N/A	+0.62	N/A	N/A	N/A	-83	+97	N/A

Nomenclature: See separate page