

ANDRAVIDA, Greece

WMO: 166820

Lat: 37.923N

Lon: 21.288E

Elev: 39

StdP: 14.68

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 32.5	(c) 35.6	(d) 22.9	(e) 17.3	(f) 39.9	(g) 26.5	(h) 20.5	(i) 40.9	(j) 25.2	(k) 55.6	(l) 21.9	(m) 55.6	(n) 1.6	(o) 100	(p) 0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 21.7	(c) 93.2	(d) 70.8	(e) 91.1	(f) 71.1	(g) 89.0	(h) 71.1	(i) 76.1	(j) 85.2	(k) 75.0	(l) 84.3	(m) 73.9	(n) 83.4	(o) 9.8	(p) 300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 73.6	(b) 125.1	(c) 80.4	(d) 71.9	(e) 118.2	(f) 79.7	(g) 71.0	(h) 114.3	(i) 79.2	(j) 39.6	(k) 85.2	(l) 38.5	(m) 84.0	(n) 37.5	(o) 84.1	(p) 81.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 20.4	(b) 17.1	(c) 14.5	(e) 27.5	(f) 98.1	(g) 3.5	(h) 3.0	(i) 24.9	(j) 100.3	(k) 22.9	(l) 102.1	(m) 20.9	(n) 103.8	(o) 18.4	(p) 106.0		
			DB													
			WB													
				25.7	78.2	3.2	1.5	23.4	79.3	21.5	80.2	19.7	81.1	17.3	82.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.1	49.5	50.4	53.6	58.6	66.4	73.3	77.1	78.2	72.9	65.7	58.5	52.0	(6)
(7)		DBStd	11.06	5.14	5.06	4.38	4.35	4.06	4.06	2.96	2.76	3.79	4.52	5.14	5.38	(7)
(8)		HDD50	187	71	51	17	2	0	0	0	0	0	0	5	41	(8)
(9)		HDD65	2120	479	408	354	195	33	1	0	0	1	47	200	402	(9)
(10)		CDD50	4969	56	64	128	262	508	699	840	875	686	486	261	104	(10)
(11)		CDD65	1427	0	0	1	4	76	250	375	410	237	67	6	1	(11)
(12)		CDH74	13858	0	0	7	66	613	2392	3998	4448	1929	387	18	0	(12)
(13)		CDH80	5259	0	0	1	6	108	836	1675	2042	554	35	2	0	(13)
(14)	Wind	WSAvg	5.0	5.2	5.7	5.7	5.1	5.0	4.8	4.9	4.8	4.5	4.0	4.8	5.0	(14)
(15)	Precipitation	PrecAvg	29.5	4.1	3.5	2.4	1.5	0.9	0.3	0.1	0.3	2.0	3.6	5.4	5.4	(15)
(16)		PrecMax	37.2	11.2	10.2	5.9	4.3	2.6	1.9	0.8	2.9	4.3	7.9	11.6	13.0	(16)
(17)		PrecMin	16.3	0.4	0.4	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.4	0.1	0.0	(17)
(18)		PrecStd	5.3	2.3	2.4	1.5	1.0	0.6	0.4	0.2	0.6	1.1	2.1	2.6	2.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.8	68.1	72.0	80.5	86.4	94.6	95.4	98.2	91.4	84.0	76.4	68.4	(19)
(20)			MCWB	57.1	55.4	56.4	60.6	66.1	70.8	71.2	69.9	68.1	67.5	64.3	60.6	(20)
(21)		2%	DB	62.5	64.1	67.8	75.3	82.7	90.3	91.9	93.6	87.8	80.3	73.1	65.9	(21)
(22)			MCWB	56.5	55.7	56.9	59.8	65.2	70.7	71.7	70.9	69.8	66.6	63.4	58.8	(22)
(23)		5%	DB	60.7	61.3	64.8	71.8	80.3	87.7	89.9	91.5	85.7	78.3	70.2	63.0	(23)
(24)			MCWB	54.9	54.6	56.2	59.3	64.8	70.2	72.0	71.0	69.9	65.9	61.8	56.9	(24)
(25)		10%	DB	58.7	59.4	62.8	69.3	77.2	84.6	87.9	89.4	83.2	75.6	68.1	61.0	(25)
(26)			MCWB	53.3	53.2	55.5	58.7	64.1	69.7	71.7	71.2	69.5	64.9	60.4	55.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.4	59.1	60.3	64.3	70.1	75.9	77.4	78.1	76.0	72.0	67.2	62.1	(27)
(28)			MCDWB	62.7	64.0	68.0	73.7	79.6	85.5	86.9	86.3	83.0	77.6	72.7	66.8	(28)
(29)		2%	WB	57.3	57.1	58.8	62.2	68.3	73.8	75.8	76.4	74.0	69.9	64.9	59.8	(29)
(30)			MCDWB	61.4	61.7	65.0	71.3	77.3	84.3	85.4	85.3	82.1	76.1	70.7	64.0	(30)
(31)		5%	WB	55.3	55.6	57.4	60.7	66.8	72.5	74.7	75.3	72.5	68.2	63.2	58.2	(31)
(32)			MCDWB	59.5	60.6	63.2	68.7	76.0	82.9	84.3	84.5	80.9	75.4	68.8	62.5	(32)
(33)		10%	WB	53.5	54.1	56.1	59.4	65.4	71.1	73.6	74.2	71.1	66.7	61.5	56.2	(33)
(34)			MCDWB	57.7	59.1	61.6	66.8	74.6	81.4	83.4	83.6	79.6	73.6	66.9	60.4	(34)
(35)	Mean Daily Temperature Range	MDBR		15.1	15.6	16.9	18.5	20.0	20.9	21.1	21.7	19.3	18.8	16.8	15.2	(35)
(36)		5% DB	MCDBR	15.8	17.1	19.8	23.5	24.4	25.3	24.2	26.0	22.3	20.9	18.6	16.0	(36)
(37)			MCWBR	11.0	10.9	11.9	11.5	10.5	10.6	10.1	10.3	10.0	10.4	11.0	10.8	(37)
(38)		5% WB	MCDWB	14.2	15.7	18.0	20.4	21.3	22.7	21.5	21.4	19.7	17.7	16.5	13.4	(38)
(39)			MCWBR	10.6	10.8	11.7	11.3	10.4	10.6	10.0	10.1	10.2	10.3	11.1	9.9	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.353	0.383	0.424	0.464	0.456	0.434	0.439	0.449	0.432	0.410	0.381	0.361	(40)
(41)		taud		2.434	2.321	2.195	2.099	2.183	2.297	2.287	2.256	2.301	2.331	2.382	2.412	(41)
(42)		Ebn at Noon		260	265	264	260	264	269	267	261	259	252	246	247	(42)
(43)		Edh at Noon		27	34	43	50	47	42	42	42	38	34	29	26	(43)
(44)	All-Sky Solar Radiation	RadAvg		660	927	1366	1790	2134	2421	2483	2206	1666	1166	788	600	(44)
(45)		RadStd		71	93	101	138	101	110	70	66	89	86	67	75	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		+0.43	N/A	N/A	+1.40	-0.86	-1.48	N/A	-121	+180	N/A	
(47)	Regional (8 neighbors)		+0.54	N/A	N/A	+1.40	N/A	N/A	-137	+189	N/A	(47)

Nomenclature: See separate page