

SKIROS, Greece

WMO: 166840

Lat: 38.9629N

Lon: 24.4907E

Elev: 68

StdP: 14.66

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.8	38.7	24.7	18.8	40.9	27.7	21.7	42.3	46.9	37.0	39.4	45.8	14.3	30	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.1	88.3	71.5	86.1	71.5	84.3	71.5	75.8	83.3	74.6	82.2	73.6	81.4	8.5	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.5	124.8	80.9	71.9	118.3	80.2	70.9	114.1	79.7	39.4	83.3	38.3	82.3	37.3	81.4	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
30.9	26.3	22.6	32.7	95.5	3.0	5.2	30.5	99.2	28.7	102.3	27.0	105.2	24.8	109.0
			30.4	78.1	3.0	2.2	28.2	79.7	26.4	81.0	24.7	82.2	22.5	83.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.9	49.6	50.3	53.2	58.3	66.2	73.5	77.6	77.8	72.0	64.7	58.6	52.1	(6)
(7)		DBStd	11.30	5.83	6.09	5.88	5.20	4.83	4.34	3.08	2.90	4.17	4.82	5.35	5.85	(7)
(8)		HDD50	226	77	64	33	3	0	0	0	0	0	0	4	45	(8)
(9)		HDD65	2173	478	411	368	208	41	0	0	0	2	62	202	401	(9)
(10)		CDD50	4937	64	73	131	253	503	705	857	862	661	457	261	110	(10)
(11)		CDD65	1410	0	0	2	8	79	255	392	397	212	54	10	1	(11)
(12)		CDH74	10074	0	0	9	19	312	1702	3449	3393	1055	124	11	0	(12)
(13)		CDH80	2137	0	0	1	2	43	354	844	720	162	10	1	0	(13)
(14)	Wind	WSAvg	9.7	12.0	12.1	10.7	8.6	7.5	7.3	8.3	9.4	9.2	9.7	10.0	12.0	(14)
(15)	Precipitation	PrecAvg	18.4	2.6	2.4	2.1	1.1	0.7	0.6	0.2	0.3	0.9	1.7	2.1	3.7	(15)
(16)		PrecMax	33.6	5.6	7.0	6.5	3.1	2.5	5.2	1.3	1.8	3.8	4.3	5.9	11.0	(16)
(17)		PrecMin	7.9	0.2	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.5	(17)
(18)		PrecStd	6.6	1.4	1.7	1.6	0.8	0.7	1.1	0.3	0.5	1.1	1.4	1.5	2.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.6	66.6	73.1	76.5	84.4	91.8	93.5	90.0	88.0	80.9	75.1	68.8	(19)
(20)		MCWB	56.2	56.4	59.4	59.0	65.4	69.8	71.5	73.5	70.2	67.5	62.9	60.3	(20)	
(21)		2%	DB	62.3	63.0	67.6	72.3	80.5	86.2	89.3	87.4	84.1	77.2	71.4	65.1	(21)
(22)		MCWB	56.0	55.3	56.7	58.6	64.3	69.2	71.4	73.0	70.6	67.3	62.9	58.4	(22)	
(23)		5%	DB	60.5	61.1	64.5	69.8	77.2	83.6	86.1	85.6	81.0	74.7	69.2	63.0	(23)
(24)		MCWB	54.7	54.5	55.3	58.3	63.2	69.1	71.6	72.9	69.9	66.4	62.2	57.1	(24)	
(25)		10%	DB	58.7	59.2	62.3	66.9	74.9	81.2	84.2	83.9	79.1	72.0	66.6	60.9	(25)
(26)		MCWB	53.4	53.5	54.5	57.2	62.7	69.0	71.8	72.6	68.9	65.1	61.1	55.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.2	58.3	60.8	63.2	69.4	75.4	77.4	77.9	76.0	71.3	66.1	61.5	(27)
(28)		MCDWB	62.6	63.6	69.9	70.7	78.8	84.2	85.4	84.9	82.4	77.4	71.3	66.5	(28)	
(29)		2%	WB	56.5	56.6	58.1	61.0	66.9	73.4	75.5	76.1	73.3	69.0	64.3	59.4	(29)
(30)		MCDWB	61.0	61.6	64.9	68.6	75.0	81.4	83.4	83.3	79.7	74.5	69.3	64.2	(30)	
(31)		5%	WB	55.2	55.3	56.5	59.5	65.6	72.0	74.4	74.9	71.8	67.4	63.0	57.6	(31)
(32)		MCDWB	59.7	60.3	62.5	66.6	73.4	79.8	82.4	82.3	78.3	72.7	67.8	62.3	(32)	
(33)		10%	WB	53.6	54.0	55.1	58.5	64.4	70.7	73.3	73.9	70.3	65.8	61.5	55.8	(33)
(34)		MCDWB	58.0	58.7	60.8	65.1	72.3	78.7	81.4	81.6	77.3	70.9	66.1	60.2	(34)	
(35)	Mean Daily Temperature Range	MDBR	9.1	9.4	10.2	11.3	12.2	12.1	11.1	10.1	10.6	9.5	9.5	8.7	(35)	
(36)		5% DB	MCDBR	10.9	11.7	13.5	15.2	16.0	15.8	15.0	12.7	14.1	13.6	11.7	10.8	(36)
(37)		MCWBR	7.5	7.8	7.8	8.7	8.4	8.7	9.3	7.8	9.0	8.2	7.1	7.4	(37)	
(38)		5% WB	MCDBR	10.0	10.8	12.0	13.4	13.6	12.6	12.1	11.0	12.4	12.0	10.3	9.7	(38)
(39)		MCWBR	7.6	7.9	8.0	8.9	8.5	8.2	8.5	7.7	8.8	8.2	7.1	7.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.368	0.394	0.431	0.469	0.446	0.424	0.426	0.435	0.429	0.415	0.392	0.377	(40)	
(41)		taud	2.375	2.280	2.187	2.102	2.241	2.347	2.348	2.315	2.322	2.315	2.324	2.337	(41)	
(42)		Ebn at Noon	251	259	260	258	266	272	270	265	259	248	238	236	(42)	
(43)		Edh at Noon	28	35	43	49	44	39	39	39	37	34	30	28	(43)	
(44)	All-Sky Solar Radiation	RadAvg	555	814	1272	1718	2107	2365	2390	2114	1616	1081	705	484	(44)	
(45)		RadStd	75	104	108	166	98	115	61	44	85	91	68	74	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (10 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	-205	+175	N/A	

Nomenclature: See separate page