

ARAXOS, Greece

WMO: 166870

Lat: 38.1492N

Lon: 21.4222E

Elev: 11

StdP: 101.19

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.0	2.8	-5.1	2.5	5.5	-3.0	2.9	6.0	10.2	11.5	9.2	11.7	0.4	90	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.3	35.1	21.7	33.9	21.6	32.2	21.8	24.9	30.2	24.2	29.5	23.6	29.0	4.4	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	18.0	27.6	22.8	17.5	27.4	21.9	16.6	26.7	75.8	30.0	72.9	29.2	70.2	29.4	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.6	7.6	6.7	-1.5	37.9	1.5	1.5	-2.6	38.9	-3.4	39.8	-4.3	40.6	-5.3	41.7		
			-2.7	26.4	1.6	1.2	-3.8	27.3	-4.8	28.0	-5.6	28.6	-6.8	29.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.6	9.9	10.4	12.1	15.0	19.3	23.5	26.0	26.6	22.9	19.0	14.9	11.2
	DBStd	6.40	2.75	2.75	2.43	2.54	2.40	2.68	2.05	2.07	2.28	2.48	2.79	2.84
	HDD10.0	92	35	25	8	1	0	0	0	0	0	2	20	
	HDD18.3	1148	261	221	192	104	18	1	0	0	1	108	221	
	CDD10.0	2869	32	37	74	151	287	404	497	516	388	279	148	57
	CDD18.3	885	0	0	0	3	47	155	238	257	138	42	3	1
	CDH23.3	8999	0	0	4	26	337	1553	2754	3001	1124	191	9	0
	CDH26.7	3671	0	0	1	3	57	584	1264	1427	321	13	1	0
Wind	WSAvg	2.1	2.4	2.6	2.5	2.2	1.9	1.8	1.8	2.0	1.8	2.1	2.1	2.3
Precipitation	PrecAvg	659	89	80	60	40	20	8	4	4	29	81	135	126
	PrecMax	1208	222	180	165	124	70	60	35	41	106	235	377	341
	PrecMin	293	0	5	0	1	0	0	0	0	0	6	14	20
	PrecStd	177	58	44	37	27	18	14	8	9	30	51	78	77
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.9	19.9	22.1	26.2	30.1	35.8	37.0	37.8	33.2	28.1	24.8	20.2
		MCWB	14.7	14.5	14.8	17.0	19.3	22.0	21.5	22.1	20.7	20.0	18.9	16.3
	2%	DB	17.0	17.7	19.8	23.2	28.1	33.8	35.0	35.8	31.1	26.2	22.2	18.8
		MCWB	13.6	13.6	14.3	16.1	19.1	21.8	22.1	21.6	21.3	19.4	17.4	15.3
	5%	DB	15.8	16.2	18.2	22.0	26.8	31.8	33.8	34.0	29.9	25.2	21.1	17.1
		MCWB	13.0	12.7	13.7	15.5	18.8	21.4	21.9	21.3	21.5	18.9	17.0	14.2
	10%	DB	14.8	15.2	17.1	20.2	25.1	30.0	32.1	32.8	28.2	24.1	20.0	16.1
		MCWB	11.9	11.9	13.2	14.9	18.6	21.3	22.0	21.7	21.0	18.4	16.0	13.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.5	15.2	16.5	18.6	22.1	24.7	26.1	26.1	24.9	22.2	19.6	17.0
		MCDB	17.6	17.8	20.1	23.3	27.3	30.8	31.4	31.2	29.0	25.7	22.9	19.5
	2%	WB	14.2	14.1	15.2	17.2	20.7	23.7	25.0	24.9	23.7	21.1	18.4	15.7
		MCDB	16.3	16.8	18.3	21.6	25.4	29.6	30.6	29.9	27.8	24.4	21.5	17.8
	5%	WB	13.1	13.2	14.3	16.2	19.7	22.8	24.2	24.2	22.8	20.3	17.5	14.7
		MCDB	15.3	15.8	17.4	20.5	24.6	28.6	29.7	29.5	27.0	23.7	20.4	16.9
	10%	WB	12.1	12.4	13.6	15.5	19.0	22.1	23.5	23.6	22.1	19.5	16.5	13.7
		MCDB	14.2	15.0	16.5	19.5	23.8	27.9	29.0	29.0	26.5	22.9	19.3	15.8
Mean Daily Temperature Range	5% DB	MDBR	7.7	7.9	8.7	9.6	10.4	11.2	11.5	11.3	10.1	9.2	8.6	7.9
		MCDBR	8.9	9.0	10.6	11.9	12.6	13.4	13.3	13.2	11.9	10.3	9.8	8.9
		MCWBR	6.1	5.8	6.5	6.2	5.9	5.6	5.0	4.8	5.4	5.3	6.0	6.2
	5% WB	MCDBR	8.3	8.4	9.9	11.1	11.5	12.2	11.8	11.6	10.7	9.5	9.2	8.0
		MCWBR	6.1	5.7	6.6	6.5	6.2	5.9	5.6	5.5	5.7	5.6	6.0	6.0
Clear-Sky Solar Irradiance	taub	0.351	0.381	0.423	0.464	0.457	0.436	0.441	0.451	0.432	0.409	0.378	0.358	
	taud	2.437	2.321	2.194	2.093	2.175	2.284	2.274	2.244	2.292	2.330	2.383	2.414	
	Ebn at Noon	821	837	833	819	832	847	839	822	815	795	777	780	
	Edh at Noon	85	108	134	157	148	133	133	134	121	106	89	82	
All-Sky Solar Radiation	RadAvg	2.05	2.88	4.23	5.58	6.61	7.53	7.75	6.91	5.19	3.63	2.45	1.87	
	RadStd	0.24	0.31	0.33	0.44	0.32	0.36	0.25	0.22	0.29	0.28	0.21	0.25	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.23	N/A	N/A	+0.76	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	+0.32	N/A	N/A	+0.77	N/A	N/A	N/A	-78	+100	N/A

Nomenclature: See separate page