

SAMOS, Greece

WMO: 167230

Lat: 37.690N

Lon: 26.912E

Elev: 6

StdP: 101.26

Time Zone: 2.00 (EUE)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.4	3.9	-7.0	2.1	5.2	-5.1	2.5	5.9	13.4	11.3	12.6	10.9	4.0	0	0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	36.1	21.8	34.8	21.5	33.5	21.1	25.2	31.7	23.8	30.6	22.7	29.8	6.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.2	17.9	29.6	21.8	16.5	27.9	20.2	14.9	27.0	77.4	31.8	71.5	30.5	67.5	29.6	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.8	10.0	9.3	DB 0.3	39.4	1.6	1.9	-0.9	40.7	-1.9	41.8	-2.8	42.9	-4.0	44.2		
(5)			WB -1.7	25.2	1.6	1.1	-2.9	26.0	-3.8	26.6	-4.7	27.2	-5.8	28.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	10.6	10.6	12.0	15.0	20.5	25.6	28.6	28.4	24.1	19.6	14.9	12.1		
	DBStd	7.18	3.29	3.12	2.85	2.76	2.79	2.68	2.18	2.52	2.49	2.90	3.30	3.23		
	HDD10.0	99	32	28	13	2	0	0	0	0	0	0	7	18		
	HDD18.3	1088	240	216	198	103	10	0	0	0	0	21	106	194		
	CDD10.0	3221	51	45	74	153	327	467	575	572	423	297	155	83		
	CDD18.3	1168	0	0	1	4	78	217	317	313	173	60	4	0		
	CDH23.3	12079	0	0	1	17	499	2222	3952	3818	1345	224	2	0		
	CDH26.7	5175	0	0	0	1	103	870	1937	1851	387	27	0	0		
(14) Wind	WSAvg	4.6	4.7	4.8	4.7	3.6	3.8	4.7	5.3	5.5	4.2	4.2	4.2	5.1		
(15) Precipitation	PrecAvg	718	132	104	75	51	35	2	0	0	10	45	103	161		
	PrecMax	1026	320	230	164	114	129	12	7	2	62	147	427	394		
	PrecMin	405	21	24	8	10	11	0	0	0	6	13	22	22		
	PrecStd	156	74	62	46	31	27	3	1	1	17	35	82	82		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.2	18.1	21.8	25.9	31.0	36.1	38.8	38.3	33.9	29.2	23.2	19.3		
		MCWB	14.1	13.2	14.5	16.0	18.2	22.2	21.8	21.7	19.8	18.7	17.0	15.2		
	2%	DB	17.2	17.1	19.2	23.2	29.1	34.2	36.0	36.3	31.9	27.0	21.9	18.5		
		MCWB	13.8	13.0	13.7	14.8	17.9	20.7	22.0	21.5	19.3	18.3	16.8	14.8		
	5%	DB	16.8	16.2	18.0	21.8	27.8	32.9	34.8	34.9	30.2	25.3	20.9	17.9		
		MCWB	13.6	12.8	12.7	14.8	17.7	20.2	21.9	21.2	19.2	18.1	16.5	14.6		
	10%	DB	15.9	15.7	17.0	20.1	26.1	31.2	33.4	33.3	29.0	24.2	20.0	17.0		
		MCWB	12.9	12.5	12.7	14.4	16.9	19.4	21.6	21.1	18.8	17.8	16.1	14.0		
	0.4%	WB	15.3	14.7	15.7	17.2	20.0	27.1	27.4	26.0	23.1	21.7	18.8	16.4		
		MCDB	17.3	16.9	19.6	22.4	26.7	34.2	33.5	32.2	27.1	25.3	21.4	18.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	14.4	13.9	14.8	16.2	19.3	23.6	25.9	24.4	22.2	20.7	18.1	15.4		
		MCDB	16.8	16.1	17.9	20.8	25.8	29.7	32.3	31.1	26.6	24.3	20.8	17.8		
	5%	WB	13.6	13.2	14.0	15.6	18.7	21.7	24.4	23.3	21.5	19.9	17.4	14.8		
		MCDB	16.2	15.7	17.0	20.0	24.9	27.9	31.1	30.6	26.5	23.7	20.1	17.3		
	10%	WB	12.8	12.6	13.2	15.0	18.1	20.7	23.1	22.5	20.7	19.1	16.5	14.0		
		MCDB	15.5	15.3	16.4	19.2	24.1	28.4	30.3	30.5	26.4	23.1	19.4	16.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.8	6.4	7.0	7.9	9.3	9.7	9.5	9.4	8.7	7.5	6.8	5.4		
		MCDBR	5.7	6.8	8.4	10.3	10.8	10.8	10.5	10.4	9.9	8.6	7.3	5.6		
		MCWBR	4.1	4.9	5.3	5.2	4.6	5.0	4.9	4.3	4.5	4.8	4.8	4.1		
	5% WB	MCDBR	5.7	6.1	7.4	8.7	9.8	10.3	9.8	9.7	8.9	7.6	6.5	4.5		
		MCWBR	4.6	4.9	5.5	5.3	5.0	6.1	6.4	5.2	5.5	5.4	4.9	3.8		
(40) Clear-Sky Solar Irradiance	taub		0.367	0.401	0.438	0.474	0.452	0.414	0.411	0.418	0.410	0.409	0.386	0.372		
	taud		2.374	2.257	2.145	2.081	2.204	2.361	2.369	2.338	2.362	2.329	2.350	2.370		
	Ebn at Noon		801	816	819	811	836	867	866	852	839	798	770	765		
	Edh at Noon		91	116	142	160	144	123	121	122	113	106	93	86		
(44) All-Sky Solar Radiation	RadAvg		2.16	2.96	4.45	5.80	7.02	7.95	8.04	7.13	5.71	4.05	2.70	1.98		
	RadStd		0.23	0.26	0.28	0.48	0.34	0.32	0.12	0.12	0.25	0.20	0.20	0.27		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-62	N/A	N/A

Nomenclature: See separate page