

NAXOS, Greece

WMO: 167320

Lat: 37.1014N

Lon: 25.3731E

Elev: 32

StdP: 14.68

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	43.7	45.8	30.0	24.1	46.3	32.9	27.5	48.1	53.4	48.2	48.2	50.3	23.8	0	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.8	86.2	72.1	84.3	72.1	82.7	71.7	75.4	82.9	74.4	81.8	73.5	80.7	10.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.8	121.8	81.0	71.7	117.3	80.2	70.8	113.5	79.6	38.9	83.1	38.0	82.1	37.1	80.8	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
43.2	37.7	32.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.6	54.4	55.5	56.7	60.5	68.1	74.6	77.7	77.6	75.2	67.8	61.5	56.4
	DBStd	9.51	4.58	4.25	4.33	4.41	3.43	3.61	2.68	2.35	3.20	3.65	4.43	4.41
	HDD50	34	16	6	4	1	0	0	0	0	0	0	1	6
	HDD65	1410	328	267	258	145	10	0	0	0	0	15	118	269
	CDD50	5713	153	160	213	316	560	737	859	856	757	552	346	204
	CDD65	1614	0	1	1	11	106	287	394	391	307	102	13	1
	CDH74	9508	0	1	1	14	233	1613	2954	2888	1672	128	4	0
	CDH80	1287	0	0	0	0	19	276	472	326	189	5	0	0
(14) Wind	WSAvg	15.2	17.0	17.3	17.3	13.6	11.9	11.9	15.3	15.1	13.0	16.9	15.4	17.8
(15) Precipitation	PrecAvg	14.4	2.5	2.5	1.6	0.7	0.5	0.0	0.0	0.0	0.3	1.4	2.0	2.7
	PrecMax	21.9	6.1	6.1	3.9	3.0	2.2	0.6	1.1	0.2	1.5	7.4	5.1	5.0
	PrecMin	8.5	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.2
	PrecStd	3.2	1.3	1.6	1.1	0.7	0.5	0.1	0.2	0.0	0.4	1.7	1.4	1.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.3	68.8	70.4	76.1	82.6	89.3	90.9	87.3	87.1	79.9	73.3	69.1
		MCWB	57.5	56.6	58.2	61.5	64.7	71.8	70.5	72.3	72.4	68.0	63.3	60.6
	2%	DB	63.7	65.4	67.1	72.1	79.0	85.1	86.4	84.6	83.6	77.0	71.4	66.3
		MCWB	57.6	57.0	56.9	60.9	64.8	70.7	72.4	73.5	72.2	69.6	63.8	59.7
	5%	DB	62.3	63.2	65.0	69.9	76.5	82.9	84.3	83.0	82.0	75.1	69.5	64.3
		MCWB	57.2	56.8	56.8	60.2	64.9	70.2	72.0	73.1	71.7	68.8	62.7	58.4
	10%	DB	61.0	61.8	63.1	67.7	74.4	80.9	82.5	81.6	80.5	73.2	67.9	62.7
		MCWB	56.0	56.1	56.3	59.3	64.4	69.6	71.9	72.6	71.1	66.8	61.8	57.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.7	60.1	60.5	64.7	69.1	75.3	76.4	76.8	75.5	72.7	66.6	62.7
		MCDB	63.2	65.3	65.2	70.7	77.8	85.3	83.8	83.0	83.1	76.8	70.8	67.2
	2%	WB	59.1	58.7	59.1	62.7	67.7	73.0	75.3	75.4	74.0	70.8	64.8	60.6
		MCDB	62.3	63.3	64.2	70.0	75.4	82.0	82.8	82.5	81.2	75.3	69.9	64.7
	5%	WB	57.7	57.6	58.1	61.5	66.6	71.9	74.2	74.4	73.0	69.1	63.3	59.2
		MCDB	61.6	62.2	63.5	68.2	73.6	80.2	81.8	81.5	79.9	74.4	68.5	63.8
	10%	WB	56.3	56.5	57.1	60.2	65.6	70.9	73.0	73.5	72.1	67.3	62.1	57.7
		MCDB	60.5	61.2	62.8	66.6	72.4	79.2	80.7	80.5	79.1	72.6	67.3	62.3
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	7.3	7.4	8.7	9.0	8.6	6.8	5.7	7.4	5.5	7.1	6.3
		MCDBR	9.3	10.3	10.7	12.8	13.6	12.2	10.9	9.0	11.0	9.1	10.2	8.9
		MCWBR	6.5	6.9	6.8	9.2	7.8	7.9	7.2	6.7	7.8	6.8	6.5	5.9
	5% WB	MCDBR	8.3	9.5	9.1	11.9	10.7	10.3	9.4	7.5	9.7	7.9	8.6	7.9
		MCWBR	6.5	7.2	6.8	9.0	7.0	7.7	7.0	6.2	7.7	6.6	6.1	5.7
(40) Clear-Sky Solar Irradiance	taub		0.362	0.391	0.427	0.459	0.440	0.407	0.408	0.411	0.412	0.405	0.386	0.369
	taud		2.406	2.305	2.197	2.135	2.253	2.391	2.391	2.370	2.376	2.353	2.367	2.394
	Ebn at Noon		258	264	264	262	269	277	276	273	266	256	246	246
	Edh at Noon		28	35	43	48	43	38	38	38	36	33	29	27
(44) All-Sky Solar Radiation	RadAvg		674	916	1400	1826	2177	2459	2451	2183	1757	1232	829	607
	RadStd		61	87	85	133	98	84	35	30	75	60	58	65

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	+0.67	N/A	N/A	N/A	N/A	+0.59	+0.67	N/A	-137	+169	N/A

Nomenclature: See separate page