

METHONI, Greece

WMO: 167340

Lat: 36.825N

Lon: 21.704E

Elev: 170

StdP: 14.61

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.2	41.9	20.9	15.7	47.5	26.2	20.3	48.1	31.3	55.6	27.6	55.6	8.5	50	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.1	87.8	72.4	85.9	73.5	84.5	73.5	77.4	83.2	76.3	82.4	75.3	81.6	10.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.6	134.7	81.6	74.4	129.2	80.8	73.2	123.9	79.9	41.0	83.1	39.9	82.6	38.9	81.6	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.9	21.7	19.0	DB	35.0	94.9	1.8	5.0	33.7	98.6	32.7	101.5	31.7	104.3	30.5	108.0
			WB	31.4	78.7	2.7	1.7	29.4	79.9	27.9	80.9	26.4	81.9	24.4	83.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.5	52.6	53.3	55.2	59.7	66.0	72.7	77.0	79.1	74.6	67.6	61.1	54.7
	DBStd	10.08	4.47	4.02	4.20	4.35	3.75	3.77	2.83	2.64	3.45	4.36	4.50	4.42
	HDD50	61	25	13	9	1	0	0	0	0	0	0	1	12
	HDD65	1691	384	329	303	168	33	0	0	0	0	26	128	320
	CDD50	5362	106	104	171	292	497	682	836	901	737	546	333	157
	CDD65	1518	0	0	1	10	64	232	371	436	287	107	10	0
	CDH74	10340	0	0	2	36	134	1221	2802	4065	1799	279	2	0
	CDH80	2254	0	0	0	5	13	215	575	1163	276	7	0	0
Wind	WSAvg	9.2	9.3	9.5	9.3	9.5	8.9	9.4	9.9	9.1	9.2	7.9	8.8	9.3
Precipitation	PrecAvg	27.1	4.3	3.3	2.5	1.3	0.6	0.1	0.0	0.1	1.3	3.6	4.4	5.5
	PrecMax	40.7	8.7	7.2	6.5	3.4	2.5	0.6	0.3	1.2	7.1	20.6	11.7	13.6
	PrecMin	15.8	0.9	0.5	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.2	0.3	1.4
	PrecStd	5.9	1.9	1.6	1.4	0.9	0.6	0.1	0.0	0.2	1.7	3.4	2.4	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.8	68.1	71.2	78.3	81.7	89.3	90.4	93.5	86.1	81.1	74.2	67.8
		MCWB	58.8	54.1	58.1	56.1	62.7	69.3	69.0	69.7	72.6	69.2	63.7	60.6
	2%	DB	62.6	63.5	66.0	72.9	77.3	84.6	86.3	88.8	84.3	78.7	72.2	65.1
		MCWB	57.0	55.8	57.2	58.7	63.7	70.5	73.2	72.3	73.2	69.5	64.2	59.2
	5%	DB	61.2	61.5	63.6	69.6	74.7	82.2	84.7	86.8	83.0	77.0	70.5	63.6
		MCWB	55.9	55.3	56.8	58.3	65.3	71.0	73.7	73.7	72.8	68.5	63.3	58.0
	10%	DB	60.0	59.9	62.0	67.3	72.9	79.9	83.3	85.3	81.6	75.3	68.6	62.2
		MCWB	54.9	54.3	56.2	57.9	64.8	70.5	73.4	74.0	72.1	67.0	62.1	56.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.4	59.1	60.8	63.1	70.2	76.7	78.2	79.4	77.0	73.6	67.2	62.3
		MCDB	64.0	63.0	67.0	69.7	75.1	82.5	83.7	85.0	82.6	77.5	71.1	65.7
	2%	WB	58.7	57.8	59.1	61.6	68.4	74.2	77.0	77.9	75.6	71.6	65.6	60.6
		MCDB	61.5	61.8	63.5	68.1	73.4	80.3	82.6	83.8	81.6	76.5	70.1	63.8
	5%	WB	57.2	56.5	58.0	60.5	67.2	72.8	75.8	76.7	74.4	70.0	64.3	59.2
		MCDB	60.4	60.5	62.2	66.5	72.3	78.9	81.8	82.9	80.6	75.1	69.1	62.6
	10%	WB	55.7	55.4	56.9	59.3	65.9	71.6	74.7	75.7	73.2	68.1	62.8	57.6
		MCDB	59.5	59.2	61.1	64.9	71.1	77.6	80.9	82.1	79.5	73.7	67.4	61.5
Mean Daily Temperature Range	5% DB	MDBR	11.3	10.9	11.3	12.1	11.5	11.4	11.0	12.1	12.2	13.1	11.9	11.5
		MCDBR	11.6	11.5	12.8	15.2	13.8	15.3	13.2	14.8	13.4	14.1	13.4	12.0
		MCWBR	8.3	7.7	8.0	8.6	8.5	9.7	8.6	9.3	8.0	8.3	8.1	8.1
	5% WB	MCDBR	9.8	10.3	10.9	12.5	11.2	11.8	11.1	11.6	11.4	12.0	11.1	9.6
		MCWBR	7.9	7.8	7.8	8.7	8.5	9.2	8.2	8.8	8.2	8.3	8.3	8.0
Clear-Sky Solar Irradiance	taub	0.355	0.383	0.427	0.461	0.453	0.428	0.432	0.446	0.430	0.410	0.383	0.364	
	taud	2.434	2.331	2.191	2.115	2.200	2.321	2.313	2.275	2.318	2.339	2.382	2.412	
	Ebn at Noon	262	267	265	262	266	272	269	263	261	254	249	249	
	Edh at Noon	28	34	43	49	46	41	41	42	38	34	29	27	
All-Sky Solar Radiation	RadAvg	704	963	1427	1858	2178	2448	2489	2209	1707	1198	821	632	
	RadStd	67	81	95	132	98	99	52	56	83	80	74	56	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.47	N/A	N/A	+1.26	-0.63	-1.01	N/A	-121	+167	N/A

Nomenclature: See separate page