

MILOS, Greece

WMO: 167380

Lat: 36.739N

Lon: 24.429E

Elev: 547

StdP: 14.41

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	40.1	42.3	22.5	17.3	44.2	26.1	20.4	46.3	43.5	44.5	41.6	46.9	25.2	0	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	92.1	66.8	89.2	66.7	87.0	66.8	73.9	81.9	72.6	80.8	71.5	79.9	8.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.5	118.5	78.9	69.9	112.3	77.7	68.5	106.9	76.9	37.9	81.5	36.6	81.1	35.6	79.5	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.2	33.6	30.7	DB	38.9	98.7	3.4	3.2	36.5	101.0	34.5	102.9	32.6	104.6	30.1	106.9	(4)
(5)			WB	34.7	76.2	3.7	2.4	32.0	78.0	29.8	79.4	27.7	80.7	24.9	82.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	52.0	52.3	54.7	59.7	68.2	75.6	79.9	79.5	75.3	67.8	60.8	54.5
	DBStd	11.23	4.87	4.75	5.23	4.91	4.61	4.33	3.63	3.11	3.78	4.81	5.39	4.85
	HDD50	109	36	31	17	2	0	0	0	0	0	0	3	20
	HDD65	1765	403	355	321	168	20	0	0	0	0	27	144	327
	CDD50	5616	98	95	163	293	564	767	928	915	758	552	325	158
	CDD65	1798	0	0	2	9	118	317	463	450	308	114	17	0
	CDH74	12980	0	0	6	28	512	2297	4330	3856	1685	257	9	0
	CDH80	3839	0	0	1	1	90	686	1535	1151	355	20	0	0
Wind	WSAvg	13.1	15.2	15.9	15.0	12.1	10.9	11.7	12.9	13.4	10.2	12.5	12.1	15.2
Precipitation	PrecAvg	16.1	3.0	2.0	1.9	0.9	0.5	0.1	0.0	0.0	0.2	1.7	2.4	3.5
	PrecMax	22.4	10.2	5.4	3.9	4.3	2.8	1.2	0.2	0.2	1.8	6.9	6.9	9.5
	PrecMin	9.4	0.1	0.1	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.8
	PrecStd	3.3	2.0	1.2	1.0	1.0	0.7	0.2	0.0	0.0	0.4	1.7	2.0	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.6	64.1	72.8	77.9	87.1	94.1	97.7	94.7	91.5	82.5	75.8	66.4
		MCWB	56.1	55.6	55.2	58.6	63.4	65.7	66.1	69.8	66.4	65.7	63.5	59.1
	2%	DB	61.2	61.7	67.0	72.9	82.1	89.4	92.8	90.5	86.4	79.5	72.1	63.9
		MCWB	55.0	54.5	55.4	58.1	62.0	64.6	66.4	68.2	67.7	66.2	63.7	58.4
	5%	DB	59.8	60.1	63.8	70.0	79.1	86.3	89.7	87.9	83.7	76.9	69.6	62.2
		MCWB	54.6	53.8	55.3	57.1	60.7	64.5	66.4	68.2	68.1	65.6	62.2	57.0
	10%	DB	58.5	58.6	61.5	67.4	76.4	83.8	87.2	85.7	81.6	74.3	67.7	60.8
		MCWB	54.0	53.2	54.2	56.2	60.0	64.7	66.8	68.5	67.4	65.2	61.5	56.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.4	57.9	59.4	62.9	67.1	73.0	75.8	77.2	74.5	72.6	67.2	61.4
		MCDB	61.4	62.2	65.7	71.1	77.2	82.9	82.5	86.6	81.0	77.9	72.6	64.6
	2%	WB	57.0	56.2	57.8	60.6	65.2	70.7	72.9	74.5	72.5	70.1	65.1	59.6
		MCDB	59.9	60.0	63.3	68.3	76.1	80.4	81.8	82.9	79.0	75.5	69.9	62.7
	5%	WB	55.7	55.0	56.4	59.2	63.8	69.1	71.4	72.9	71.3	68.3	63.8	58.2
		MCDB	58.9	58.5	61.6	65.8	73.3	78.9	81.3	81.6	78.3	73.5	68.3	61.4
	10%	WB	54.5	54.0	55.2	58.0	62.6	67.8	70.1	71.9	70.2	66.9	62.4	57.0
		MCDB	58.1	57.7	60.2	64.6	71.3	77.8	80.7	80.4	77.8	72.2	66.6	60.3
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.1	8.5	10.7	12.9	13.6	12.6	10.9	10.7	8.7	7.2	6.3
		MCDBR	8.0	9.1	11.9	14.6	16.7	16.9	16.6	14.3	14.0	11.6	9.7	8.4
		MCWBR	5.4	6.1	6.7	7.0	6.8	7.0	6.9	6.7	6.8	5.9	5.7	5.9
	5% WB	MCDBR	7.3	8.4	10.4	12.3	14.1	13.6	12.6	11.6	12.2	10.7	9.3	8.1
		MCWBR	5.8	6.4	7.0	7.1	6.8	7.0	7.6	6.1	6.8	6.3	6.1	6.5
Clear-Sky Solar Irradiance	taub	0.356	0.382	0.419	0.447	0.431	0.401	0.403	0.407	0.410	0.399	0.380	0.364	
	taud	2.426	2.336	2.221	2.164	2.275	2.401	2.401	2.381	2.381	2.370	2.385	2.402	
	Ebn at Noon	262	268	267	266	272	279	278	274	267	259	250	249	
	Edh at Noon	28	34	42	47	43	37	37	37	36	33	29	27	
All-Sky Solar Radiation	RadAvg	694	945	1431	1872	2213	2503	2494	2230	1784	1239	825	610	
	RadStd	62	96	95	130	94	83	38	38	81	66	70	63	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	+0.59	N/A	N/A	N/A	+0.81	+0.85	N/A	-126	N/A	N/A

Nomenclature: See separate page