

KOS, Greece

WMO: 167420

Lat: 36.793N

Lon: 27.092E

Elev: 412

StdP: 14.48

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 39.1	(c) 41.2	(d) 22.6	(e) 17.2	(f) 41.6	(g) 25.2	(h) 19.5	(i) 43.2	(j) 30.7	(k) 53.1	(l) 28.2	(m) 54.3	(n) 14.8	(o) 0	(p) 0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 13.8	(c) 92.8	(d) 70.6	(e) 89.8	(f) 70.2	(g) 87.8	(h) 70.0	(i) 75.3	(j) 83.2	(k) 74.3	(l) 82.2	(m) 73.4	(n) 81.1	(o) 12.6	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.4	126.2	77.8	71.9	119.8	77.3	71.3	117.4	77.1	39.0	83.2	38.0	81.6	37.2	81.6	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 25.2	(b) 22.4	(c) 20.4	(e) 36.2	(f) 98.0	(g) 3.9	(h) 3.6	(i) 33.4	(j) 100.5	(k) 31.1	(l) 102.6	(m) 28.9	(n) 104.6	(o) 26.0	(p) 107.2		
(4) 25.2	(5) 22.4	(6) 20.4	(7) 36.2	(8) 98.0	(9) 3.9	(10) 3.6	(11) 33.4	(12) 100.5	(13) 31.1	(14) 102.6	(15) 28.9	(16) 104.6	(17) 26.0	(18) 107.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.9	52.5	52.9	55.9	61.1	68.6	76.4	80.4	80.7	75.5	68.6	61.5	55.3
	DBStd	11.13	5.23	5.23	4.51	4.50	4.14	4.29	3.22	3.04	3.62	4.44	5.07	5.29
	HDD50	99	37	30	11	1	0	0	0	0	0	0	3	17
	HDD65	1596	387	338	283	131	13	0	0	0	0	20	122	302
	CDD50	5891	114	112	193	333	578	793	943	951	766	577	349	182
	CDD65	1913	0	0	0	13	126	343	478	486	316	132	18	1
	CDH74	14019	0	0	0	29	461	2528	4483	4453	1772	282	11	0
	CDH80	4526	0	0	0	1	70	785	1667	1600	383	20	0	0
Wind	WSAvg	10.3	10.4	10.8	10.6	9.5	9.2	10.9	12.3	11.7	10.2	9.1	8.8	10.0
Precipitation	PrecAvg	27.0	6.5	4.8	3.1	1.5	0.6	0.2	0.0	0.0	0.4	2.2	3.1	5.9
	PrecMax	44.3	15.9	10.2	6.5	6.6	3.9	1.7	0.3	1.0	3.1	16.9	8.6	14.0
	PrecMin	9.2	0.1	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	1.0
	PrecStd	8.0	4.1	2.4	1.9	1.5	0.8	0.4	0.1	0.2	0.9	3.3	2.1	3.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.1	65.5	68.6	77.3	86.0	95.0	96.9	96.3	90.0	82.5	75.4	68.0
		MCWB	57.7	57.6	57.8	62.2	65.3	70.9	70.7	70.9	69.5	66.5	65.4	61.2
	2%	DB	62.5	62.8	66.0	73.5	81.9	90.0	92.8	91.8	86.3	79.0	72.0	66.1
		MCWB	56.6	56.4	56.8	60.0	64.6	69.3	70.5	71.5	69.4	66.7	64.1	60.3
	5%	DB	60.9	61.1	64.2	70.2	78.8	87.4	89.8	89.6	84.1	77.0	70.0	64.3
		MCWB	55.6	55.5	56.3	59.1	64.1	68.7	70.0	70.9	68.9	66.3	63.2	58.4
	10%	DB	59.3	59.5	62.5	68.0	76.6	84.3	87.7	87.5	82.1	75.2	68.2	62.6
		MCWB	54.2	54.3	55.5	58.5	63.7	68.4	70.0	71.0	68.8	65.4	62.0	57.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.3	59.6	60.1	64.6	68.9	74.9	76.3	77.1	74.8	71.6	67.5	63.0
		MCDB	62.6	63.6	65.2	73.5	79.1	85.4	84.8	84.9	81.4	76.4	71.8	66.9
	2%	WB	57.5	57.8	58.9	62.1	67.3	72.7	74.7	75.7	73.4	70.0	65.8	61.0
		MCDB	61.0	61.6	63.3	69.9	76.3	82.5	83.3	83.2	79.1	74.6	70.3	65.0
	5%	WB	56.2	56.4	57.5	60.7	66.1	71.5	73.8	74.7	72.3	68.8	64.4	59.2
		MCDB	60.0	60.4	62.1	67.3	74.6	80.4	82.2	82.1	78.3	73.8	69.2	63.0
	10%	WB	54.9	55.0	56.6	59.7	65.1	70.4	72.8	73.9	71.1	67.4	62.9	57.6
		MCDB	59.0	59.3	61.2	65.8	73.1	79.7	81.3	81.4	77.5	72.8	67.7	61.7
Mean Daily Temperature Range	5% DB	MDBR	8.3	8.8	9.5	11.2	12.8	13.9	14.6	13.8	12.0	10.5	9.4	8.0
		MCDBR	8.9	9.7	10.9	14.1	16.0	17.4	17.3	16.5	14.2	12.1	10.8	8.8
		MCWBR	6.6	6.7	6.9	6.9	6.9	6.7	6.3	6.1	6.5	5.9	6.2	6.1
	5% WB	MCDBR	8.2	8.9	9.7	12.4	14.1	15.1	14.7	13.9	12.6	11.0	9.9	7.8
		MCWBR	6.9	6.9	7.0	7.1	6.7	6.3	6.3	5.8	6.6	6.7	6.5	6.3
Clear-Sky Solar Irradiance	taub	0.352	0.381	0.414	0.444	0.431	0.396	0.393	0.403	0.392	0.391	0.371	0.356	
	taud	2.440	2.341	2.235	2.179	2.274	2.416	2.422	2.389	2.427	2.401	2.420	2.445	
	Ebn at Noon	263	268	269	267	272	280	280	276	273	261	254	253	
	Edh at Noon	28	34	41	46	43	37	36	37	34	32	28	26	
All-Sky Solar Radiation	RadAvg	725	985	1459	1891	2254	2532	2528	2257	1838	1321	896	661	
	RadStd	72	80	81	128	96	74	35	34	68	61	61	75	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-112	N/A	N/A

Nomenclature: See separate page