

KITHIRA, Greece

WMO: 167430

Lat: 36.274N

Lon: 23.017E

Elev: 1045

StdP: 14.15

Time Zone: 2.00 (EUE)

Period: 90-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 39.9	(c) 42.0	(d) 24.8	(e) 19.6	(f) 44.3	(g) 28.4	(h) 23.2	(i) 45.3	(j) 57.7	(k) 44.2	(l) 50.8	(m) 45.3	(n) 20.3	(o) 40	(p) 0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 11.0	(c) 92.9	(d) 68.9	(e) 89.8	(f) 68.6	(g) 87.5	(h) 67.5	(i) 74.5	(j) 82.8	(k) 73.3	(l) 81.5	(m) 72.2	(n) 80.5	(o) 11.8	(p) 40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.9	122.8	78.9	70.7	117.7	78.4	69.4	112.5	77.9	38.7	82.6	37.6	81.6	36.6	80.7	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 42.1	(b) 33.9	(c) 29.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.9	52.1	52.3	54.1	59.6	66.0	74.9	79.8	80.8	74.9	68.2	61.4	54.3
	DBStd	11.33	4.62	4.77	4.80	4.52	5.08	4.99	4.78	4.00	4.13	5.02	4.45	4.87
	HDD50	99	33	27	17	1	0	0	0	0	0	0	1	20
	HDD65	1798	400	356	340	173	50	0	0	0	0	26	123	330
	CDD50	5550	98	91	144	290	497	748	924	953	746	563	342	154
	CDD65	1775	0	0	2	12	82	299	459	488	296	124	13	0
	CDH74	13256	0	0	2	28	223	1987	4380	4794	1597	244	1	0
	CDH80	4086	0	0	0	2	23	542	1561	1643	263	52	0	0
(14) Wind	WSAvg	12.0	13.8	13.9	13.5	11.2	10.7	9.9	9.9	10.5	10.9	13.1	12.1	14.8
(15) Precipitation	PrecAvg	21.8	3.9	2.7	1.9	1.0	0.5	0.1	0.0	0.2	0.7	1.6	4.6	4.6
	PrecMax	35.5	8.9	5.6	4.5	2.8	2.6	0.4	0.2	1.2	3.3	6.4	11.7	9.4
	PrecMin	13.5	1.0	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1	1.9	0.7
	PrecStd	5.7	2.2	1.5	1.2	0.9	0.6	0.1	0.0	0.3	0.9	1.7	2.2	2.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.8	66.6	70.0	77.4	82.7	92.2	99.8	96.3	89.9	87.0	72.9	67.5
		MCWB	58.2	55.0	56.3	59.2	65.0	66.0	67.7	68.3	69.0	61.4	64.6	61.1
	2%	DB	61.0	62.1	64.9	72.9	79.3	88.1	93.6	92.4	85.4	78.8	70.7	64.3
		MCWB	56.2	55.0	55.3	57.5	63.0	66.5	69.2	69.1	67.0	66.8	63.2	58.8
	5%	DB	59.7	60.1	61.6	69.5	76.6	85.5	89.9	89.7	82.6	76.1	68.9	62.4
		MCWB	54.8	54.7	54.7	55.8	61.9	66.2	68.5	68.8	67.8	66.7	62.6	56.6
	10%	DB	58.5	58.5	59.7	66.4	74.0	82.9	87.4	87.4	80.7	74.1	67.4	60.9
		MCWB	53.8	54.0	54.6	55.6	61.1	65.5	67.5	68.1	67.4	66.4	61.7	56.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.4	58.2	58.9	62.3	68.3	73.0	76.1	76.7	74.9	71.6	67.7	61.9
		MCDB	62.0	60.5	63.3	72.6	78.0	84.3	87.7	84.7	80.8	74.8	71.8	65.7
	2%	WB	57.4	56.7	57.6	59.9	65.9	70.8	74.1	74.7	73.1	70.4	65.0	59.7
		MCDB	59.8	59.6	61.2	66.2	74.2	81.3	83.0	82.9	79.6	74.3	68.4	62.8
	5%	WB	55.8	55.8	56.5	58.7	64.4	69.5	72.8	73.7	71.9	69.0	63.5	58.4
		MCDB	58.9	59.0	60.0	64.5	71.8	78.7	81.3	82.1	78.2	73.8	67.6	61.0
	10%	WB	54.3	54.7	55.4	57.6	63.1	68.2	71.5	72.5	70.7	67.7	62.4	57.0
		MCDB	58.0	58.2	59.0	63.3	70.4	77.7	80.9	81.3	77.6	73.2	67.0	60.6
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	6.7	6.9	8.5	9.1	11.1	11.4	11.0	9.1	7.5	6.8	6.6
		MCDBR	7.4	8.3	9.5	13.9	12.8	14.1	15.1	14.1	11.5	9.7	8.3	8.8
	5% WB	MCWBR	6.0	6.0	6.4	8.5	9.0	8.8	9.2	9.3	8.3	6.4	5.8	6.2
		MCDWR	6.4	6.4	7.8	10.2	10.9	12.2	12.0	11.3	9.9	8.0	7.0	6.4
(40) Clear-Sky Solar Irradiance	taub	taub	0.347	0.372	0.411	0.437	0.426	0.399	0.404	0.413	0.408	0.393	0.373	0.356
		taud	2.457	2.363	2.239	2.185	2.278	2.395	2.389	2.364	2.379	2.388	2.408	2.429
	Ebn at Noon	Ebn at Noon	267	272	271	269	273	279	277	273	268	262	254	254
		Edh at Noon	27	34	41	46	43	38	38	38	36	32	29	27
(44) All-Sky Solar Radiation	RadAvg	RadAvg	725	980	1441	1879	2193	2460	2469	2207	1756	1229	836	637
	RadStd	RadStd	64	89	94	126	91	84	45	39	80	78	72	59

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page