

SANTORINI, GreeceWMO: **167443**Lat: **36.399N**Lon: **25.479E**Elev: **127**StdP: **14.63**Time Zone: **2.00 (EUE)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	41.4	44.3	26.7	20.7	45.6	30.1	24.3	46.4	38.8	50.4	34.5	50.7	18.5	0	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	91.0	71.3	88.1	70.9	86.2	70.7	75.6	83.2	74.4	82.4	73.4	81.7	12.2	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.4	124.8	79.6	71.8	117.9	79.4	70.1	111.4	79.0	39.2	84.2	38.0	82.0	37.0	81.9	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.2	27.6	24.9	DB	38.8	96.4	3.9	4.3	35.9	99.4	33.6	101.9	31.4	104.3	28.5	107.4	(4)
(5)			WB	35.3	78.2	3.7	1.6	32.7	79.4	30.5	80.3	28.4	81.2	25.7	82.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.0	54.6	54.2	56.5	60.6	68.0	75.9	80.2	80.2	74.9	68.2	61.7	55.6	(6)	
	DBStd	10.40	4.79	5.01	4.17	3.86	3.86	4.18	3.07	2.69	3.65	3.95	4.01	4.84	(7)	
	HDD50	54	18	18	6	1	0	0	0	0	0	0	1	10	(8)	
	HDD65	1454	322	302	263	138	12	0	0	0	0	15	111	291	(9)	
	CDD50	5884	161	137	208	320	559	778	935	935	747	566	353	185	(10)	
	CDD65	1808	0	1	0	7	106	328	470	470	297	115	13	1	(11)	
	CDH74	13556	0	0	0	14	316	2359	4557	4421	1665	221	3	0	(12)	
	CDH80	3664	0	0	0	1	42	606	1434	1299	271	11	0	0	(13)	
(14) Wind	WSAvg	12.6	13.4	14.6	14.1	11.9	10.8	11.8	13.4	12.9	11.7	11.8	11.1	14.1	(14)	
(15) Precipitation	PrecAvg	11.4	1.9	1.9	1.1	0.6	0.4	0.0	0.0	0.0	0.2	0.9	1.5	2.6	(15)	
	PrecMax	21.2	4.3	5.3	3.0	2.8	2.8	0.3	0.1	0.2	2.5	4.4	3.0	5.9	(16)	
	PrecMin	4.9	0.0	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.7	(17)	
	PrecStd	4.3	1.2	1.2	0.9	0.7	0.7	0.1	0.0	0.0	0.6	1.2	0.8	1.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.5	67.8	68.1	75.5	84.4	94.8	95.1	91.8	88.2	81.0	73.5	68.4	(19)	
		MCWB	57.7	58.6	58.5	59.7	64.6	70.2	71.1	71.9	69.7	68.8	64.9	62.7	(20)	
	2%	DB	64.1	64.5	66.1	71.6	80.6	88.1	91.3	89.7	84.6	78.7	71.5	66.4	(21)	
		MCWB	57.4	57.5	58.0	58.9	64.1	69.0	71.2	71.8	70.0	68.5	63.8	60.7	(22)	
	5%	DB	62.6	62.7	64.4	69.4	77.2	85.7	88.2	87.8	82.7	76.6	69.8	64.6	(23)	
		MCWB	56.7	56.6	57.4	59.8	63.7	68.8	70.6	72.0	69.8	68.2	63.3	58.6	(24)	
	10%	DB	61.1	61.1	62.7	66.6	75.1	82.8	86.2	86.0	80.8	74.9	68.1	62.8	(25)	
		MCWB	55.6	55.6	56.6	58.5	63.3	68.4	70.6	71.6	69.5	67.0	62.0	57.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.0	60.3	61.1	63.6	68.4	74.6	77.2	78.0	76.0	72.3	67.2	64.4	(27)	
		MCDB	63.2	64.1	65.3	69.4	76.5	85.5	84.7	85.6	81.6	76.6	71.1	67.5	(28)	
	2%	WB	58.8	58.9	59.7	62.1	67.0	72.5	75.5	75.6	74.2	70.8	65.6	61.6	(29)	
		MCDB	62.3	62.9	63.9	67.4	74.9	82.4	83.2	83.5	79.6	75.5	69.6	65.3	(30)	
	5%	WB	57.3	57.4	58.7	60.9	65.7	71.1	74.2	74.5	72.9	69.4	64.2	59.6	(31)	
		MCDB	61.7	61.9	62.9	66.4	73.3	80.6	82.5	83.0	78.9	74.6	68.3	64.0	(32)	
	10%	WB	56.1	56.0	57.2	59.8	64.8	70.0	72.9	73.5	71.6	67.8	63.0	57.7	(33)	
		MCDB	60.7	60.7	61.9	65.2	72.3	79.6	82.0	82.3	78.5	73.4	67.1	62.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	8.2	8.8	10.2	11.0	11.7	11.2	10.6	10.3	9.3	9.5	7.8	(35)	
		MCDBR	8.6	9.0	10.1	13.5	14.2	14.3	14.0	13.2	12.2	11.0	10.6	8.7	(36)	
	5% WB	MCWBR	6.4	6.4	7.0	7.6	7.9	6.9	6.6	6.2	6.8	6.8	7.3	6.8	(37)	
		MCWBR	8.1	8.5	9.0	11.3	11.9	12.5	11.9	11.6	11.0	10.4	9.7	8.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.361	0.389	0.426	0.459	0.444	0.407	0.406	0.411	0.413	0.404	0.385	0.368	(40)	
		taud	2.416	2.317	2.200	2.131	2.237	2.389	2.394	2.372	2.374	2.362	2.376	2.404	(41)	
	Ebn at Noon		261	266	265	263	268	278	277	273	267	258	249	249	(42)	
		Edh at Noon	29	35	43	49	44	38	37	38	36	33	30	27	(43)	
(44) All-Sky Solar Radiation	RadAvg		715	951	1439	1876	2203	2499	2480	2220	1792	1271	863	642	(44)	
	RadStd		61	88	84	112	89	66	35	29	77	56	61	61	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (8 neighbors)		+0.58	N/A	+1.67	N/A	+1.03	+0.99	N/A	-121	+173	N/A	

Nomenclature: See separate page