

RHODES DIAGORAS, Greece

WMO: 167490

Lat: 36.405N

Lon: 28.086E

Elev: 19

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	43.0	46.0	23.5	17.7	46.6	28.1	22.1	48.5	26.2	52.8	23.2	52.2	12.5	310	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.3	90.5	73.0	88.4	73.2	87.0	73.2	77.9	84.7	76.8	83.8	75.9	83.0	14.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.6	133.9	82.0	74.8	130.6	81.6	73.5	124.8	81.0	41.4	84.4	40.4	83.8	39.5	83.0	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	22.5	20.5	18.8	DB	39.4	95.5	3.8	3.2	36.6	97.8	34.4	99.6	32.2	101.4	29.5	103.7
(5)				WB	33.4	80.2	3.2	1.7	31.0	81.5	29.2	82.4	27.4	83.4	25.0	84.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.6	55.0	55.4	58.3	62.8	69.6	76.7	80.9	81.7	77.7	71.1	63.8	57.9	(6)
(7)		DBStd	10.28	4.32	4.27	3.91	3.80	3.66	3.68	2.76	2.36	2.96	3.91	4.44	4.37	(7)
(8)		HDD50	28	13	9	2	0	0	0	0	0	0	0	0	4	(8)
(9)		HDD65	1170	309	267	209	84	5	0	0	0	0	5	69	222	(9)
(10)		CDD50	6471	169	162	259	385	607	802	957	983	830	653	415	249	(10)
(11)		CDD65	2137	0	0	1	19	147	352	492	518	380	193	34	1	(11)
(12)		CDH74	16839	0	0	1	42	427	2543	5014	5519	2723	547	23	0	(12)
(13)		CDH80	4667	0	0	0	2	48	620	1626	1812	523	36	0	0	(13)
(14)	Wind	WSAvg	9.1	7.5	7.9	8.5	8.7	9.4	11.4	12.6	12.3	10.5	7.6	6.1	6.9	(14)
(15)	Precipitation	PrecAvg	26.5	5.4	3.9	2.6	1.5	0.8	0.0	0.0	0.3	2.0	3.6	5.8	(15)	
(16)		PrecMax	39.4	11.5	8.0	5.5	6.8	5.8	0.3	0.2	0.2	2.3	8.3	10.8	13.2	(16)
(17)		PrecMin	12.9	0.0	0.9	0.1	0.2	0.0	0.0	0.0	0.0	0.2	0.2	0.0	0.0	(17)
(18)		PrecStd	6.1	2.7	2.0	1.7	1.3	1.2	0.1	0.0	0.6	1.9	2.4	3.0	3.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.5	66.6	71.5	78.9	84.3	91.5	93.4	94.1	89.8	83.8	76.9	69.3	(19)
MCWB			58.8	58.8	61.1	62.0	66.5	71.2	72.1	73.9	73.1	70.1	67.1	62.7	(20)	
2%		DB	64.0	64.6	68.1	74.0	80.8	88.0	90.2	90.2	86.2	80.6	73.7	67.6	(21)	
		MCWB	57.8	57.6	58.9	61.9	66.7	71.1	72.5	74.3	72.8	69.8	65.5	61.3	(22)	
5%		DB	62.6	63.0	66.1	71.6	78.5	85.9	88.2	88.2	84.4	78.7	71.9	66.0	(23)	
		MCWB	57.0	57.0	58.5	61.3	66.6	70.7	72.5	74.8	72.5	69.0	64.6	60.0	(24)	
10%		DB	61.1	62.0	64.4	69.4	76.1	83.8	86.4	86.5	82.7	77.0	70.2	64.4	(25)	
		MCWB	55.8	56.4	57.7	60.8	66.5	70.4	72.5	74.7	71.9	68.4	63.6	58.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.7	60.9	63.2	67.2	73.0	76.5	78.6	79.6	77.3	73.9	69.6	64.2	(27)
MCD B			63.7	64.3	68.2	73.8	77.0	83.3	84.7	86.1	83.9	78.8	73.3	67.8	(28)	
2%		WB	59.2	59.2	61.0	64.5	70.2	74.7	77.1	78.4	75.9	72.4	67.4	62.3	(29)	
		MCD B	62.4	63.0	65.4	70.4	76.0	81.3	84.0	85.4	82.5	77.4	71.9	66.0	(30)	
5%		WB	57.8	58.1	59.7	62.9	68.9	73.5	76.0	77.4	74.7	71.0	66.1	60.7	(31)	
		MCD B	61.4	62.1	64.2	68.6	75.0	80.5	83.2	84.4	81.3	76.2	70.6	64.5	(32)	
10%		WB	56.7	56.8	58.6	61.7	67.5	72.3	74.9	76.5	73.7	69.7	64.6	59.4	(33)	
		MCD B	60.5	61.1	63.2	67.3	73.7	80.0	82.4	83.7	80.3	75.0	69.4	63.4	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.6	9.0	9.6	10.6	10.8	10.9	10.3	9.7	9.8	9.8	8.9	(35)	
MCD BR			9.3	9.9	11.5	14.3	13.9	13.6	12.9	12.0	11.0	10.7	10.9	9.8	(36)	
MCWBR			6.7	7.1	7.3	8.4	8.5	7.2	6.7	6.7	6.8	6.3	6.7	6.4	(37)	
5% WB		MCD BR	8.4	9.1	10.5	11.9	11.4	11.3	10.9	10.2	10.0	10.1	10.0	8.8	(38)	
		MCWBR	7.1	7.3	7.6	8.3	8.3	7.4	7.3	6.7	7.3	7.0	7.1	6.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.359	0.389	0.424	0.457	0.444	0.407	0.406	0.421	0.400	0.400	0.376	0.360	(40)	
(41)		taud	2.426	2.321	2.205	2.141	2.238	2.388	2.389	2.343	2.404	2.383	2.410	2.443	(41)	
(42)		Ebn at Noon	262	266	266	263	268	278	277	271	271	259	252	253	(42)	
(43)		Edh at Noon	28	35	43	48	44	38	38	39	35	32	29	26	(43)	
(44)	All-Sky Solar Radiation	RadAvg	751	1022	1491	1914	2267	2541	2533	2267	1869	1347	927	691	(44)	
(45)		RadStd	75	83	87	127	103	68	39	33	67	68	61	71	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.54	N/A	N/A	+0.70	N/A	N/A	N/A	-74	+209	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-104	N/A	N/A

Nomenclature: See separate page