

HERAKLION, Greece

WMO: 167540

Lat: 35.340N

Lon: 25.180E

Elev: 115

StdP: 14.63

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	42.5	44.6	28.3	22.4	52.0	31.6	26.0	51.6	34.7	52.2	32.0	52.4	12.5	170	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.1	89.7	71.0	87.4	72.1	85.7	72.3	77.3	84.7	76.1	83.7	74.9	82.8	10.5	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.0	131.9	83.1	73.5	125.0	82.4	71.9	118.4	81.4	40.8	84.3	39.7	83.9	38.5	82.9	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.4	24.8	22.2	38.6	98.2	3.0	4.3	36.4	101.2	34.6	103.7	32.9	106.1	30.7	109.3
			35.2	79.6	2.9	2.0	33.2	81.0	31.5	82.2	29.9	83.3	27.8	84.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.9	54.2	54.4	56.7	61.2	67.5	74.3	78.8	78.9	74.7	68.9	62.8	57.1	(6)
	DBStd	9.92	4.54	4.77	4.79	5.09	4.56	4.19	2.88	2.59	3.27	4.44	4.87	4.78	(7)
	HDD50	34	14	12	4	0	0	0	0	0	0	0	0	4	(8)
	HDD65	1419	335	299	264	138	22	0	0	0	0	15	96	250	(9)
	CDD50	5825	145	135	211	336	543	730	893	897	742	585	385	223	(10)
	CDD65	1734	1	2	6	24	99	280	428	432	292	135	31	4	(11)
	CDH74	13787	1	6	29	151	481	2076	4266	4277	1933	485	76	6	(12)
	CDH80	3341	0	0	6	40	112	447	1180	1143	323	79	10	1	(13)
(14) Wind	WSAvg	10.5	11.4	11.7	11.0	9.9	8.7	9.5	11.4	11.3	9.8	9.8	10.1	11.2	(14)
(15) Precipitation	PrecAvg	18.8	3.5	2.8	2.4	1.1	0.6	0.1	0.0	0.0	0.6	2.2	2.3	3.3	(15)
	PrecMax	31.3	9.3	7.3	15.9	4.7	3.3	1.7	0.5	1.0	6.4	10.7	6.1	9.0	(16)
	PrecMin	10.3	0.2	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.3	(17)
	PrecStd	4.7	1.9	1.8	2.4	1.0	0.6	0.2	0.1	0.2	1.2	2.4	1.7	1.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.4	72.0	77.2	85.8	89.5	93.6	93.6	91.7	90.0	87.5	80.8	73.4	(19)
		MCWB	56.9	56.9	58.1	60.5	64.9	71.6	70.9	72.0	70.9	67.4	64.4	60.8	(20)
	2%	DB	65.9	67.6	71.6	77.5	82.6	87.5	89.2	87.9	85.5	81.5	75.5	69.5	(21)
		MCWB	56.4	56.5	56.7	57.7	63.5	70.2	72.3	73.6	71.5	67.6	63.7	59.9	(22)
	5%	DB	63.0	64.5	67.9	73.5	78.7	84.2	86.4	86.2	82.8	78.7	73.1	66.5	(23)
		MCWB	55.4	55.3	56.7	58.4	64.9	70.5	72.9	73.9	72.1	68.6	63.0	58.5	(24)
	10%	DB	61.1	62.3	64.7	69.9	75.6	82.2	85.0	84.6	81.4	76.6	70.2	64.5	(25)
		MCWB	54.6	55.0	56.5	59.4	64.6	70.1	72.6	73.6	71.4	67.6	62.3	57.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.4	59.9	62.0	67.1	72.4	77.2	78.7	79.1	77.4	72.9	68.4	63.3	(27)
		MCDB	65.8	66.6	69.2	75.7	78.6	85.3	85.7	85.8	83.6	79.1	75.4	70.2	(28)
	2%	WB	57.5	58.0	59.9	63.8	69.6	74.7	76.9	77.5	75.3	70.9	66.0	61.0	(29)
		MCDB	63.4	65.1	66.7	70.8	76.1	82.8	84.6	84.7	82.0	77.8	72.6	67.6	(30)
	5%	WB	56.2	56.4	58.5	61.9	67.9	73.1	75.6	76.3	73.8	69.4	64.3	59.2	(31)
		MCDB	61.9	63.1	65.2	68.6	74.9	81.4	83.7	83.8	80.9	76.5	71.0	65.5	(32)
	10%	WB	54.9	55.0	57.1	60.3	66.3	71.7	74.5	75.1	72.4	67.9	62.7	57.5	(33)
		MCDB	60.5	61.2	63.8	67.2	73.3	79.8	82.9	82.9	79.9	74.9	69.1	63.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.6	11.4	12.6	13.8	14.0	13.1	11.6	11.1	12.1	11.5	11.5	10.4	(35)
		MCDBR	13.2	14.3	17.3	19.3	18.6	15.9	14.4	13.3	14.5	15.1	14.2	13.2	(36)
	5% WB	MCWBR	8.6	9.2	10.6	11.9	11.6	11.9	11.1	10.8	11.1	9.6	8.5	8.6	(37)
		MCWBR	12.4	13.7	14.8	16.2	15.3	13.9	13.2	12.7	13.9	13.7	13.2	12.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.365	0.392	0.436	0.476	0.463	0.418	0.414	0.421	0.428	0.413	0.391	0.376	(40)
	taud		2.390	2.293	2.146	2.052	2.146	2.326	2.340	2.318	2.302	2.314	2.341	2.358	(41)
	Ebn at Noon		261	266	263	259	263	275	275	271	263	256	249	248	(42)
	Edh at Noon		30	36	46	53	49	41	40	40	39	35	31	29	(43)
(44) All-Sky Solar Radiation	RadAvg		742	990	1445	1869	2183	2472	2459	2207	1786	1275	882	655	(44)
	RadStd		61	95	93	110	92	67	36	42	78	66	68	50	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.61	N/A	+3.15	N/A	+1.67	+1.84	N/A	-117	+220
(47) Regional (5 neighbors)		+0.54	N/A	+2.16	N/A	+1.26	+1.35	N/A	-115	+193

Nomenclature: See separate page